

Facility Dynamics

ENGINEERING

Controlling Variable Air Volume Systems

Fan System Flow and Static Control (Supplemental)


Presented By:

David Sellers; Facility Dynamics Engineering


Senior Engineer

NAVFAC, San Diego

Varying Fan Volume



Varying Fan Volume




Single Zone Technique

- Modulate based on zone temperature

Multiple Zones

- Zones modulate based on temperature
- Fixed pressure may be maintained at some point in the system

Varying Fan Volume




Single Zone Technique

- Modulate based on zone temperature


Multiple Zones

- Zones modulate based on temperature
- Fixed pressure may be maintained at some point in the system
- Fan follows the total zone flow requirement
- Work on a family of system curves

Varying Fan Volume




Varying Fan Volume



Discharge Dampers

- Push the fan up its curve
- Approach the surge line
- Noise can be an issue

Varying Fan Volume



Inlet Guide Vanes

- Direct the flow into the fan wheel imparting “swirl”
- Changes the shape of the surge line
- Droops the fan curve
- Tend to follow the system curve
- May be integral to the fan’s peak efficiency point

Inlet Guide Vanes; Directing Airflow into the Fan Wheel



TAB 20-4 - FAN FLOW AND STATIC CONTROL

Inlet Guide Vanes; Directing Airflow into the Fan Wheel




Inlet Guide Vanes; Directing Airflow into the Fan Wheel



Inlet Guide Vanes; Directing Airflow into the Fan Wheel



Inlet Guide Vanes; Should You Remove Them if you Retrofit a VSD?



Inlet Guide Vanes; Should You Remove Them if you Retrofit a VSD?

“It Depends”


Jay Santos

See *Inlet Guide Vanes (IGVs) and Variable Speed Drives(VSDs)* at <http://av8rdas.wordpress.com/> for more information

Adding VFDs?
Remove the Vanes (Maybe),
Leave the Inlet Cone (For Sure)

08/10/2006

Varying Fan Volume




Varying Speed

Traditional balancing approach
Family of similar shaped operating curves

Tends to preserve the efficiency at the original operating point

- Tend to follow the system curve

Varying Fan Volume



System Curve

Varying Blade Pitch

Vane axial fan approach

Similar to speed variation in terms of power reduction

Tend to follow the system curve

Mechanically complex


TWO STAGE CONTROLLABLE PITCH FAN**ITEM NUMBERS**

Image courtesy AVA HVAC Products

TAB 20-4 - http://avahvacproducts.com/Joy_Fan_Service_Parts.html

JO14C

CONTROLLABLE PITCH ROTOR ASSY
17 $\frac{1}{2}$ " , 21" AND 26 $\frac{1}{2}$ " HUB
ORDERING REPAIR PARTS

- * GIVE FAN MODEL
- * GIVE FAN SERIAL NUMBER
- * GIVE FAN ITEM NUMBER

ITEM NUMBERS

- 1) C.P. BLADE
- 2) TEFLON WASHER
- 3) BUSHING
- 4) 26-1/2" HUB
- 5) HUB INSERT
- 6) SPACER
- 7) THRUST WASHER
- 8) BUTTON HEAD CAP SCREW
- 9) FLAT WASHER
- 10) LOCK NUT
- 11) CLAMP
- 12) WASHER
- 13) NUT
- 14) SUPPORT WASHER
- 15) ROLLER
- 16) SOCKET HEAD SHOULDER SCREW
- 17) INSERT LOCK RING
- 18) HEX SOCKET HEADLESS SET SCREW

NEW PHILADELPHIA FAN COMPANY




Image courtesy AVA HVAC Products

http://avahvacproducts.com/Joy_Fan_Service_Parts.html

TAB 20-4 - FAN FLOW AND STATIC CONTROL



TAB 20-4 - FAN FLOW AND STATIC CONTROL







TAB 20-4 - FAN FLOW AND STATIC CONTROL

Power Consumption Comparison

Source:
Howden Buffalo
Fan Engineering
9th Edition



Power Consumption Comparison



Greenheck publishes inlet vane performance metrics and other useful information like torque requirements in *Dampers for Centrifugal Fans – Inlet and Outlet*

http://www.greenheck.com/media/pdf/catalogs/centrifugal_damper_catalog.pdf

Parallel Fan Considerations

- Backdraft dampers are desirable
- Back draft dampers are not perfect
 - Fan wheels can be massive




Parallel Fan Considerations

- Backdraft dampers are:
 - Desirable
 - Not perfect
- Fan wheels can be massive
- Fan wheels can have large moment's of inertia

$$\text{Moment of Inertia} = I = \sum mr^2$$


- Things with a lot of inertia tend to stay in motion once they are set in motion
 - VSD have to deal with this when starting against a spinning motor
 - Hub bolts and shafts have to deal with this when starting against a spinning motor

Size	Wheel Diameter, in.	Maximum RPM	Class 1		Class 2		
			Weight, lb	WR ² , lb-ft ²	Maximum RPM	Weight, lb	WR ² , lb-ft ²
Aluminum DWBI Wheels							
122	12.25	3,957	14	1	5,158	15	1
135	13.50	3,374	15	2	4,398	18	2
150	15.00	3,232	22	2	4,213	24	2
165	16.50	2,761	25	4	3,599	28	5
182	18.25	2,248	29	10	2,930	29	10
200	20.00	2,051	36	11	2,674	40	14
222	22.25	1,837	45	18	2,395	53	21
245	24.50	1,668	53	32	2,175	62	37
270	27.00	1,541	62	45	2,009	69	50
300	30.00	1,387	80	75	1,808	86	81
330	33.00	1,261	108	122	1,644	114	129
365	36.50	1,114	109	154	1,452	123	174
402	40.25	1,010	133	236	1,317	144	256
445	44.50	914	191	353	1,191	222	416
490	49.00	830	245	584	1,082	260	619
542	54.25	750	339	945	977	337	939
600	60.00	678	380	1,388	883	376	1,372
660	66.00	616	495	1,972	803	499	1,987
730	73.00	557	593	2,949	726	716	3,832
807	80.75	504	727	4,382	656	819	4,955
890	89.00	457	1,131	8,259	596	1,295	9,429
982	98.25	414	1,340	12,230	539	1,541	13,979
Steel DWBI Wheels							
270	27.00	1,541	152	116	2,009	170	117
300	30.00	1,387	201	176	1,808	197	176
330	33.00	1,261	263	272	1,644	254	272
365	36.50	1,114	326	439	1,452	335	440
402	40.25	1,010	395	640	1,317	390	640
445	44.50	914	516	981	1,191	557	984
490	49.00	830	585	1,427	1,082	618	1,430
542	54.25	750	739	2,128	977	771	2,247
600	60.00	678	906	3,338	883	897	3,338
660	66.00	616	1,349	5,213	803	1,375	5,217
730	73.00	557	1,571	8,239	726	1,582	8,243
807	80.75	504	1,876	12,195	656	1,992	12,933
890	89.00	457	2,827	21,881	596	2,842	21,887
982	98.25	414	3,329	31,933	539	3,343	31,941



The Two Thirds Rule Applies to Air Handling Systems Too


Optimization Strategies



Move the Sensor

- Transportation delays may be an issue
- Long wiring runs may be an issue


Optimization Strategies



Solving the Wiring Run Problem

- Transportation delays may be even more of an issue
- Network failure = Open control loop
- Delays and/or open loop could = Open duct

Optimization Strategies




Having Your Cake and Eating It Too

- Add a sensor at the fan discharge to control the supply fan
- Reset the discharge sensor set point based on a remote sensor using the network to transmit the data

Optimize the resetting sensor location using the “two thirds” rule


Optimization Strategies



DDC Zone Controls Offer Additional Opportunities

- Reset discharge static based on conditions at the terminal unit to keep at least one zone damper nearly wide open
- Monitor ongoing operation to identify and resolve “rogue” zones


Optimization Strategies



Discharge Temperature Optimization

- Potentially interactive with discharge pressure optimization

Optimization Strategies



Discharge Temperature Optimization

- Potentially interactive with discharge pressure optimization

$$Q_{Zone} = 1.08 \times cfm_{Zone} \times (t_{Zone} - t_{Supply})$$

If:


Q_{Zone} and t_{Zone} are constant

And:

t_{Supply} goes up

Then:

$t_{Zone} - t_{Supply}$ gets smaller and cfm must increase to keep everything in balance



Can Systems with Pneumatic Zones and
DDC Central Systems be Optimized?