

Facility Dynamics

ENGINEERING

Controlling Variable Air Volume Systems

Supply and Return Fan Flow Management and Tracking
(Supplemental)

Presented By:

David Sellers; Facility Dynamics Engineering


Senior Engineer

NAVFAC, San Diego

A Word about Return and Relief Fans

Return Fans


- Overcome the static pressure loss between the zone and the air handling system
- Operate any time the supply fan runs
 - Return air for recirculation
 - Frequently, deliver air to the relief louver for discharge to the exterior when operating on an economizer cycle
- Coordinating with VAV supply operation is tricky



A Word about Return and Relief Fans

Relief Fans


- Overcome the static pressure loss between the air handling unit location and the relief louver
- Only operate during an economizer cycle
- VFD operation often coordinated with building pressure



Large, Slow Speed Fan Considerations

Because of their moment of inertia, large, slow speed fans can require a larger motor to start them than they need to run them

- Large = heavy fan wheels with a high moment of inertia
- Slow speed = Not doing a lot of work, relatively speaking



Large, Slow Speed Fan Considerations

Because of their moment of inertia, large, slow speed fans can required a larger motor to start them than they need to run them

- Large = heavy fan wheels with a high moment of inertia
- Slow speed = Not doing a lot of work, relatively speaking

Motor starting torque capabilities can vary radically from manufacturer to manufacturer

| WR ² Values For Open Drip-Proof Motors | | | | | | | | |
|---|--------|------------------|---------------|------------------|-------------------|-----------------|-------------|-----------------|
| 1750 rpm | | | | | | | | |
| HP | Baldor | General Electric | Gould Century | Lincoln Electric | Marathon Electric | Reliance Motors | U.S. Motors | Leeson Electric |
| 1 | 11 | 14 | 15 | 13 | NA | 20 | 53 | 14 |
| 1-1/2 | 20 | 20 | 21 | 18 | NA | 30 | 47 | 21 |
| 2 | 25 | 27 | 27 | 25 | NA | 40 | 43 | 27 |
| 3 | 35 | 41 | 37 | 26 | NA | 50 | 30 | 38 |
| 5 | 55 | 68 | 52 | 44 | NA | 70 | 70 | 60 |
| 7-1/2 | 80 | 59 | 64 | 55 | NA | 100 | 143 | 85 |
| 10 | 100 | 53 | 82 | 71 | NA | 124 | 208 | 110 |
| 15 | 150 | 103 | 152 | 93 | 135 | 185 | 579 | 140 |
| 20 | 200 | 118 | 236 | 121 | 190 | 260 | 139 | NA |
| 25 | 240 | 135 | 265 | 185 | 190 | 300 | 266 | NA |
| 30 | 290 | 166 | 367 | 244 | 230 | 305 | 362 | NA |
| 40 | 370 | 228 | 447 | 394 | 305 | 450 | 202 | NA |
| 50 | 400 | 277 | 572 | 546 | 320 | 490 | 222 | NA |
| 60 | 450 | 400 | 637 | 502 | 375 | 580 | 550 | NA |
| 75 | 500 | 380 | 683 | 691 | 555 | 950 | 739 | NA |
| 100 | NA | 876 | 954 | 1,111 | 610 | 1,000 | 1,254 | NA |
| 125 | NA | 912 | 1,136 | 1,284 | 765 | 1,270 | 2,019 | NA |
| 1150 rpm | | | | | | | | |
| HP | Baldor | General Electric | Gould Century | Lincoln Electric | Marathon Electric | Reliance Motors | U.S. Motors | Leeson Electric |
| 1 | 30 | 38 | 45 | 24 | NA | 34 | 153 | NA |
| 1-1/2 | 45 | 56 | 50 | 25 | NA | 73 | 59 | NA |
| 2 | 60 | 75 | 72 | 32 | NA | 84 | 77 | NA |
| 3 | 90 | 69 | 85 | 48 | NA | 86 | 161 | NA |
| 5 | 145 | 88 | 117 | 79 | NA | 150 | 517 | NA |
| 7-1/2 | 210 | 142 | 290 | 104 | 320 | 210 | 612 | NA |
| 10 | 270 | 164 | 385 | 137 | 370 | 270 | 250 | NA |
| 15 | 400 | 201 | 573 | 206 | 430 | 430 | 380 | NA |
| 20 | 500 | 282 | 865 | 274 | 585 | 480 | 574 | NA |
| 25 | 650 | 342 | 944 | 390 | 645 | 750 | 738 | NA |
| 30 | 750 | 457 | 1,145 | 454 | 855 | 870 | 1,037 | NA |
| 40 | 1,000 | 725 | 1,350 | 764 | 770 | 930 | 1,004 | NA |
| 50 | 1,200 | 826 | 1,547 | 942 | 1,035 | 1,080 | 1,562 | NA |
| 60 | NA | 865 | 1,732 | 1,003 | 1,710 | 1,400 | 4,953 | NA |
| 75 | NA | 1,121 | 1,864 | 1,237 | 2,140 | 1,600 | 6,815 | NA |
| 100 | NA | 1,945 | 1,987 | 2,003 | 1,875 | 2,100 | NA | NA |
| 125 | NA | 2,153 | 2,342 | 2,994 | 2,505 | 2,600 | NA | NA |
| Notes: | | | | | | | | |
| 1. Values are for T-frame motors. | | | | | | | | |
| 2. WR ² is at motor shaft as measured in LB - Ft ² . | | | | | | | | |
| 3. NA = Not Available. | | | | | | | | |
| 4. WR ² is the same as WK ² which is used by many manufacturers. | | | | | | | | |
| 5. Data from Penn Barry Engineering Data 16000 - Fan Starting Requirements and WR ₂ Values for Motors. | | | | | | | | |

Large, Slow Speed Fan Considerations

Because of their moment of inertia, large, slow speed fans can required a larger motor to start them than they need to run them

- Large = heavy fan wheels with a high moment of inertia
- Slow speed = Not doing a lot of work, relatively speaking

Motor starting torque capabilities can vary radically from manufacturer to manufacturer

WR² Values For Totally Enclosed Fan Cooled Motors

| 1750 rpm | | | | | | | | |
|----------|--------|------------------|---------------|------------------|-------------------|-----------------|-------------|-----------------|
| HP | Baldor | General Electric | Gould Century | Lincoln Electric | Marathon Electric | Reliance Motors | U.S. Motors | Leeson Electric |
| 1 | 11 | 14 | 16 | 13 | NA | 20 | 43 | 14 |
| 1-1/2 | 20 | 20 | 22 | 18 | NA | 30 | 34 | 21 |
| 2 | 25 | 27 | 27 | 25 | NA | 40 | 83 | 27 |
| 3 | 34 | 41 | 37 | 26 | NA | 50 | 34 | 38 |
| 5 | 54 | 68 | 52 | 44 | NA | 70 | 73 | 58 |
| 7-1/2 | 80 | 55 | 64 | 55 | NA | 100 | 154 | 80 |
| 10 | 100 | 57 | 82 | 71 | NA | 124 | 336 | 90 |
| 15 | 150 | 110 | 213 | 93 | 215 | 185 | 184 | NA |
| 20 | 200 | 152 | 293 | 121 | 290 | 270 | 271 | NA |
| 25 | 240 | 267 | 397 | 185 | 265 | 300 | 315 | NA |
| 30 | 290 | 325 | 492 | 244 | 315 | 390 | 590 | NA |
| 40 | 370 | 396 | 622 | 394 | 475 | 530 | 561 | NA |
| 50 | 440 | 496 | 736 | 546 | 610 | 640 | 637 | NA |
| 60 | 490 | 609 | 933 | 502 | 580 | 770 | 1,037 | NA |
| 75 | 530 | 837 | 1,134 | 691 | 710 | 1,000 | 1,103 | NA |
| 100 | NA | 1,073 | 1,525 | 1,111 | 1,075 | 1,540 | NA | NA |
| 125 | NA | 1,389 | 2,132 | 1,284 | 1,340 | 1,820 | NA | NA |
| 1150 rpm | | | | | | | | |
| HP | Baldor | General Electric | Gould Century | Lincoln Electric | Marathon Electric | Reliance Motors | U.S. Motors | Leeson Electric |
| 1 | 30 | 38 | 45 | 24 | NA | 34 | 235 | NA |
| 1-1/2 | 45 | 56 | 50 | 25 | NA | 73 | 51 | NA |
| 2 | 65 | 75 | 72 | 32 | NA | 84 | 65 | NA |
| 3 | 95 | 69 | 85 | 48 | NA | 86 | 142 | NA |
| 5 | 150 | 88 | 117 | 79 | NA | 150 | 450 | NA |
| 7-1/2 | 215 | 142 | 382 | 104 | 345 | 220 | 539 | NA |
| 10 | 280 | 164 | 513 | 137 | 315 | 300 | 224 | NA |
| 15 | 410 | 398 | 738 | 206 | 495 | 430 | 767 | NA |
| 20 | 510 | 443 | 916 | 274 | 645 | 660 | 1,662 | NA |
| 25 | 620 | 694 | 1,049 | 390 | 750 | 750 | 1,077 | NA |
| 30 | 700 | 854 | 1,293 | 454 | 875 | 870 | 1,506 | NA |
| 40 | 950 | 785 | 1,745 | 764 | 1,230 | 980 | 2,848 | NA |
| 50 | 1,150 | 1,152 | 2,268 | 942 | 1,455 | 1,570 | 4,624 | NA |
| 60 | NA | 1,442 | 3,764 | 1,003 | 2,785 | 2,000 | NA | NA |
| 75 | NA | 1,713 | 4,660 | 1,237 | 3,280 | 2,100 | NA | NA |
| 100 | NA | 2,448 | 5,534 | 2,003 | 3,595 | 3,700 | NA | NA |
| 125 | NA | 2,781 | 6,820 | 2,994 | 4,485 | 4,300 | NA | NA |

Notes:

1. Values are for T-frame motors.

2. WR² is at motor shaft as measured in LB - Ft².

3. NA = Not Available.

4. WR² is the same as WK² which is used by many manufacturers.

5. Data from Penn Barry Engineering Data 16000 - Fan Starting Requirements and WR₂ Values for Motors.

A Few Rules of Thumb

From Twin City Engineering Bulletin ED-1800

1. Remember, the motor has to accelerate the motor armature and the drive system in addition to the fan wheel itself.
2. Acceleration time can be estimated as follows:

$$Time_{Acceleration} = \left(\frac{WR^2_{MotorSpeedReference} \times MotorSpeed}{308 \times (1.5 \times MotorFullLoadTorque)} \right)$$

Where:

$Time_{Acceleration}$ = Acceleration time in seconds

$WR^2_{MotorSpeedReference}$ = Moment of inertia of the load, referenced to the motor speed

$MotorFullLoadTorque$ = Motor rating in lb-ft

Taken from Twin City Fan Engineering Letter ED-1800 "Application Guide for Selecting AC Motors Capable of Overcoming Fan Inertia"

3. Totally enclosed fan cooled motor WK^2 capabilities can be estimated as follows:
 - 3600 rpm motor $WK^2 = 2.25 \times \text{motor hp}$
 - 1800 rpm motor $WK^2 = 13.5 \times \text{motor hp}$
 - 1200 rpm motor $WK^2 = 37.5 \times \text{motor hp}$
 - 900 rpm motor $WK^2 = 80.0 \times \text{motor hp}$

Matching VAV Supply and Return Fan Performance

A Number of Options

- Speed tracking
- Flow tracking
- Building static pressure based
- Return fan discharge static pressure based
- Mixed air plenum static pressure based

A Number of Issues

- Minimum outdoor air flow control
- Building make-up/exhaust balance
- Zone pressure control
- Building pressurization
- Economizer performance

Matching VAV Supply and Return Fan Performance

A Number of Options

- Speed tracking
- Flow tracking
- Building static pressure based
- Return fan discharge static pressure based
- Mixed air plenum static pressure based

National Building Controls Information Program

Application Guideline
Return Fan Capacity Control via Speed Control
October 2009

The guideline explores the speed control strategies commonly used to match return fan capacity to a variable air volume system application. While return fan performance in building applications, the guideline focuses primarily on return fan capacity control via speed control.

The guideline is divided into a fundamental chapter, followed by a chapter focusing on each of the speed control configurations. Each chapter is designed to present the design, testing, and commissioning and installation, and finally, the performance and energy efficiency of the system.

While the focus of the guideline is on speed control, it also includes information on other return fan capacity control strategies, such as flow tracking, static pressure tracking, and return fan discharge static pressure tracking. The guideline also includes information on the design, testing, and commissioning and installation, and finally, the performance and energy efficiency of the system.

Table of Contents

| | |
|---|-----|
| 1. Introduction and Fundamentals | 1.0 |
| 2. Speed Tracking Control | 2.0 |
| 3. Flow Tracking Control | 3.0 |
| 4. Building Pressure Control | 4.0 |
| 5. Discharge Pressure Control | 5.0 |
| 6. Mixed Air Plenum Pressure Control | 6.0 |
| Appendix A - Introduction and Overview | A.0 |
| Appendix B - Component Testing and Operation | B.0 |
| Appendix C - Minimum Outdoor Air Flow Requirements | C.0 |
| Appendix D - Return Control via Flow for Single Speed Return | D.0 |
| Appendix E - Control System Architecture and Software Issues | E.0 |
| Appendix F - Fan and Drive System Considerations | F.0 |
| Appendix G - The Relationship Between Design, Installation, and Operation | G.0 |
| Appendix H - Fan and Return System Performance | H.0 |
| Appendix I - Minimum Outdoor Air Requirements and Return Fan Capacity Control | I.0 |
| Index of Terms | 1.0 |
| References | 1.0 |


NBICIP - National Building Controls Information Program

Matching VAV Supply and Return Fan Performance

Theory vs. Reality: Applying a VFD to a VAV System Return Fan:


- 25,000 cfm fan system
- Serves an average low-rise office building
- Design intent – provide a constant 5,000 cfm minimum outdoor air flow
- Supply fan controlled to maintain a fixed discharge static pressure
- Supply fan static = 3.5 inches w.c.
 - 1.5 inches w.c. internal
 - 2.0 inches w.c. external
- Return fan controlled by signal tracking technique

The System Diagram




The Design Selection Points

Supply Fan - Greenheck 36-AFDV



Return Fan - Greenheck SFB-30-150





Flow differential = 5,000 cfm

Step 1:

The VAV Terminal Unit Throttles from 5,000 to 0 cfm

The VAV box throttling forces the supply fan up its curve



Since the supply fan speed is unchanged, the return fan operating point is virtually unchanged



Flow differential = 0 cfm

Step 2: The Supply Fan and Return Fan Operating Points Shift

The supply fan VFD slows down to bring the discharge static under control by moving the operating point down the new system curve

Return Fan - Greenheck SFB-30-150

The return fan speed is reduced by an equal percentage and its operating point shifts down the system curve



Flow differential = 0 cfm



Step 3:

The Supply Fan and Return Fan Operating Points Shift

The supply fan speed increases to maintain the discharge static pressure as the VAV boxes reposition to re-establish the required flow rate

Return Fan - Greenheck SFB-30-150

The return fan speed is increased by an equal percentage and its operating point shifts up the system curve



Flow differential = 2,067 cfm

Summary

| Step | Flow | | | | | | | |
|--------|--------|-----------|--------|-----------|-------------|-------------|--------------------------|-------------|
| | Supply | | Return | | Outdoor Air | | OA Deviation from Design | |
| | cfm | % Change | cfm | % Change | cfm | % of Supply | cfm | % of Supply |
| Design | 25,000 | Base case | 20,000 | Base case | 5,000 | 20% | Base case | Base case |
| 1 | 20,000 | 20% | 20,000 | 0% | 0 | 0% | -5,000 | -20% |
| 2 | 17,650 | 29% | 17,650 | 12% | 0 | 0% | -5,000 | -20% |
| 3 | 20,000 | 20% | 17,933 | 10% | 2,067 | 10% | -2,933 | -10% |

| Step | Speed | | | | | |
|--------|--------|--------|-----------------------|-----------|-----------|-----------|
| | Supply | Return | Change from Base Case | | | |
| | | | Supply | | Return | |
| | rpm | rpm | rpm | % | rpm | % |
| Design | 895 | 463 | Base case | Base case | Base case | Base case |
| 1 | 895 | 463 | 0 | 0% | 0 | 0% |
| 2 | 790 | 409 | -105 | -12% | -54 | -12% |
| 3 | 803 | 415 | -92 | -10% | -48 | -10% |