



Cooling Load Check Figures																		
Classifications	Occupancy Sq Ft/Person			Lights and Other Electrical Watts/Sq Ft			Refrigeration Sq Ft/Ton†			Supply Air Rate						CFM/Sq Ft		
	Lo	Av	Hi	Lo	Av	Hi	Lo	Av	Hi	East-South-West			North			Internal		
										Lo	Av	Hi	Lo	Av	Hi	Lo	Av	Hi
Apartment, High Rise	325	175	100	0.7	0.9	1.1	450	400	350	0.8	1.2	1.7	0.5	0.8	1.3	-	-	-
Auditoriums, Churches, Theaters	15	11	6	0.5	0.7	0.9	400	250	90	-	-	-	-	-	-	1.0	2.0	3.0
Educational Facilities	30	25	20	0.75	1.0	1.1	240	185	150	1.0	1.6	2.2	0.9	1.3	2.0	0.8	1.2	1.9
Schools, Colleges, Universities																		
Factories - Assembly Areas	50	35	23	2.5†	4.0†	5.5†	240	150	90	-	-	-	-	-	-	2.0	3.6	5.5
Light Manufacturing	200	150	100	7.5†	9†	11†	200	150	100	-	-	-	-	-	-	1.6	2.5	3.8
Heavy Manufacturing*	200	250	300	12†	25†	30†	100	80	60	-	-	-	-	-	-	2.5	4.0	6.5
Hospitals - Patient Rooms	70	50	25	0.5	0.75	1.0	275	220	165	1.0	1.5	2.0	0.8	1.2	1.4	0.7	1.0	1.3
Public Areas	100	80	50	0.5	0.75	1.0	175	140	110	1.0	1.25	1.45	1.0	1.1	1.2	0.95	1.0	1.1
Hotels, Motels, Dormitories	200	150	100	0.5	0.75	1.0	350	300	220	1.0	1.40	1.5	0.9	1.2	1.4	-	-	-
Libraries and Museums	80	60	40	0.5	0.75	1.0	340	280	200	1.0	1.6	2.1	0.9	1.1	1.3	0.9	1.0	1.1
Office Buildings (General)	130	110	80	2†	2.5†	4†	360	280	190	1.0	1.6	2.2	0.9	1.3	2.0	0.8	1.0	1.2
Private Offices	150	125	100	0.5	0.75	1.0	-	-	-	1.2	1.8	2.4	1.1	1.5	1.8	0.8	1.2	1.4
Stenographic Department	100	85	70	1.0	1.25	1.5	-	-	-	-	-	-	-	-	-	0.9	1.3	2.0
Residential - Large	600	400	200	0.5	1.0	1.5	600	500	380	0.8	1.2	1.6	0.5	0.8	1.3	-	-	-
Medium	600	360	200	0.5	1.0	1.5	700	550	400	0.7	1.1	1.4	0.5	0.7	1.2	-	-	-
Small	17	15	13	0.5	1.0	1.5	135	100	80	1.8	2.4	3.7	1.2	1.6	2.1	0.9	1.1	1.4
Restaurants - Large																		
Medium							150	120	100	1.5	2.0	3.0	1.1	1.4	1.8	0.9	1.0	1.3
Shopping Centers, Department Stores and Specialty Shops																		
Beauty and Barber Shops	45	40	25	3.0†	5.0†	9.0†	240	160	105	1.5	2.6	4.2	1.1	1.7	2.6	0.9	1.3	2.0
Malls	100	75	50	1.0	1.5	2.0	365	230	160	-	-	-	-	-	-	1.1	1.8	2.5
Refrigeration for Central Heating and Cooling Plant																		
Urban Districts							475	380	285									
College Campuses							400	320	240									
Commercial Centers							330	265	200									
Residential Centers							625	500	375									

Refrigeration and air quantities for applications listed in this table of cooling load check figures are based on all-air system and normal outdoor air quantities for ventilation except as noted.

Notes: †Refrigeration loads are for entire application

*Air quantities for heavy manufacturing areas are based on supplementary means to remove excessive heat.



2009 ASHRAE Pocket Guide (I-P) (SECURED) - Adobe Acrobat Standard DC

File Edit View Window Help

Home Tools Document 142 (153 of 273) 131% Sign In

Surface Conductances and Resistances for Air

Position of Surface	Direction of Heat Flow	Surface Emittance, ϵ					
		Non-reflective $\epsilon = 0.90$		Reflective $\epsilon = 0.05$			
		h_i	R	h_i	R	h_i	R
STILL AIR							
Horizontal	Upward	1.63	0.61	0.91	1.10	0.76	1.32
Sloping—45°	Upward	1.60	0.62	0.88	1.14	0.73	1.37
Vertical	Horizontal	1.46	0.68	0.74	1.35	0.59	1.70
Sloping—45°	Downward	1.32	0.76	0.60	1.67	0.45	2.22
Horizontal	Downward	1.08	0.92	0.37	2.70	0.22	4.55
MOVING AIR (Any position)							
15-mph Wind (for winter)	Any	h_o	R				
		6.00	0.17	—	—	—	—
7.5-mph Wind (for summer)	Any	4.00	0.25	—	—	—	—

Notes:
 1. Surface conductance h_i and h_o measured in $\text{Btu/h ft}^2 \text{ }^\circ\text{F}$; resistance R in $\text{ft}^2 \text{ h/Btu}$.
 2. No surface has both an air space resistance value and a surface resistance value.
 3. Conductances are for surfaces of the stated emittance facing virtual blackbody surroundings at the same temperature as the ambient air. Values are based on a surface-air temperature difference of 10 $^\circ\text{F}$ and for surface temperatures of 70 $^\circ\text{F}$.
 4. Condensate can have a significant impact on surface emittance.

Emittance Values of Various Surfaces and Effective Emittances of Air Spaces^a

Surface	Average Emittance ϵ	Effective Emittance ϵ_{eff} of Air Space	
		One Surface Emittance ϵ ; Other, 0.9	Both Surfaces Emittance ϵ
Aluminum foil, bright	0.05	0.05	0.03
Aluminum foil, with condensate just visible (> 0.7 gr/ft ²)	0.30	0.29	—
Aluminum foil, with condensate clearly visible (> 2.9 gr/ft ²)	0.70	0.65	—
Aluminum sheet	0.12	0.12	0.06
Aluminum coated paper, polished	0.20	0.20	0.11
Steel, galvanized, bright	0.25	0.24	0.15
Aluminum paint	0.50	0.47	0.35
Building materials: wood, paper, masonry, nonmetallic paints	0.90	0.82	0.82
Regular glass	0.84	0.77	0.72

^aThese values apply in the 4 to 40 μm range of the electromagnetic spectrum.

2009 ASHRAE Pocket Guide (I-P) (SECURED) - Adobe Acrobat Standard DC

File Edit View Window Help

Home Tools Document

143 (154 of 273)

131%

...

?

Sign In

Effective Thermal Resistance of Ventilated Attics^a (Summer Condition)

Part A. Nonreflective Surfaces

Ventilation Air Temperature, °F	Sol-Air ^b Temperature, °F	Not Ventilation ^b	Natural Ventilation	Power Ventilation ^c									
				Ventilation Rate, cfm/ft ²									
				Ceiling Resistance R ^d , °F·ft ² ·h/Btu									
				0	0.1	0.5	1.0	1.5					
				10	20	10	20	10	20	10	20	10	20
80	120	1.9	1.9	2.8	3.4	6.3	9.3	9.6	16	11	20		
80	140	1.9	1.9	2.8	3.5	6.5	10	9.8	17	12	21		
80	160	1.9	1.9	2.8	3.6	6.7	11	10	18	13	22		
100	120	1.9	1.9	2.2	2.3	3.3	4.4	4.0	6.0	4.1	6.9		
100	140	1.9	1.9	2.4	2.7	4.2	6.1	5.8	8.7	6.5	10		
100	160	1.9	1.9	2.6	3.2	5.0	7.6	7.2	11	8.3	13		

Part B. Reflective Surfaces^e

80	120	6.5	6.5	8.1	8.8	13	17	17	25	19	30		
80	140	6.5	6.5	8.2	9.0	14	18	18	26	20	31		
80	160	6.5	6.5	8.3	9.2	15	18	19	27	21	32		
100	120	6.5	6.5	7.0	7.4	8.0	10	8.5	12	8.8	12		
100	140	6.5	6.5	7.3	7.8	10	12	11	15	12	16		
100	160	6.5	6.5	7.6	8.2	11	14	13	18	15	20		

^aAlthough the term effective resistance is commonly used when there is attic ventilation, this table includes values for situations with no ventilation. The effective resistance of the attic added to the resistance (1/U) of the ceiling yields the effective resistance of this combination based on sol-air and room temperatures. These values apply to wood frame construction with a roof deck and roofing that has a conductance of 1.0 Btu/h·ft²·°F.

^bThis condition cannot be achieved in the field unless extreme measures are taken to tightly seal the attic.

^cBased on air discharging outward from attic.

^dWhen determining ceiling resistance, do not add the effect of a reflective surface facing the attic, as it is accounted for in part B of this table.

^eRoof surface temperature rather than sol-air temperature can be used if 0.25 is subtracted from the attic resistance shown.

^fSurfaces with effective emittance $\epsilon_{\text{eff}} = 0.05$ between ceiling joists facing attic space.

143

Typical Thermal Properties of Common Building and Insulating Materials—Design Values (Continued)						
Description	Density, lb/ft ³	Conductivity (k), Btu·in h·ft ² ·°F	Conductance (C), Btu h·ft ² ·°F	Resistance (R)		Specific Heat, Btu lb·°F
				Per Inch Thickness (1/k), °F·ft ² ·h Btu·in	For Thickness Listed (1/C), °F·ft ² ·h Btu	
Wood, hardwood finish..... 0.75 in.	—	—	1.47	—	0.68	—
INSULATING MATERIALS						
<i>Blanket and Batt</i>						
Mineral fiber, fibrous form processed from rock, slag, or glass approx. 8.25-10 in.	0.4-2.0	—	0.033	—	30	—
<i>Board and Slabs</i>						
Cellular glass.....	8.0	0.33	—	3.03	—	0.18
Glass fiber, organic bonded	4.0-9.0	0.25	—	4.00	—	0.23
Expanded perlite, organic bonded	1.0	0.36	—	2.78	—	0.30
Expanded rubber (rigid)	4.5	0.22	—	4.55	—	0.40
Expanded polystyrene, extruded (smooth skin surface) (HCFC-142b exp.).....	1.8-3.5	0.20	—	5.00	—	0.29
Expanded polystyrene, molded beads	1.0	0.26	—	3.85	—	—
	1.25	0.25	—	4.00	—	—
	1.5	0.24	—	4.17	—	—
Cellular phenolic (open cell)	1.8-2.2	0.23	—	4.40	—	—
Mineral fiber with resin binder.....	15.0	0.29	—	3.45	—	0.17
Mineral fiberboard, wet felted						
Core or roof insulation	16-17	0.34	—	2.94	—	—
Acoustical tile	18.0	0.35	—	2.86	—	0.19
Mineral fiberboard, wet molded						
Acoustical tile	23.0	0.42	—	2.38	—	0.14
Cement fiber slabs (shredded wood with Portland cement binder).....	25-27.0	0.50-0.53	—	2.0-1.89	—	—

File Edit View Window Help
 2009 ASHRAE Handbook (IP) (SI) (SI) - Adobe Acrobat Standard DC
 Home Tools Document 146 (157 of 273) 131% * * * 2 Sign In

Typical Thermal Properties of Common Building and Insulating Materials—Design Values (Continued)

Description	Density, lb/ft ³	Conductivity (<i>k</i>), Btu·in h·ft ² ·°F	Conductance (<i>C</i>), Btu h·ft ² ·°F	Resistance (<i>R</i>)		Specific Heat, Btu lb·°F
				Per Inch Thickness (1/ <i>k</i>), °F·ft ² ·h Btu·in	For Thickness Listed (1/ <i>C</i>), °F·ft ² ·h Btu	
<i>Loose Fill</i>						
Cellulosic insulation (milled paper or wood pulp).....	2.3-3.2	0.27-0.32	—	3.70-3.13	—	0.33
Perlite, expanded	2.0-4.1	0.27-0.31	—	3.7-3.3	—	0.26
	4.1-7.4	0.31-0.36	—	3.3-2.8	—	—
	7.4-11.0	0.36-0.42	—	2.8-2.4	—	—
Mineral fiber (rock, slag, or glass)						
approx. 3.75-5 in.	0.6-2.0	—	—	—	11.0	0.17
approx. 6.5-8.75 in.	0.6-2.0	—	—	—	19.0	—
Vermiculite, exfoliated	7.0-8.2	0.47	—	2.13	—	0.32
	4.0-6.0	0.44	—	2.27	—	—
ROOFING						
Built-up roofing..... 0.375 in.	70	—	3.00	—	0.33	0.35
Slate..... 0.5 in.	—	—	20.00	—	0.05	0.30
Wood shingles, plain and plastic film faced	—	—	1.06	—	0.94	0.31
PLASTERING MATERIALS						
Cement plaster, sand aggregate	116	5.0	—	0.20	—	0.20
Gypsum plaster:						
Lightweight aggregate..... 0.5 in.	45	—	3.12	—	0.32	—
Perlite aggregate	45	1.5	—	0.67	—	0.32
Sand aggregate.....	105	5.6	—	0.18	—	0.20
Sand aggregate on metal lath..... 0.75 in.	—	—	7.70	—	0.13	—
Vermiculite aggregate	45	1.7	—	0.59	—	—
MASONRY MATERIALS						
<i>Masonry Units</i>						

146

146

Typical Thermal Properties of Common Building and Insulating Materials—Design Values (Continued)						
Description	Density, lb/ft ³	Conductivity (k), Btu·in h·ft ² ·°F	Conductance (C), Btu h·ft ² ·°F	Resistance (R)		Specific Heat, Btu lb·°F
				Per Inch Thickness (1/k), °F·ft ² ·h Btu·in	For Thickness Listed (1/C), °F·ft ² ·h Btu	
Brick, fired clay	150	8.4-10.2	—	0.12-0.10	—	—
Clay tile, hollow	—	—	—	—	—	—
1 cell deep	4 in.	—	0.90	—	1.11	—
2 cells deep	8 in.	—	0.54	—	1.85	—
3 cells deep	12 in.	—	0.40	—	2.50	—
Concrete blocks	—	—	—	—	—	—
Medium weight aggregate (combinations of normal weight and lightweight aggregate)	—	—	—	—	—	—
8 in., 26-29 lb, 97-112 lb/ft ³ concrete, 2 or 3 cores..	—	—	0.58-0.78	—	1.71-1.28	—
Same with perlite filled cores	—	—	0.27-0.44	—	3.7-2.3	—
Lightweight aggregate (expanded shale, clay, slate or slag, pumice)	—	—	—	—	—	—
6 in., 16-17 lb 85-87 lb/ft ³ concrete, 2 or 3 cores..	—	—	0.52-0.61	—	1.93-1.65	—
Same with perlite filled cores	—	—	0.24	—	4.2	—
Same with vermiculite filled cores	—	—	0.33	—	3.0	—
8 in., 19-22 lb, 72-86 lb/ft ³ concrete	—	—	0.32-0.54	—	3.2-1.90	0.21
Same with perlite filled cores	—	—	0.15-0.23	—	6.8-4.4	—
Same with vermiculite filled cores	—	—	0.19-0.26	—	5.3-3.9	—
Same with molded EPS (beads) filled cores	—	—	0.21	—	4.8	—
Same with UF foam filled cores	—	—	0.22	—	4.5	—
Same with molded EPS inserts in cores	—	—	0.29	—	3.5	—
Stone, lime, or sand	180	72	—	0.01	—	—
Quartzitic and sandstone	140	24	—	0.04	—	—
Calclitic, dolomitic, limestone, marble, and granite...	180	30	—	0.03	—	—
Gypsum partition tile	140	16	—	0.06	—	—
3 by 12 by 30 in., solid	—	—	0.79	—	1.26	0.19

File Edit View Window Help

Home Tools Document

148

(159 of 273)

131%

...

2

Sign In

Typical Thermal Properties of Common Building and Insulating Materials—Design Values (Continued)

Description	Density, lb/ft ³	Conductivity (<i>k</i>), Btu-in h-ft ² ·°F	Conductance (<i>C</i>), Btu h-ft ² ·°F	Resistance (<i>R</i>)		Specific Heat, Btu lb·°F
				Per Inch Thickness (1/ <i>k</i>), °F-ft ² ·h Btu-in	For Thickness Listed (1/ <i>C</i>), °F-ft ² ·h Btu	
<i>Concretes</i>						
Sand and gravel or stone aggregate concretes (concretes with more than 50% quartz or quartzite sand have conductivities in the higher end of the range).....	150	10.0-20.0	—	0.10-0.05	—	—
Limestone concretes.....	140	9.0-18.0	—	0.11-0.06	—	0.19-0.24
	130	7.0-13.0	—	0.14-0.08	—	—
	140	11.1	—	0.09	—	—
	120	7.9	—	0.13	—	—
Gypsum-fiber concrete (87.5% gypsum, 12.5% wood chips).....	51	1.66	—	0.60	—	0.21
Cement/lime, mortar, and stucco.....	120	9.7	—	0.10	—	—
<i>Lightweight aggregate concretes</i>						
Expanded shale, clay, or slate; expanded slags; cinders; pumice (with density up to 100 lb/ft ³); and scoria (sanded concretes have conductivities in the higher end of the range)....	120	6.4-9.1	—	0.16-0.11	—	—
	60	2.1-2.5	—	0.48-0.40	—	—
Perlite, vermiculite, and polystyrene beads.....	50	1.8-1.9	—	0.55-0.53	—	—
	30	1.1	—	0.91	—	—
Foam concretes.....	120	5.4	—	0.19	—	—
SIDING MATERIALS (on flat surface)						
<i>Shingles</i>						
Wood, 16 in., 7.5 exposure.....	—	—	1.15	—	0.87	0.31
Wood, double, 16-in., 12-in. exposure.....	—	—	0.84	—	1.19	0.28
<i>Siding</i>						
Asphalt roll siding.....	—	—	6.50	—	0.15	0.35
Asphalt insulating siding (0.5 in. bed.).....	—	—	0.69	—	1.46	0.35
Hardboard siding, 0.4375 in.	—	—	1.49	—	0.67	0.28
Wood, drop, 1 by 8 in.	—	—	1.27	—	0.79	0.28
Wood, bevel, 0.5 by 8 in., lapped.....	—	—	1.23	—	0.81	0.28

148

Typical Thermal Properties of Common Building and Insulating Materials—Design Values (Continued)						
Description	Density, lb/ft ³	Conductivity (k), Btu·in h·ft ² ·°F	Conductance (C), Btu h·ft ² ·°F	Resistance (R)		Specific Heat, Btu lb·°F
				Per Inch Thickness (1/k), °F·ft ² ·h Btu·in	For Thickness Listed (1/C), °F·ft ² ·h Btu	
Wood, plywood, 0.375 in., lapped.....	—	—	1.69	—	0.59	0.29
Aluminum, steel, or vinyl, over sheathing	—	—	1.64	—	0.61	0.29 ^d
Hollow-backed	—	—	0.55	—	1.82	0.32
Insulating-board backed nominal 0.375 in.	—	—	—	—	—	—
Insulating-board backed nominal 0.375 in., foil backed	—	—	0.34	—	2.96	—
Architectural (soda-lime float) glass	158	6.9	—	—	—	0.21
WOODS (12% moisture content)^{d,e}						
<i>Hardwoods</i>						0.39 ^s
Oak	41.2-46.8	1.12-1.25	—	0.89-0.80	—	—
Birch	42.6-45.4	1.16-1.22	—	0.87-0.82	—	—
Maple	39.8-44.0	1.09-1.19	—	0.92-0.84	—	—
Ash	38.4-41.9	1.06-1.14	—	0.94-0.88	—	—
<i>Softwoods</i>						0.39 ^s
Southern Pine	35.6-41.2	1.00-1.12	—	1.00-0.89	—	—
Douglas Fir-Larch	33.5-36.3	0.95-1.01	—	1.06-0.99	—	—
Southern Cypress	31.4-32.1	0.90-0.92	—	1.11-1.09	—	—
Hem-Fir, Spruce-Pine-Fir	24.5-31.4	0.74-0.90	—	1.35-1.11	—	—
West Coast Woods, Cedars	21.7-31.4	0.68-0.90	—	1.48-1.11	—	—
California Redwood	24.5-28.0	0.74-0.82	—	1.35-1.22	—	—

2009 ASHRAE Pocket Guide (I-P) (SECURED) - Adobe Acrobat Standard DC

File Edit View Window Help

Home Tools Document 150 (161 of 273) 131% Sign In

Cooling Load Temperature Differences for Flat Roofs--24°N Latitude, July

Roof No.	Solar time, h													
	2	4	6	8	10	12	14	16	18	20	22	24		
1	-2	-5	-6	9	44	76	92	86	58	23	8	2		
2	0	-4	-6	1	30	64	86	89	70	36	14	5		
3	8	2	-2	3	22	47	68	77	68	47	29	16		
4	11	3	-2	-4	5	27	55	75	80	67	43	23		
5	16	8	3	1	10	30	52	68	70	59	41	27		
8	24	17	11	9	14	27	43	54	58	52	42	32		
9	25	16	9	4	5	17	36	54	65	63	51	37		
10	31	22	15	9	8	16	30	45	56	59	52	41		
13	31	25	20	16	16	23	33	43	49	49	43	37		
14	32	27	23	19	19	24	32	40	45	45	42	37		

Cooling Load Temperature Differences for Flat Roofs--36°N Latitude, July

Roof No.	Solar time, h													
	2	4	6	8	10	12	14	16	18	20	22	24		
1	-2	-5	-6	12	45	75	90	84	60	26	9	2		
2	0	-4	-6	4	32	63	84	87	70	39	15	5		
3	8	2	-2	4	24	47	67	75	68	48	30	17		
4	11	3	-1	-3	7	29	55	74	79	67	45	24		
5	16	8	3	2	12	31	52	67	70	59	42	27		
8	25	17	12	9	15	28	42	54	58	53	43	33		
9	26	16	9	4	7	19	37	54	64	63	52	38		
10	32	23	15	10	9	17	30	45	56	58	52	42		
13	31	25	20	16	17	24	33	43	49	49	44	37		
14	32	28	23	20	20	25	32	40	45	46	42	37		

Cooling Load Temperature Differences for Flat Roofs--48°N Latitude, July

Roof No.	Solar time, h													
	2	4	6	8	10	12	14	16	18	20	22	24		
1	-2	-5	-5	15	44	69	83	79	59	29	9	2		
2	0	-4	-5	6	32	60	78	81	68	41	16	5		
3	8	2	-1	6	24	45	63	71	65	48	30	17		
4	12	3	-1	-2	8	29	52	69	74	65	45	25		
5	16	8	3	3	13	31	49	63	66	58	42	27		
8	24	17	11	10	16	27	40	51	55	51	42	32		
9	26	16	9	5	8	19	35	51	60	61	51	38		
10	31	22	15	10	10	17	29	43	53	56	51	41		
13	30	25	20	16	18	24	32	41	47	47	43	37		
14	32	27	23	20	20	24	31	38	43	44	41	36		

CAUTION: Approximate data--Use for preliminary computations only.
Also, see notes on next page.

150

2009 ASHRAE Pocket Guide (I-P) (SECURED) - Adobe Acrobat Standard DC

File Edit View Window Help

Home Tools Document 151 (162 of 273) 131% Sign In

Notes for CLTD Data for Flat Roofs

1. Data applies directly to: (1) dark surface, (2) indoor temperature is 78°F, (3) outdoor maximum temperature of 95°F with mean temperature of 85°F and daily range of 21°F, (4) solar radiation typical of clear day on 21st day of month, (5) outside surface film resistance of 0.333 (h ft²°F/Btu), and (6) inside surface resistance of 0.685 (h ft²°F/Btu).

2. Adjustments to design temperatures

$$\text{Corr. CLTD} = \text{CLTD} + (78 - t_p) + (t_m - 85)$$
 where t_p = inside temperature and t_m = mean outdoor temperature, or t_m = maximum outdoor temperature - (daily range)/2
 No adjustment recommended for color or for ventilation of air space above a ceiling.
 For design purposes, the data suffices for plus or minus 2 weeks from the 21st day of given month.

Roof Classifications for Use with CLTD Tables for Flat Roofs

Mass Location	Suspended Ceiling	R-Factor, h ft ² °F/Btu	Wood 1 in.	2 in. (heavyweight) Concrete	Steel Deck	Attic Ceiling Comb.
Mass inside insul.	Without	0 to 10	*	2	*	*
		10 to 20	*	4	*	*
		20 to 25	*	5	*	*
	With	0 to 5	*	5	*	*
		5 to 10	*	8	*	*
		10 to 20	*	13	*	*
		20 to 25	*	14	*	*
Mass evenly placed	Without	0 to 5	1	2	1	1
		5 to 15	2	*	1	2
		15 to 25	4	*	2	2
	With	0 to 5	*	3	1	*
		5 to 10	4	*	1	*
		10 to 15	5	*	2	*
		15 to 20	9	*	2	*
		20 to 25	10	*	4	*
Mass outside insul.	Without	0 to 5	*	2	*	*
		5 to 10	*	3	*	*
		10 to 15	*	4	*	*
	With	15 to 25	*	5	*	*
		0 to 10	*	3	*	*
		10 to 15	*	4	*	*
		15 to 20	*	5	*	*

* Denotes roof that is not possible with the chosen parameters

151

Approximate Cooling Load Temperature Differences (CLTDs) for Sunlit Walls—24°N Latitude, July																								
Wall Facing	Solar time, h								Solar time, h								Solar time, h							
	6	8	10	12	14	16	18	20	6	8	10	12	14	16	18	20	6	8	10	12	14	16	18	20
Low Mass, Low R-Factor Wall																								
N	-2	13	18	22	28	32	34	17	1	0	6	13	18	23	28	30	-2	2	12	18	23	28	32	29
NE	0	39	53	39	30	30	24	13	0	3	20	36	39	35	32	27	-2	9	36	46	38	32	29	22
E	0	44	63	48	32	30	24	13	1	3	22	43	46	40	34	28	-2	10	42	55	44	35	30	23
SE	-2	25	44	42	32	30	24	13	0	1	13	28	35	35	32	27	-2	4	26	40	38	33	29	22
S	-3	3	12	24	31	30	23	13	0	-1	1	7	16	24	27	25	-2	-1	4	13	24	29	28	22
SW	-3	3	13	22	40	58	52	20	1	-1	1	7	15	29	43	47	-2	-1	5	13	24	42	54	44
W	-3	3	13	22	42	73	75	27	2	0	2	7	15	30	52	61	-1	-1	5	13	23	46	69	61
NW	-3	3	13	22	37	62	67	25	1	0	2	7	15	27	45	54	-1	-1	5	13	22	40	60	55
High Mass, Low R-Value Wall																								
N	3	3	7	12	16	21	25	27	10	8	8	10	12	15	18	21	12	9	8	8	10	13	16	19
NE	3	6	20	31	33	32	31	27	11	9	14	21	25	26	27	26	13	10	10	15	21	24	27	27
E	4	6	22	36	39	36	33	29	12	10	15	24	29	30	30	29	14	11	11	17	24	28	30	31
SE	3	4	14	25	30	30	30	26	10	8	11	17	21	24	25	25	13	10	9	12	17	21	24	25
S	3	1	3	7	14	20	23	22	8	6	5	6	10	14	17	18	10	8	6	5	7	10	14	17
SW	5	3	4	8	14	26	38	40	13	10	9	9	11	17	24	30	17	13	10	8	9	12	18	25
W	7	4	4	8	15	28	45	51	17	13	11	11	13	18	28	36	21	16	12	10	11	13	20	30
NW	6	3	4	8	14	25	40	46	15	12	10	10	12	17	25	32	19	14	11	9	10	12	18	26

CAUTION: Approximate data—Use for preliminary computations only.

152

Wall Facing	Solar time, h								Solar time, h								Solar time, h							
	6	8	10	12	14	16	18	20	6	8	10	12	14	16	18	20	6	8	10	12	14	16	18	20
	Low Mass, Low R-Factor Wall								Low Mass, Medium R-Factor Wall								Low Mass, High R-Factor Wall							
N	-1	12	14	21	28	29	30	17	0	0	5	10	16	22	26	27	-2	3	9	15	21	27	28	27
NE	1	41	46	30	29	29	24	14	0	4	21	33	33	31	30	27	-2	12	36	39	32	30	28	23
E	1	49	64	48	31	30	24	14	1	4	26	45	47	40	34	29	-2	14	46	56	45	34	30	23
SE	-1	31	52	52	36	30	24	14	1	2	16	34	44	41	35	29	-2	7	31	48	47	37	31	23
S	-3	4	18	39	47	40	25	14	0	-1	2	11	25	36	38	32	-2	-1	6	21	37	44	37	25
SW	-2	4	13	23	50	67	59	23	1	0	2	8	17	34	51	54	-1	-1	5	13	28	50	62	51
W	-2	4	13	21	42	73	78	31	2	0	2	8	15	30	52	63	-1	-1	5	13	23	46	69	65
NW	-2	4	13	21	29	53	65	28	1	0	2	8	15	24	39	51	-2	-1	5	13	21	33	53	55
	High Mass, Low R-Factor Wall								High Mass, Medium R-Factor Wall								High Mass, High R-Factor Wall							
N	3	3	6	10	15	20	23	25	9	7	8	9	11	14	17	19	11	9	7	7	9	11	14	17
NE	3	7	20	28	29	29	29	26	10	9	14	20	23	24	25	25	13	10	10	15	19	22	24	25
E	4	8	25	38	40	37	34	29	12	11	17	25	30	31	31	30	15	11	12	18	25	30	31	31
SE	4	5	17	30	37	36	33	29	12	10	13	20	26	29	29	28	14	11	10	14	20	26	29	30
S	3	2	4	11	22	31	33	29	10	8	7	9	14	20	24	25	13	10	7	7	10	15	21	24
SW	6	3	4	8	16	31	44	46	15	12	10	10	13	19	28	34	19	15	11	10	10	14	21	29
W	7	4	5	9	15	28	46	54	17	14	12	11	13	18	28	37	22	17	13	11	11	14	20	30
NW	6	3	4	8	14	22	35	43	14	11	10	10	12	15	22	30	18	14	11	9	10	12	17	24

CAUTION: Approximate data—Use for preliminary computations only.

CAUTION: Approximate data--Use for preliminary computations only.

Wall Facing	Solar time, h								Solar time, h								Solar time, h									
	6	8	10	12	14	16	18	20	6	8	10	12	14	16	18	20	6	8	10	12	14	16	18	20		
Low Mass, Low R-Factor Wall									Low Mass, Medium R-Factor Wall									Low Mass, High R-Factor Wall								
N	3	10	13	21	27	28	27	21	1	2	6	10	16	21	25	26	-1	5	9	14	21	26	27	27		
NE	10	42	38	26	28	29	24	15	1	7	23	31	30	29	28	26	0	18	36	34	28	28	28	23		
E	10	54	64	47	31	29	25	15	1	8	30	47	48	40	34	29	0	20	49	57	44	34	29	23		
SE	4	36	59	61	45	31	25	15	1	4	20	40	51	49	40	32	-1	11	36	55	56	43	33	24		
S	-2	5	28	52	62	51	29	15	1	0	3	16	34	48	50	40	-1	0	9	30	50	57	47	30		
SW	-1	5	12	29	59	75	65	29	2	0	3	8	20	40	58	61	-1	0	6	14	33	58	69	57		
W	-1	5	13	21	41	72	80	41	2	0	3	8	15	29	51	64	-1	0	6	13	22	45	69	69		
NW	-2	5	12	21	27	45	62	37	2	0	2	8	14	22	34	47	-1	0	5	13	20	29	46	54		
High Mass, Low R-Factor Wall									High Mass, Medium R-Factor Wall									High Mass, High R-Factor Wall								
N	3	4	6	10	14	19	22	24	9	8	8	9	11	14	17	19	12	9	8	8	9	11	14	17		
NE	4	10	22	26	26	27	27	25	10	10	15	20	22	23	24	24	13	10	12	16	19	22	23	24		
E	4	11	28	40	40	37	34	29	12	12	19	27	32	32	32	30	15	12	14	20	27	31	32	32		
SE	4	7	20	35	43	42	38	32	13	12	15	23	30	34	34	32	16	12	12	17	24	30	34	34		
S	5	3	6	16	31	41	43	37	13	10	9	12	19	27	32	33	16	12	10	10	14	21	28	32		
SW	7	4	5	9	19	36	50	52	18	14	12	12	15	23	32	39	22	17	13	11	12	16	24	33		
W	8	5	6	9	15	27	45	55	19	15	12	12	14	19	28	38	23	18	14	12	12	14	20	30		
NW	6	4	5	8	14	20	31	41	14	11	10	10	12	15	20	28	18	14	11	9	10	12	16	22		

Note 1. Apply data directly to (1) dark surface, (2) indoor temperature of 78°F, (3) outdoor maximum temperature of 95°F with mean temperature of 85°F and daily range of 21°F, (4) outside surface film resistance of 0.333 (h·ft²·°F)/Btu, and (5) inside surface resistance of 0.685 (h·ft²·°F)/Btu.
Note 2. Adjustments to design temperatures:

Note 2. Adjustments to design temperatures:

$$\text{Corr. CLTD} = \text{CLTD} + (78 - t_c) + (t_m - 85)$$

where t_r = inside temperature and t_m = mean outdoor temperature, or t_m = maximum outdoor temperature - (daily range)/2

Note 3. Adjustments to months other than July: For design purposes, the data suffices for plus or minus 2 weeks from the 21st day of given month

Tables do not consider zone type and are conservative. Use for preliminary computations only.

Glass	Solar time,
-------	-------------

Facing	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22
N	0	19	35	36	36	38	40	42	42	40	38	39	43	32	11	6	3	1
NE	0	54	124	150	144	115	78	58	49	44	38	32	25	14	6	3	1	1
E	0	57	139	177	180	154	107	68	54	46	40	33	25	14	6	3	1	1
SE	0	26	74	104	114	106	83	59	50	44	38	32	25	14	6	3	1	1
S	0	5	15	23	30	35	40	43	43	40	37	32	24	14	6	3	1	1
SW	0	5	15	23	30	35	39	42	61	88	110	118	105	62	24	12	6	3
W	0	5	15	23	30	35	39	41	67	116	160	186	184	118	44	21	11	5
NW	0	5	15	23	30	35	39	41	51	83	122	151	158	106	39	19	9	5
Hor	0	10	55	113	170	218	253	271	273	258	225	176	115	54	24	12	6	3

N	0	25	29	28	32	36	39	40	41	39
---	---	----	----	----	----	----	----	----	----	----

NE	0	79	129	139	120	84	58	50	45	41	37	32	26	17	7	3	2	1
E	0	86	153	184	182	155	107	67	54	45	39	33	26	17	7	3	2	1
SE	0	42	90	125	142	140	119	86	58	48	40	34	27	17	7	3	2	1
S	0	8	17	24	36	53	70	80	79	68	52	38	29	18	7	3	2	1
SW	0	8	17	24	30	35	38	57	90	122	141	144	127	85	32	15	8	4
W	0	8	17	24	30	35	38	40	66	115	159	188	191	149	53	25	12	6
NW	0	8	17	24	30	35	38	40	40	56	93	129	148	127	43	21	10	5
Hor	0	20	66	120	171	215	246	263	265	251	221	178	124	66	28	13	7	3

48°N Latitude, July

Glass Facing	Solar time, h																		
	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	
N	14	28	24	27	31	34	37	38	38	37	35	31	27	34	25	9	4	2	
NE	32	101	130	126	95	61	49	44	41	38	35	31	26	19	10	4	2	1	
E	31	112	165	188	182	153	104	65	51	43	38	32	27	19	10	4	2	1	
SE	11	58	106	143	164	168	152	119	77	54	43	35	28	20	10	4	2	1	
S	3	11	18	30	58	90	116	130	130	116	88	56	37	24	12	5	3	1	
SW	3	11	18	24	30	34	46	82	122	152	168	166	146	106	50	22	11	5	
W	3	11	18	24	30	34	36	38	64	112	156	186	193	167	89	36	17	9	
NW	3	11	18	24	30	34	36	38	38	40	67	106	134	134	76	30	14	7	
Hor	5	32	73	120	163	200	226	241	242	230	205	170	125	76	35	16	8	4	

Tables do not consider zone type and are conservation. Data apply directly to: (1) standard double strength glass with no inside shade, and (2) clear sky, 21st day of month.

Adjustments to table data

- Adjustments to turbine data
 - Latitudes other than 24, 36 and 48°N
 - Linear interpolation is acceptable.
 - Months other than July
 - For design purposes, data will suffice for plus or minus 2 weeks from the 21st day of given month.
 - Other types of glass and internal shade
 - Use shading coefficients as multiplier.
 - Externally shaded glass
 - Use north orientation

2009 ASHRAE Pocket Guide (I-P) (SECURED) - Adobe Acrobat Standard DC

File Edit View Window Help

Home Tools Document 157 (168 of 273) 131% Sign In

Shading Coefficients* for Single Glass with Indoor Shading by Venetian Blinds or Roller Shades

Type of Glass	Nominal Thickness, ^a in.	Solar Transmittance ^b	Type of Shading				
			Roller Shade				
			Venetian Blinds		Opaque Translucent		
			Medium	Light	Dark	White	Light
Clear	3/32 ^c	0.87 to 0.80	0.74 ^d (0.63) ^e	0.67 ^d (0.58) ^e	0.81	0.39	0.44
Clear	1/4 to 1/2	0.80 to 0.71					
Clear pattern	1/8 to 1/2	0.87 to 0.79					
Heat-absorbing pattern	1/8	—					
Tinted	3/16, 7/32	0.74, 0.71					
Heat-absorbing ^f	3/16, 1/4	0.46					
Heat-absorbing pattern	3/16, 1/4	—	0.57	0.53	0.45	0.30	0.36
Tinted	1/8, 7/32	0.59, 0.45					
Heat-absorbing or pattern	—	0.44 to 0.30	0.54	0.52	0.40	0.28	0.32
Heat-absorbing ^f	3/8	0.34					
Heat-absorbing or pattern	—	0.29 to 0.15					
Reflective coated glass	S.C. = 0.30 ^g = 0.40 = 0.50 = 0.60		0.25 0.33 0.42 0.50	0.23 0.29 0.38 0.44			

*Refer to manufacturers' literature for values.
^bFor vertical blinds with opaque white and beige louvers in the tightly closed position, SC is 0.25 and 0.29 when used with glass of 0.71 to 0.80 transmittance.
^cTypical residential glass thickness.
^dFrom Van Dyck and Konec (1982), for 45° open venetian blinds, 35° solar incidence, and 35° profile angle.
^eValues for closed venetian blinds. Use these values only when operation is automated for solar gain reduction (as opposed to daylight use).
^fRefers to gray, bronze, and green tinted heat-absorbing glass.
^gSC for glass with no shading device.

*Note: Shading Coefficient (SC) has been superseded by solar heat gain coefficient (SHGC) including the effect of incident angle of solar radiation on the glass, and the effect of type of framing. This shading coefficient table is sufficiently accurate for the approximate cooling load calculations of this publication. For the glazing portion of single-pane clear and tinted fenestration,

$$SC = \frac{SHGC}{0.87}$$

This does not include frame effects.

157

2009 ASHRAE Pocket Guide (I-P) (SECURED) - Adobe Acrobat Standard DC

File Edit View Window Help



Home Tools Document 158 (169 of 273) 131% Sign In

Rates of Heat Gain from Occupants of Conditioned Spaces

Degree of Activity		Total Heat, Btu/h		Sensible Heat, Btu/h	Latent Heat, Btu/h	% Sensible Heat that is Radiant ^b	
		Adult Male	Adjusted, M/F ^a			Low V ^c	High V ^c
Seated at theater	Theater, matinee	390	330	225	165		
Seated at theater, night	Theater, night	390	350	245	145	60	27
Seated, very light work	Offices, hotels, apartments	450	400	245	155		
Moderately active office work	Offices, hotels, apartments	475	450	250	200		
Standing, light work; walking	Department store, retail store	550	450	250	200	58	38
Walking, standing	Drug store, bank	550	500	250	250		
Sedentary work	Restaurant ^d	490	550	275	275		
Light bench work	Factory	800	750	275	475		
Moderate dancing	Dance hall	900	850	305	545	49	35
Walking 3 mph; light machine work	Factory	1000	1000	375	625		
Bowling ^e	Bowling alley	1500	1450	580	870		
Heavy work	Factory	1500	1450	580	870	54	19
Heavy machine work; lifting	Factory	1600	1600	635	965		
Athletics	Gymnasium	2000	1800	710	1090		

Notes:
1. Tabulated values are based on 75°F room dry-bulb temperature. For 80°F room dry bulb, the total heat remains the same, but the sensible heat values should be decreased by approximately 20%, and the latent heat values increased accordingly.
2. Also refer to Table 4, Chapter 8, for additional rates of metabolic heat generation.
3. All values are rounded to nearest 5 Btu/h.
^aAdjusted heat gain is based on normal percentage of men, women, and children for the application listed, with the postulate that the gain from an adult female is 85% of that for an adult male, and that the gain from a child is 75% of that for an adult male.
^bValues approximated from data in Table 6, Chapter 8, where air velocity with limits shown in that table.
^cAdjusted heat gain includes 60 Btu/h for food per individual (30 Btu/h sensible and 30 Btu/h latent).
^dFigure one person per alley actually bowling, and all others as sitting (400 Btu/h) or standing or walking slowly (550 Btu/h).

158



2009 ASHRAE Pocket Guide (I-P) (SECURED) - Adobe Acrobat Standard DC

File Edit View Window Help

Home Tools Document 161 (172 of 273) 131% Sign In

Lighting Heat Gain Parameters for Typical Operating Conditions

Luminaire Category	Space Fraction	Radiative Fraction	Notes
Recessed fluorescent luminaire without lens	0.64 to 0.74	0.48 to 0.68	<ul style="list-style-type: none"> Use middle values in most situations May use higher space fraction, and lower radiative fraction for luminaire with side-slot returns May use lower values of both fractions for direct/indirect luminaire May use higher values of both fractions for ducted returns
Recessed fluorescent luminaire with lens	0.40 to 0.50	0.61 to 0.73	<ul style="list-style-type: none"> May adjust values in the same way as for recessed fluorescent luminaire without lens
Downlight compact fluorescent luminaire	0.12 to 0.24	0.95 to 1.0	<ul style="list-style-type: none"> Use middle or high values if detailed features are unknown Use low value for space fraction and high value for radiative fraction if there are large holes in luminaire's reflector
Downlight incandescent luminaire	0.70 to 0.80	0.95 to 1.0	<ul style="list-style-type: none"> Use middle values if lamp type is unknown Use low value for space fraction if standard lamp (i.e. A-lamp) is used Use high value for space fraction if reflector lamp (i.e. BR-lamp) is used
Non-in-ceiling fluorescent luminaire	1.0	0.5 to 0.57	<ul style="list-style-type: none"> Use lower value for radiative fraction for surface-mounted luminaire Use higher value for radiative fraction for pendant luminaire

Source: Fisher and Chaurasrisalai (2006).

The table above provides a range of design data under typical operating conditions: airflow 1 cfm/ft², supply air between 59°F and 62°F, room temperature between 72°F and 75°F, and lighting heat input in a range from 0.9 to 2.6 W/ft². For a fluorescent luminaire without lens, the figure below gives more precise data. The data should be used with judgement.

Lighting Heat Gain Parameters for Recessed Fluorescent Luminaire Without Lens

161

2009 ASHRAE Pocket Guide (I-P) (SECURED) - Adobe Acrobat Standard DC

File Edit View Window Help

Home Tools Document 162 (173 of 273) 131% Sign In

Heat Gain from Motors and their Loads

Instantaneous rate of heat gain from equipment operated by electric motors within a conditioned space.

$$q_{em} = 2545 (P/E_m) F_{lm} F_{LM}$$

where

- q_{em} = heat equivalent of equipment operation
- P = motor power rating, hp
- E_m = motor efficiency, decimal fraction < 1.0
- F_{lm} = motor use factor 1.0 or < 1.0 (proportion operating)
- F_{LM} = motor load factor 1.0 or < 1.0

When motor is outside the conditioned space, but load is inside,

$$q_{em} = 2545 P F_{lm} F_{LM}$$

When motor is inside the conditioned space, but load is outside,

$$q_{em} = 2545 P \left(\frac{1.0 - E_m}{E_m} \right) F_{lm} F_{em}$$

Minimum Nominal Efficiency for General Purpose Design A and Design B Motors

Number of Poles ⇒	Minimum Nominal Full-Load Efficiency, %					
	Open Motors			Enclosed Motors		
	2	4	6	2	4	6
Synchronous Speed (RPM) ⇒	3600	1800	1200	3600	1800	1200
Motor Horsepower						
1	—	82.5	80.0	75.5	82.5	80.0
1.5	82.5	84.0	84.0	82.5	84.0	85.5
2	84.0	84.0	85.5	84.0	84.0	86.5
3	84.0	86.5	86.5	85.5	87.5	87.5
5	85.5	87.5	87.5	87.5	87.5	87.5
7.5	87.5	88.5	88.5	88.5	89.5	89.5
10	88.5	89.5	90.2	89.5	89.5	89.5
15	89.5	91.0	90.2	90.2	91.0	90.2
20	90.2	91.0	91.0	90.2	91.0	90.2
25	91.0	91.7	91.7	91.0	92.4	91.7
30	91.0	92.4	92.4	91.0	92.4	91.7
40	91.7	93.0	93.0	91.7	93.0	93.0
50	92.4	93.0	93.0	92.4	93.0	93.0
60	93.0	93.6	93.6	93.0	93.6	93.6
75	93.0	94.1	93.6	93.0	94.1	93.6
100	93.0	94.1	94.1	93.6	94.5	94.1
125	93.6	94.5	94.1	94.5	94.5	94.1
150	93.6	95.0	94.5	94.5	95.0	95.0
200	94.5	95.0	94.5	95.0	95.0	95.0

Heat output of a motor is generally proportional to motor load, within rated overload limits. Because of typically high no-load motor current, fixed losses, and other reasons, F_{LM} is generally assumed to be unity, and no adjustment should be made for underloading or overloading unless the situation is fixed and can be accurately established, and reduced-load efficiency data can be obtained from the motor manufacturer. Unless the manufacturer's technical literature indicates otherwise, motor heat gain normally should be equally divided between radiant and convective components for the subsequent cooling load calculations.

162

Cooking Appliances

Heat gain: $q_s = q_{DPA} F_U F_R$, where F_U is the usage factor and F_R is the radiation factor.

Recommended Rates of Radiant and Convective Heat Gain from Unhooded Electric Appliances During Idle (Ready-to-Cook) Conditions

Appliance	Energy Rate, Btu/h		Rate of Heat Gain, Btu/h				Usage Factor F_U	Radiation Factor F_R
	Rated	Standby	Sensible Radiant	Sensible Convective	Latent	Total		
Cabinet: hot serving (large), insulated*	6,800	1,200	400	800	0	1,200	0.18	0.33
Cabinet: hot serving (large), uninsulated	6,800	3,500	700	2,800	0	3,500	0.51	0.2
Cabinet: proofing (large)*	17,400	1,400	1,200	0	200	1,400	0.08	0.86
Cabinet: proofing (small-15 shelf)	14,300	3,900	0	900	3,000	3,900	0.27	0
Coffee brewing urn	13,000	1,200	200	300	700	1,200	0.09	0.17
Drawer warmers, 2-drawer (moist holding)*	4,100	500	0	0	200	200	0.12	0
Egg cooker	10,900	700	300	400	0	700	0.06	0.43
Espresso machine*	8,200	1,200	400	800	0	1,200	0.15	0.33
Food warmer: steam table (2-well-type)	5,100	3,500	300	600	2,600	3,500	0.69	0.09
Freezer (small)	2,700	1,100	500	600	0	1,100	0.41	0.45
Hot dog roller*	3,400	2,400	900	1,500	0	2,400	0.71	0.38
Hot plate: single burner, high speed	3,800	3,000	900	2,100	0	3,000	0.79	0.3
Hot-food case (dry holding)*	31,100	2,500	900	1,600	0	2,500	0.08	0.36
Hot-food case (moist holding)*	31,100	3,300	900	1,800	600	3,300	0.11	0.27
Microwave oven: commercial (heavy duty)	10,900	0	0	0	0	0	0	0
Oven: countertop conveyORIZED bake/finishing*	20,500	12,600	2,200	10,400	0	12,600	0.61	0.17
Panini*	5,800	3,200	1,200	2,000	0	3,200	0.55	0.38
Popcorn popper*	2,000	200	100	100	0	200	0.1	0.5
Rapid-cook oven (quartz-halogen)*	41,000	0	0	0	0	0	0	0
Rapid-cook oven (microwave/convection)*	24,900	4,100	1,000	3,100	0	4,100	0.16	0.24
Reach-in refrigerator*	4,800	1,200	300	900	0	1,200	0.25	0.25
Refrigerated prep table*	2,000	900	600	300	0	900	0.45	0.67
Steamer (bun)	5,100	700	600	100	0	700	0.14	0.86
Toaster: 4-slice pop up (large): cooking	6,100	3,000	200	1,400	1,000	2,600	0.49	0.07
Toaster: contact (vertical)	11,300	5,300	2,700	2,600	0	5,300	0.47	0.51
Toaster: conveyor (large)	32,800	10,300	3,000	7,300	0	10,300	0.31	0.29
Toaster: small conveyor	5,800	3,700	400	3,300	0	3,700	0.64	0.11
Waffle iron	3,100	1,200	800	400	0	1,200	0.39	0.67

Recommended Rates of Radiant Heat Gain from Hooded Electric Appliances During Idle (Ready-to-Cook) Conditions					
Appliance	Energy Rate, Btu/h		Rate of Heat Gain, Btu/h		
	Rated	Standby	Sensible Radiant	Usage Factor F_u	Radiation Factor F_r
Broiler: underfired 3 ft	36,900	30,900	10,800	0.84	0.35
Cheesemelter*	12,300	11,900	4,600	0.97	0.39
Fryer: kettle	99,000	1,800	500	0.02	0.28
Fryer: open deep-fat, 1-vat	47,800	2,800	1,000	0.06	0.36
Fryer: pressure	46,100	2,700	500	0.06	0.19
Griddle: double sided 3 ft (clamshell down)*	72,400	6,900	1,400	0.1	0.2
Griddle: double sided 3 ft (clamshell up)*	72,400	11,500	3,600	0.16	0.31
Griddle: flat 3 ft	58,400	11,500	4,500	0.2	0.39
Griddle-small 3 ft*	30,700	6,100	2,700	0.2	0.44
Induction cooktop*	71,700	0	0	0	0
Induction wok*	11,900	0	0	0	0
Oven: combi: combi-mode*	56,000	5,500	800	0.1	0.15
Oven: combi: convection mode	56,000	5,500	1,400	0.1	0.25
Oven: convection full-size	41,300	6,700	1,500	0.16	0.22
Oven: convection half-size*	18,800	3,700	500	0.2	0.14
Pasta cooker*	75,100	8,500	0	0.11	0
Range top: top off/oven on*	16,600	4,000	1,000	0.24	0.25
Range top: 3 elements on/oven off	51,200	15,400	6,300	0.3	0.41
Range top: 6 elements on/oven off	51,200	33,200	13,900	0.65	0.42
Range top: 6 elements on/oven on	67,800	36,400	14,500	0.54	0.4
Range: hot-top	54,000	51,300	11,800	0.95	0.23
Roisserie*	37,900	13,800	4,500	0.36	0.33
Salamander*	23,900	23,300	7,000	0.97	0.3
Steam kettle: large (60 gal) simmer lid down*	110,600	2,600	100	0.02	0.04
Steam kettle: small (40 gal) simmer lid down*	73,700	1,800	300	0.02	0.17
Steamer: compartment: atmospheric*	33,400	15,300	200	0.46	0.01
Tilting skillet/braising pan	32,900	5,300	0	0.16	0



164

Recommended Rates of Radiant Heat Gain from Hooded Gas Appliances During Idle (Ready-to-Cook) Conditions					
Appliance	Energy Rate, Btu/h		Rate of Heat Gain, Btu/h		
	Rated	Standby	Sensible Radiant	Usage Factor F_u	Radiation Factor F_r
Broiler: batch*	95,000	69,200	8,100	0.73	0.12
Broiler: chain (conveyor)	132,000	96,700	13,200	0.73	0.14
Broiler: overfired (upright)*	100,000	87,900	2,500	0.88	0.03
Broiler: underfired 3 ft	96,000	73,900	9,000	0.77	0.12
Fryer: doughnut	44,000	12,400	2,900	0.28	0.23
Fryer: open deep-fat, 1 vat	80,000	4,700	1,100	0.06	0.23
Fryer: pressure	80,000	9,000	800	0.11	0.09
Griddle: double sided 3 ft (clamshell down)*	108,200	8,000	1,800	0.07	0.23
Griddle: double sided 3 ft (clamshell up)*	108,200	14,700	4,900	0.14	0.33
Griddle: flat 3 ft	90,000	20,400	3,700	0.23	0.18
Oven: combi: combi-mode*	75,700	6,000	400	0.08	0.07
Oven: combi: convection mode	75,700	5,800	1,000	0.08	0.17
Oven: convection full-size	44,000	11,900	1,000	0.27	0.08
Oven: conveyor (pizza)	170,000	68,300	7,800	0.4	0.11
Oven: deck	105,000	20,500	3,500	0.2	0.17
Oven: rack mini-rotating*	56,300	4,500	1,100	0.08	0.24
Pasta cooker*	80,000	23,700	0	0.3	0
Range top: top off/oven on*	25,000	7,400	2,000	0.3	0.27
Range top: 3 burners on/oven off	120,000	60,100	7,100	0.5	0.12
Range top: 6 burners on/oven off	120,000	120,800	11,500	1.01	0.1
Range top: 6 burners on/oven on	145,000	122,900	13,600	0.85	0.11
Range: wok*	99,000	87,400	5,200	0.88	0.06
Rethemakizer*	90,000	23,300	11,500	0.26	0.49
Rice cooker*	35,000	500	300	0.01	0.6
Salamander*	35,000	33,300	5,300	0.95	0.16
Steam kettle: large (60 gal) simmer lid down*	145,000	5,400	0	0.04	0
Steam kettle: small (10 gal) simmer lid down*	52,000	3,300	300	0.06	0.09
Steam kettle: small (40 gal) simmer lid down	100,000	4,300	0	0.04	0
Steamer: compartment: atmospheric *	26,000	8,300	0	0.32	0
Tilting skillet/braising pan	104,000	10,400	400	0.1	0.04

Amended Rates of Radiant and Convective Heat Gain from Warewashing Equipment During Idle (Standby) or Washing Conditions

Appliance	Rate of Heat Gain, Btu/h								
	Energy Rate, Btu/h		Unhooded				Hooded		
	Rated	Standby/ Washing	Sensible Radiant	Sensible Convective	Latent	Total	Sensible Radiant	Usage Factor F_u	Radiation Factor F_r
Dishwasher (conveyor type, chemical sanitizing)	46,800	5700/43,600	0	4450	13490	17940	0	0.36	0
Dishwasher (conveyor type, hot-water sanitizing) standby	46,800	5700/N/A	0	4750	16970	21720	0	N/A	0
Dishwasher (door-type, chemical sanitizing) washing	18,400	1200/13,300	0	1980	2790	4770	0	0.26	0
Dishwasher (door-type, hot-water sanitizing) washing	18,400	1200/13,300	0	1980	2790	4770	0	0.26	0
Dishwasher* (under-counter type, chemical sanitizing) standby	26,600	1200/18,700	0	2280	4170	6450	0	0.35	0.00
Dishwasher* (under-counter type, hot-water sanitizing) standby	26,600	1700/19,700	800	1040	3010	4850	800	0.27	0.34
Booster heater*	130,000	0	500	0	0	0	500	0	N/A

Note: Heat load values are prorated for 30% washing and 70% standby.



2009 ASHRAE Pocket Guide (I-P) (SECURED) - Adobe Acrobat Standard DC

File Edit View Window Help

Home Tools Document 169 (180 of 273) 131% Sign In

Cooling Load Estimates for Various Office Load Densities

	Num-ber	Each, W	Total, W	Diver-sity	Load, W
Light Load Density^a					
Computers	6	55	330	0.67	220
Monitors	6	55	330	0.67	220
Laser printer—small desk top	1	130	130	0.33	43
Fax machine	1	15	15	0.67	10
Total Area Load					494
Recommended equipment load factor = 0.5 W/ft ²					
Medium Load Density^a					
Computers	8	65	520	0.75	390
Monitors	8	70	560	0.75	420
Laser printer—desk	1	215	215	0.5	108
Fax machine	1	15	15	0.75	11
Total Area Load					929
Recommended equipment load factor = 1.0 W/ft ²					
Medium/Heavy Load Density^a					
Computers	10	65	650	1	650
Monitors	10	70	700	1	700
Laser printer—small office	1	320	320	0.5	160
Facsimile machine	1	30	30	0.5	15
Total Area Load					1525
Recommended equipment load factor = 1.5 W/ft ²					
Heavy Load Density^a					
Computers	12	75	900	1	900
Monitors	12	80	960	1	960
Laser printer—small office	1	320	320	0.5	160
Facsimile machine	1	30	30	0.5	15
Total Area Load					2035
Recommended equipment load factor = 2.0 W/ft ²					

Source: Wilkins and McGaffin (1994).

169

2009 ASHRAE Pocket Guide (I-P) (SECURED) - Adobe Acrobat Standard DC

File Edit View Window Help

Home Tools Document 170 (181 of 273) 131% Sign In

Refrigerating Effect Produced by Open Refrigerated Display Fixtures

Type of Display Fixture	Btu/h ft of Fixture ^a		Total Refrigerating Effect
	Latent Heat	Sensible Heat	
<i>Low temperature</i>			
<i>Frozen Food</i>			
Single Deck	38	207	245
Single Deck, Double Island	70	400	470
2 Deck	144	576	720
3 Deck	322	1288	1610
4 or 5 Deck	400	1600	2000
<i>Ice Cream</i>			
Single Deck	64	366	430
Single Deck, Double Island	70	400	470
<i>Standard Temperature</i>			
<i>Meats</i>			
Single Deck	52	298	350
Multideck	219	876	1095
<i>Dairy</i>			
Multideck	196	784	980
<i>Produce</i>			
Single Deck	36	204	240
Multideck	192	768	960

^aThese figures are general magnitudes for fixtures adjusted for average desired product temperatures and apply to store ambients in front of the display cases of 72°F to 74°F with 50% to 55% rh. Raising the dry bulb only 3°F to 5°F and the humidity 5% to 10% can increase heat removal 25% or more. Equally lower temperatures and humidities as in winter, have an equally marked effect on lowering heat removal from the space.

170

2009 ASHRAE Pocket Guide (I-P) (SECURED) - Adobe Acrobat Standard DC

File Edit View Window Help

Home Tools Document 171 (182 of 273) 131% Sign In

VENTILATION

ASHRAE Standard 62.2-2007, Ventilation and Acceptable Air Quality in Low-Rise Residential Buildings

Low-rise residential ventilation for single and multiple family structures of three stories or fewer above grade, including manufactured and modular houses.

Whole-house mechanical ventilation systems are required for each dwelling unit:

$$cfm = 0.01 (\text{ft}^2 \text{ floor area}) + 7.5 (\text{number of bedrooms} + 1).$$

Exceptions: (a) building is in zone 3B or 3C of the IECC 2007 climate zone map, (b) building has no mechanical cooling and is in zone 1 or 2 of the climate zone map (see p. 184), or (c) building is thermally conditioned for human occupancy for less than 876 hours per year and if the authority having jurisdiction determines that window ventilation is sufficient.

Alternate means may be used to provide the required ventilation rate when approved by a licensed design professional. In hot humid climates whole-house net mechanical exhaust shall not exceed 7.5 cfm per 100 ft². In severe cold climates net supply systems shall not exceed 7.5 cfm per 100 ft². (Climates are defined on p. 184.)

Local mechanical exhaust:

Intermittent Local Ventilation Exhaust Airflow Rates

Application	Airflow	Notes
Kitchen	100 cfm	Vented range hood (including appliance-range hood combinations) required if exhaust fan flow rate is less than 5 kitchen air changes per hour.
Bathroom	50 cfm	

Continuous Local Ventilation Exhaust Airflow Rates

Application	Airflow	Notes
Kitchen	5 air changes per hour	Based on kitchen volume
Bathroom	20 cfm	

Ventilation openings: not less than 4% of floor, nor less than 5 ft² for habitable rooms; and not less than 4% of floor space, nor less than 1.5 ft² for toilets and utility rooms.

Supply ductwork for thermal conditioners except evaporative coolers, shall have a MERV 6 filter or better in accordance with ASHRAE Standard 52.2.

Airflows all refer to delivered airflow as tested, or the fans' rating at 0.25 in. sp. with duct sizing meet the prescriptive sizing of the table below.

Prescriptive Duct Sizing

Duct Type	Flex Duct				Smooth Duct			
	50	80	100	125	50	80	100	125
Fan Rating CFM @ 0.25 in. wg	50	80	100	125	50	80	100	125
Diameter in.	Maximum Length ft. (m)							
3	X	X	X	X	5	X	X	X
4	70	3	X	X	105	35	5	X
5	NL	70	35	20	NL	135	85	55
6	NL	NL	125	95	NL	NL	NL	145
7 and above	NL	NL	NL	NL	NL	NL	NL	NL

This table assumes no elbows. Deduct 15 feet of allowable duct length for each elbow.
 NL = no limit on duct length of this size.
 X = not allowed, any length of duct of this size with assumed turns and fitting will exceed the rated pressure drop.

171

2009 ASHRAE Pocket Guide (I-P) (SECURED) - Adobe Acrobat Standard DC

File Edit View Window Help

Home Tools Document 172 (183 of 273) 131% Sign In

ASHRAE Standard 62.1-2007 (Occupancies except for low-rise residential)

Use of natural ventilation systems is permitted in lieu of or in conjunction with mechanical ventilation. Naturally ventilated spaces shall be permanently open to and within 25 ft of operable wall or roof openings to the outdoors; free openable area at least 4% of net occupiable floor area. If interior spaces are ventilated through adjoining rooms, free area between rooms shall be permanently unobstructed and at least 8% of the area of the interior room, nor less than 25 ft². Occupants must have ready access to the openings.

All airstream surfaces shall be designed to resist mold growth and resist erosion. Ductwork construction shall meet SMACNA standards. Fuel-burning appliances shall have sufficient air for combustion and adequate removal of combustion products, which shall be vented directly outdoors. Filters or air cleaners with minimum MERV 6 by ASHRAE Standard 52.2 shall be provided upstream of all cooling coils or other devices with wetted surfaces through which air is supplied to occupied space. Relative humidity should be below 65% when system performance is analyzed with outdoor at the design dew point and mean coincident dry bulb. Drain pans slope minimum 1/8 in. per ft to outlet at lowest point, and drain line shall have p-trap or other seal when drain pan is at negative static pressure relative to the outlet. Drain pan shall extend from leading edge of the coil to a distance of half the vertical dimension of the coil.

Discharge from non-combustion equipment that captures contaminants generated by the equipment shall be discharged directly outdoors.



Investigate outdoor air quality. Survey and document local outdoor air quality, with description of noticeable air problems and conditions regarding its acceptability. If unacceptable, test it. Cleaning for ozone is required only if in a high-ozone area and if the minimum design outdoor airflow is 1.5 air changes or more.

Outdoor air intakes shall be located so the shortest distance from intake to any specific contaminant source shall equal or exceed Table 5.1.

Design intakes to manage rain and snow entrainment and include bird screens.

The diagram illustrates a mechanical ventilation system. Outdoor air (Makeup Air) enters through an 'Other Air Cleaner Location' and an 'Exhaust' point. It then passes through an 'Energy Recovery Unit' and an 'Air Conditioning Unit'. The conditioned air is then distributed to 'Supply Air' and 'Local Ventilation'. The 'Local Ventilation' section shows air entering an 'Occupied Space' and then returning as 'Return Air'. The 'Return Air' is then exhausted through a 'General Exhaust' and an 'Exhaustion' point. The diagram also shows 'Alternate Paths for Recirculated Air' and 'Other Air Cleaner Locations' throughout the system.

172



2009 ASHRAE Pocket Guide (I-P) (SECURED) - Adobe Acrobat Standard DC

File Edit View Window Help

Home Tools Document 175 (186 of 273) 131% Sign In

TABLE 6-1 MINIMUM VENTILATION RATES IN BREATHING ZONE
(This table is not valid in isolation; it must be used in conjunction with the accompanying notes.)

Occupancy Category	People Outdoor Air Rate, R_p cfm/person L/s/person	Area Outdoor Air Rate, R_a cfm/ft ² L/s/m ²	Default Values		Notes	Occupant Density (see Note 4) #/1000 ft ³ #/100 m ³		Air Class
			Combined Outdoor Air Rate (see Note 5) cfm/person L/s/person					

GENERAL NOTES FOR TABLE 6-1

- Related requirements: The rates in this table are based on all other applicable requirements of this standard being met.
- Smoking: This table applies to non-smoking areas. Rates for smoking-permitted spaces must be determined using other methods. See Section 6.2.9 for ventilation requirements in smoking areas.
- Air density: Volumetric airflow rates are based on an air density of 0.075 lb_m/ft³ (1.2 kg_m/m³), which corresponds to dry air at a barometric pressure of 1 atm (101.3 kPa) and an air temperature of 70°F (21°C). Rates may be adjusted for actual density but such adjustment is not required for compliance with this standard.
- Default occupant density: The default occupant density shall be used when actual occupant density is not known.
- Default combined outdoor air rate (per person): This rate is based on the default occupant density.
- Unlisted occupancies: If the occupancy category for a proposed space or zone is not listed, the requirements for the listed occupancy category that is most similar in terms of occupant density, activities and building construction shall be used.
- Health-care facilities: Rates shall be determined in accordance with Appendix E.

ITEM-SPECIFIC NOTES FOR TABLE 6-1

A For high school and college libraries, use values shown for Public Assembly Spaces—Libraries.

B Rate may not be sufficient when stored materials include those having potentially harmful emissions.

C Rate does not allow for humidity control. Additional ventilation or dehumidification may be required to remove moisture.

D Rate does not include special exhaust for stage effects, e.g., dry ice vapor, smoke.

E When combustion equipment is intended to be used on the playing surface, additional dilution ventilation and/or source control shall be provided.

F Default occupancy for dwelling units shall be two persons for studio and one-bedroom units, with one additional person for each additional bedroom.

G Air from one residential dwelling shall not be recirculated or transferred to any other space outside of that dwelling.

Correctional Facilities

Cell	5	2.5	0.12	0.6	25	10	4.9	2
Dayroom	5	2.5	0.06	0.3	30	7	3.5	1
Guard stations	5	2.5	0.06	0.3	15	9	4.5	1
Booking/waiting	7.5	3.8	0.06	0.3	50	9	4.4	2

Educational Facilities

Daycare (through age 4)	10	5	0.18	0.9	25	17	8.6	2	
Daycare sickroom	10	5	0.18	0.9	25	17	8.6	3	
Classrooms (ages 5–6)	10	5	0.12	0.6	25	15	7.4	1	
Classrooms (ages 9 plus)	10	5	0.12	0.6	35	13	6.7	1	
Lecture classroom	7.5	3.8	0.06	0.3	65	8	4.3	1	
Lecture hall (fixed seats)	7.5	3.8	0.06	0.3	150	8	4.0	1	
Art classroom	10	5	0.18	0.9	20	19	9.5	2	
Science laboratories	10	5	0.18	0.9	25	17	8.6	2	
University/college laboratories	10	5	0.18	0.9	25	17	8.6	2	
Wood/metal shop	10	5	0.18	0.9	20	19	9.5	2	
Computer lab	10	5	0.12	0.6	25	15	7.4	1	
Media center	10	5	0.12	0.6	A	25	15	7.4	1
Music/theater/dance	10	5	0.06	0.3	35	12	5.9	1	
Multi-use assembly	7.5	3.8	0.06	0.3	100	8	4.1	1	

Food and Beverage Service

Restaurant dining rooms	7.5	3.8	0.18	0.9	70	10	5.1	2
Cafeteria/fast-food dining	7.5	3.8	0.18	0.9	100	9	4.7	2
Bar, cocktail lounge	7.5	3.8	0.18	0.9	100	9	4.7	2

General

Break rooms	5	2.5	0.06	0.3	25	10	5.1	1
Coffee stations	5	2.5	0.06	0.3	20	11	5.5	1
Conference/meeting	5	2.5	0.06	0.3	50	6	3.1	1
Corridors	—	—	0.06	0.3	—	—	—	1
Storage rooms	—	—	0.12	0.6	B	—	—	1

Hotels, Motels, Resorts, Dormitories

Bedroom/living room	5	2.5	0.06	0.3	10	11	5.5	1
---------------------	---	-----	------	-----	----	----	-----	---

175

2009 ASHRAE Pocket Guide (I-P) (SECURED) - Adobe Acrobat Standard DC

File Edit View Window Help

Home Tools Document 176 (187 of 273) 131% Sign In

TABLE 6-1 MINIMUM VENTILATION RATES IN BREATHING ZONE (Continued)
(This table is not valid in isolation; it must be used in conjunction with the accompanying notes.)

Barracks (sleeping areas)	5	2.5	0.06	0.3	20	8	4.0	1	
Laundry rooms, central	5	2.5	0.12	0.6	10	17	8.5	2	
Laundry rooms within dwelling units	5	2.5	0.12	0.6	10	17	8.5	1	
Lobbies/prefunction	7.5	3.8	0.06	0.3	30	10	4.8	1	
Multi-purpose assembly	5	2.5	0.06	0.3	120	6	2.8	1	
Office Buildings									
Office space	5	2.5	0.06	0.3	5	17	8.5	1	
Reception areas	5	2.5	0.06	0.3	30	7	3.5	1	
Telephone/data entry	5	2.5	0.06	0.3	60	6	3.0	1	
Main entry lobbies	5	2.5	0.06	0.3	10	11	5.5	1	
Miscellaneous Spaces									
Bank vaults/safe deposit	5	2.5	0.06	0.3	5	17	8.5	2	
Computer (not printing)	5	2.5	0.06	0.3	4	20	10.0	1	
Electrical equipment rooms	—	—	0.06	0.3	B	—	—	1	
Elevator machine rooms	—	—	0.12	0.6	B	—	—	1	
Pharmacy (prep. area)	5	2.5	0.18	0.9	10	23	11.5	2	
Photo studios	5	2.5	0.12	0.6	10	17	8.5	1	
Shipping/receiving	—	—	0.12	0.6	B	—	—	1	
Telephone closets	—	—	0.00	0.0	—	—	—	1	
Transportation waiting	7.5	3.8	0.06	0.3	100	8	4.1	1	
Warehouses	—	—	0.06	0.3	B	—	—	2	
Public Assembly Spaces									
Auditorium seating area	5	2.5	0.06	0.3	150	5	2.7	1	
Places of religious worship	5	2.5	0.06	0.3	120	6	2.8	1	
Courtyards	5	2.5	0.06	0.3	70	6	2.9	1	
Legislative chambers	5	2.5	0.06	0.3	50	6	3.1	1	
Libraries	5	2.5	0.12	0.6	10	17	8.5	1	
Lobbies	5	2.5	0.06	0.3	150	5	2.7	1	
Museums (children's)	7.5	3.8	0.12	0.6	40	11	5.3	1	
Museums/galleries	7.5	3.8	0.06	0.3	40	9	4.6	1	
Residential									
Dwelling unit	5	2.5	0.06	0.3	F, G	F	—	1	
Common corridors	—	—	0.06	0.3	—	—	—	1	
Retail									
Sales (except as below)	7.5	3.8	0.12	0.6	15	16	7.8	2	
Mall common areas	7.5	3.8	0.06	0.3	40	9	4.6	1	
Barbershop	7.5	3.8	0.06	0.3	25	10	5.0	2	
Beauty and nail salons	20	10	0.12	0.6	25	25	12.4	2	
Pet shops (animal areas)	7.5	3.8	0.18	0.9	10	26	12.8	2	
Supermarket	7.5	3.8	0.06	0.3	8	15	7.6	1	
Coin-operated laundries	7.5	3.8	0.06	0.3	20	11	5.3	2	
Sports and Entertainment									
Sports arena (play area)	—	—	0.30	1.5	E	—	—	1	
Gym, stadium (play area)	—	—	0.30	1.5	—	30	—	2	
Spectator areas	7.5	3.8	0.06	0.3	150	8	4.0	1	
Swimming (pool & deck)	—	—	0.48	2.4	C	—	—	2	
Disco/dance floors	20	10	0.06	0.3	100	21	10.3	1	
Health club/aerobics room	20	10	0.06	0.3	40	22	10.8	2	
Health club/weight rooms	20	10	0.06	0.3	10	26	13.0	2	
Bowling alley (seating)	10	5	0.12	0.6	40	13	6.5	1	
Gambling casinos	7.5	3.8	0.18	0.9	120	9	4.6	1	
Game arcades	7.5	3.8	0.18	0.9	20	17	8.3	1	
Stages, studios	10	5	0.06	0.3	D	70	11	5.4	1

2009 ASHRAE Pocket Guide (I-P) (SECURED) - Adobe Acrobat Standard DC

File Edit View Window Help

Home Tools Document 177 (188 of 273) 131% Sign In

Ventilation Rate Procedure to Standard 62.1
(There is also an Indoor Air Quality Procedure, which is performance-based.)

Definitions

A_z = zone floor area, ft²
 P_z = zone population
 R_p = outdoor airflow rate per person, cfm, from Table 6-1
 R_a = outdoor airflow rate per unit area, cfm, from Table 6-1
 V_{bz} = breathing zone airflow, $V_{bz} = R_p \cdot P_z + R_a \cdot A_z$
 E_z = zone air distribution effectiveness, Table 6-2
 V_{oz} = outdoor airflow required for zone, $V_{oz} = V_{bz} / E_z$
 V_{ot} = outdoor intake airflow
 For single-zone system, $V_{ot} = V_{oz}$
 For 100% outdoor system (one air handler), $V_{ot} = \sum_{all\ zones} V_{oz}$
 Z_p = zone primary air fraction, from Table 6-3, $Z_p = V_{oz} / V_{pz}$
 where V_{pz} = zone primary air zone
 E_v = system ventilation efficiency, from Table 6-3
 V_{ou} = uncorrected outdoor intake airflow, $V_{ou} = D \sum_{all\ zones} (R_p \cdot P_z) + \sum_{all\ zones} (R_a \cdot P_z)$
 V_{ot} = design outdoor intake, $V_{ot} = V_{ou} / E_v$

Exhaust airflow shall be provided in accordance with Table 6-4.
 Strict separation of spaces containing environmental tobacco smoke (ETS) from ETS-free areas is required. ETS-free areas must be at a positive pressure with respect to adjacent or connected ETS areas.

177

2009 ASHRAE Pocket Guide (I-P) (SECURED) - Adobe Acrobat Standard DC

File Edit View Window Help

Home Tools Document 178 (189 of 273) 131% Sign In

TABLE 6-2 Zone Air Distribution Effectiveness

Air Distribution Configuration	E_z
Ceiling supply of cool air.	1.0
Ceiling supply of warm air and floor return.	1.0
Ceiling supply of warm air 15°F (8°C) or more above space temperature and ceiling return.	0.8
Ceiling supply of warm air less than 15°F (8°C) above space temperature and ceiling return provided that the 150 fpm (0.8 m/s) supply air jet reaches to within 4.5 ft (1.4 m) of floor level. <i>Note:</i> For lower velocity supply air, $E_z = 0.8$.	1.0
Floor supply of cool air and ceiling return provided that the 150 fpm (0.8 m/s) supply jet reaches 4.5 ft (1.4 m) or more above the floor. <i>Note:</i> Most underfloor air distribution systems comply with this proviso.	1.0
Floor supply of cool air and ceiling return, provided low-velocity displacement ventilation achieves unidirectional flow and thermal stratification.	1.2
Floor supply of warm air and floor return.	1.0
Floor supply of warm air and ceiling return.	0.7
Makeup supply drawn in on the opposite side of the room from the exhaust and/or return.	0.8
Makeup supply drawn in near to the exhaust and/or return location.	0.5

1. "Cool air" is air cooler than space temperature.
 2. "Warm air" is air warmer than space temperature.
 3. "Ceiling" includes any point above the breathing zone.
 4. "Floor" includes any point below the breathing zone.
 5. As an alternative to using the above values, E_z may be regarded as equal to air change effectiveness determined in accordance with ANSI/ASHRAE Standard 129¹⁶ for all air distribution configurations except unidirectional flow.

TABLE 6-3 System Ventilation Efficiency

Max (Z_p)	E_v
≤ 0.15	1.0
≤ 0.25	0.9
≤ 0.35	0.8
≤ 0.45	0.7
≤ 0.55	0.6
> 0.55	Use Appendix A

1. "Max Z_p " refers to the largest value of Z_p calculated using Equation 6-5, among all the zones served by the system.
 2. For values of Z_p between 0.15 and 0.55, one may determine the corresponding value of E_v by interpolating the values in the table.
 3. The values of E_v in this table are based on a 0.15 average outdoor air fraction for the system (i.e., the ratio of the uncorrected outdoor air intake V_{ou} to the total zone primary airflow for all the zones served by the air handler). For systems with higher values of the average outdoor air fraction, this table may result in unrealistically low values of E_v , and the use of Appendix A may yield more practical results.

178

2009 ASHRAE Pocket Guide (I-P) (SECURED) - Adobe Acrobat Standard DC

File Edit View Window Help

Home Tools Document 179 (190 of 273) 131% Sign In

TABLE 6-4 Minimum Exhaust Rates

Occupancy Category	Exhaust Rate, cfm/unit	Exhaust Rate, cfm/ft ²	Notes	Exhaust Rate, L/s-unit	Exhaust Rate, L/s-m ²	Air Class
Arenas	—	0.50	B	—	—	1
Art classrooms	—	0.70	—	—	3.5	2
Auto repair rooms	—	1.50	A	—	7.5	2
Barber shops	—	0.50	—	—	2.5	2
Beauty and nail salons	—	0.60	—	—	3.0	2
Cells with toilet	—	1.00	—	—	5.0	2
Copy, printing rooms	—	0.50	—	—	2.5	2
Darkrooms	—	1.00	—	—	5.0	2
Educational science laboratories	—	1.00	—	—	5.0	2
Janitor closets, trash rooms, recycling	—	1.00	—	—	5.0	3
Kitchenettes	—	0.30	—	—	1.5	2
Kitchens—commercial	—	0.70	—	—	3.5	2
Locker/dressing rooms	—	0.25	—	—	1.25	2
Locker rooms	—	0.50	—	—	2.5	2
Paint spray booths	—	—	F	—	—	4
Parking garages	—	0.75	C	—	3.7	2
Pet shops (animal areas)	—	0.90	—	—	4.5	2
Refrigerating machinery rooms	—	—	F	—	—	3
Residential kitchens	50/100	—	G	25/50	—	2
Soiled laundry storage rooms	—	1.00	F	—	5.0	3
Storage rooms, chemical	—	1.50	F	—	7.5	4
Toilets—private	25/50	—	E	12.5/25	—	2
Toilets—public	50/70	—	D	25/35	—	2
Woodwork shop/classrooms	—	0.50	—	—	2.5	2

A Strands where engines are run shall have exhaust systems that directly connect to the engine exhaust and prevent escape of fumes.
B When construction equipment is intended to be used on the playing surface additional dilution ventilation and/or source control shall be provided.
C Exhaust not required if two or more sides comprise walls that are at least 50% open to the outside.
D Rate is per water closet and/or urinal. Provide the higher rate where periods of heavy use are expected to occur, e.g., toilets in theatres, schools, and sports facilities. The lower rate may be used otherwise.
E Rate is for a toilet room intended to be occupied by one person at a time. For continuous system operation during normal hours of use, the lower rate may be used. Otherwise use the higher rate.
F See other applicable standards for exhaust rate.
G For continuous system operation, the lower rate may be used. Otherwise use the higher rate.

179

2009 ASHRAE Pocket Guide (I-P) (SECURED) - Adobe Acrobat Standard DC

File Edit View Window Help

Home Tools Document 180 (191 of 273) 131% Sign In

Multiple-Zone Systems
(From Appendix A of Standard 62.1-2004)

This is an alternative procedure for calculating the *system ventilation efficiency* (E_s) that must be used when Table 6-3 values are not used. In this alternative procedure, E_s is equal to the lowest calculated value of the *zone ventilation efficiency* E_{vz} (see Equation A-3 below). Figure A-1 contains a ventilation system schematic depicting most of the quantities used in this appendix.

The *zone ventilation efficiency* E_{vz} , i.e., the efficiency with which a system distributes outdoor air from the intake to an individual *breathing zone*, shall be calculated using Equation G-1 or G-2.

Single Supply Systems $E_{vz} = I + X_z - Z_d$ (A-1)

Equation A-1 (or A-2) shall be used for "single supply" systems, where all the ventilation air is a mixture of outdoor air and recirculated air from a single location, e.g., Reheat, Single-Duct VAV, Single-Fan Dual-Duct, and Multizone.

General Case $E_{vz} = (F_a + X_z * F_b - Z_d * F_d) / F_a$ (A-2)

Equation A-2 shall be used for systems that provide all or part of their ventilation by recirculating air from other zones without directly mixing it with outdoor air, e.g., dual-fan dual-duct, fan-powered mixing box, and transfer fans for conference rooms.


The system ventilation efficiency shall be calculated using Equation G-3.

$E_v = \text{minimum } (E_{vz})$ (A-3)

Definitions

A_z Zone Floor Area: the net occupiable floor area of the zone m², (ft²).
 D Occupant Diversity: the ratio of the *system population* to the sum of the *zone populations*:
 $D = P_s / \sum P_z$
 E_z Zone Air Distribution Effectiveness (E_z): a measure of how effectively the zone air distribution uses its supply air to maintain acceptable air quality in the *breathing zone*. E_z is determined from Table 6.2.
 E_v System Ventilation Efficiency: the efficiency with which the system distributes air from the outdoor air intake to the breathing zone in the ventilation-critical zone, which requires the largest fraction of outdoor air in the primary airstream. E_v is determined from Table 6-3.
 P_s System Population: the maximum simultaneous number of occupants in the area served by the system. Where population fluctuates, it may be averaged as described in Section 6.2.5.2. Note: Occupant load for egress often determines system population.
 P_z Zone Population: the largest number of people expected to occupy the zone during typical usage. If P_z is not known, it is determined from the default occupant densities listed in Table 6-1. Where population fluctuates, it may be averaged as described in Section 6.2.5.2.
 R_p People Outdoor Air Rate: the outdoor airflow rate per person to be provided in the breathing zone to dilute contaminants that are emitted at a rate that is related more to population than to floor area. The value of R_p for a zone is determined from Table 6.1.
 V_{bz} Breathing Zone Outdoor Airflow: the outdoor airflow required in the breathing zone of an occupiable space, $V_{bz} = R_p * P_z + R_o * A_z$.
 V_{oz} Zone Outdoor Airflow: the design outdoor airflow required in the zone, i.e., $V_{oz} = V_{bz} / E_z$.
 V_{oi} Outdoor Air Intake Flow: the design outdoor airflow required at the ventilation system outdoor air intake.
 V_{ou} Uncorrected Outdoor Air Intake: The outdoor air intake flow required if the system ventilation efficiency E_v were 1.0. $V_{ou} = D * \sum R_p * P_z + \sum R_o * A_z$.
 V_{pz} Zone Primary Airflow: The primary airflow supplied to the zone from the air-handling unit at which the outdoor air intake is located, L/s (cfm). It includes outdoor intake air and recirculated air from that air-handling unit but does not include air transferred or air recirculated to the zone by other means.

180



2009 ASHRAE Pocket Guide (I-P) (SECURED) - Adobe Acrobat Standard DC

File Edit View Window Help

Home Tools Document 182 (193 of 273) 131% Sign In

Operation and Maintenance

Provide an O&M manual together with final system design drawings, updated and maintained on site.

Table 8-1 Minimum Maintenance Activity and Frequency

Item	Activity Code	Minimum Frequency ^a
Filters and air cleaning devices	A	According to O & M Manual
Outdoor air dampers and actuators	B	Every three months or in accordance with O & M Manual
Humidifiers	C	Every three months of use or in accordance with O & M Manual
Dehumidification coils	D	Regularly when it is likely that dehumidification occurs but no less than once per year or as specified in the O & M Manual
Drain pans and other adjacent surfaces subject to wetting	D	Once per year during cooling season or as specified in the O & M Manual
Outdoor air intake louvers, bird screens, mist eliminators, and adjacent areas	E	Every six months or as specified in the O & M Manual
Sensors used for dynamic minimum outdoor air control	F	Every six months or periodically in accordance with O & M Manual
Air-handling systems except for units under 2000 cfm (1000 L/s)	G	Once every five years
Cooling towers	H	In accordance with O & M Manual or treatment system provider
Floor drains located in plenums or rooms that serve as air plenums	I	Periodically according to O & M Manual
Equipment/component accessibility	J	
Visible microbial contamination	K	
Water intrusion or accumulation	K	

ACTIVITY CODE:

A Maintain according to O & M Manual.

B Visually inspect or remotely monitor for proper function.

C Clean and maintain to limit fouling and microbial growth.

D Visually inspect for cleanliness and microbial growth and clean when fouling is observed.

E Visually inspect for cleanliness and integrity and clean when necessary.

F Verify accuracy and recalibrate or replace as necessary.

G Measure minimum quantity of outdoor air. If measured minimum air flow rates are less than 90% of the minimum outdoor air rate in the O & M Manual, they shall be adjusted or modified to bring them above 90% or shall be evaluated to determine if the measured rates are in conformance with the standard.

H Treat to limit the growth of microbiological contaminants.

I Maintain to prevent transport of contaminants from the floor drain to the plenum.

J Keep clear the space provided for routine maintenance and inspection around ventilation equipment.

K Investigate and rectify.

^a Minimum Frequencies may be increased or decreased if indicated in the O&M manual.

182