

$$Q_{\text{Btu per hour}} = 1.08 \times \text{Flow}_{\text{Cubic Feet per Minute}} \times (\text{Temperature}_{\text{In, } ^\circ\text{F}} - \text{Temperature}_{\text{Out, } ^\circ\text{F}})$$

Where:

$Q_{\text{Btu per hour}}$ = Sensible energy change in the air stream

1.08 = Unit conversion constant for dry air at 70°F

$\text{Flow}_{\text{Cubic Feet per Minute}}$ = The flow rate for the current operating mode based on TAB data

$(\text{Temperature}_{\text{In, } ^\circ\text{F}} - \text{Temperature}_{\text{Out, } ^\circ\text{F}})$ = Heat exchanger temperature difference