


Note 1

Refer to Mechanical and Electrical drawings for smoke detector requirements and locations. Provide number of smoke detectors as shown on the drawings. Require or confirm existing interlock wiring to comply with the specifications.

## POINTS LIST

| POINT DESCRIPTOR | POINT TYPE DI | AI | DO | AO |
|---|---|---|---|---|
| AHx OA Damper | | | * | |
| AHx MA Temp | | * | | |
| AHx Smoke Alarm | * | | | |
| AHx Filter Alarm | * | | | |
| AHx Fan Proof | * | | | |
| AHx Fan S/S | | | * | |
| AHx Override | * | | | |
| AHx Space Temp. | | * | | |
| AHx Temp Adj. | | * | | |
| AHx Chw Valve | | | | * |
| AHx SA Temp | | * | | |
| EFx S/S | | | * | |
| | | | | |
| TOTALS | 4 | 4 | 3 | 1 |
| | | | | |
| | | | | |
| | | | | |




AHx Supply Fan

# WIRING DIAGRAMS




# CV AIR HANDLING UNIT W/ CHW & MINIMUM OA