

Note 1

Refer to Mechanical and Electrical drawings for smoke detector requirements and locations. Provide number of smoke detectors as shown on the drawings. Reuire or confirm existing interlock wiring to comply with the specifications.

POINTS LIST

POINT DESCRIPTOR	POINT TYPE DI	AI	DO	AO
AHx OA Damper			*	
AHx MA Temp		*		
AHx Smoke Alarm	*			
AHx Filter Alarm	*			
AHx Fan Proof	*			
AHx Fan S/S			*	
AHx Override	*			
AHx Space Temp.		*		
AHx Temp Adj.		*		
AHx Cool 1 SS			*	
AHx Cool x SS			X	
AHx SA Temp		*		
EFx S/S			*	
TOTALS	4	4	X	



* Provide number of stages as required

AHU TERMINAL STRIP

Interface board terminal strip by unit manufacturer



CV AIR HANDLING UNIT W/ DX & MIN OA

WIRING DIAGRAMS