

Fans, Ducts and Air Handling Systems: Design, Performance and Commissioning Issues

Dehumidification



Instructor:

David Sellers

Senior Engineer


Facility Dynamics Engineering

November 7, 2017


The Conventional Approach



The Relationship Between Dehumidification and Discharge Temperature




ALTITUDE: SEA LEVEL
BAROMETRIC PRESSURE: 29.921 in. HG
ATMOSPHERIC PRESSURE: 14.696 psia




Determine the Sensible Heat Ratio (SHR) and plot it on the SHR Scale of a psych chart.

A SHR of 0.85 is typical of many office buildings


See *HVAC Data, Equations, and Rules of Thumb* for SHR's for other building types (and a whole lot more)



ALTITUDE: SEA LEVEL
BAROMETRIC PRESSURE: 29.921 in. HG
ATMOSPHERIC PRESSURE: 14.696 psia



ALTITUDE: SEA LEVEL
BAROMETRIC PRESSURE: 29.921 in. HG
ATMOSPHERIC PRESSURE: 14.696 psia



ALTITUDE: SEA LEVEL
BAROMETRIC PRESSURE: 29.921 in. HG
ATMOSPHERIC PRESSURE: 14.696 psia







Chart by: AKTON PSYCHROMETRICS, www.aktonassoc.com

ALTITUDE: SEA LEVEL
 BAROMETRIC PRESSURE: 29.921 in. HG
 ATMOSPHERIC PRESSURE: 14.696 psia




SHR = .85; typical of many office buildings



The slope of the SHR line represents the relationship between the **dehumidification load or moisture** that must be removed from the space to maintain steady state conditions


... and the **sensible load or heat** that must be removed from the space to maintain steady state conditions

ALTITUDE: SEA LEVEL
 BAROMETRIC PRESSURE: 29.921 in. HG
 ATMOSPHERIC PRESSURE: 14.696 psia




Apparatus Dew Point (ADP) = where the SHR line crosses the saturation curve

Cooling coils produce air that is near saturation if the air entering has a dew point above the temperature of the refrigerant in the coil



As a result, air will tend to leave a cooling coil near the point where the SHR line intersects the saturation line

ALTITUDE: SEA LEVEL
 BAROMETRIC PRESSURE: 29.921 in. HG
 ATMOSPHERIC PRESSURE: 14.696 psia



Approach to the ADP depends on things like coil depth and fins spacing

- Deeper coils = better approach
- More fins per inch = better approach

The bypass factor method developed by Willis Carrier in 1936 can be used to approximate the approach to saturation

Apparatus Dew Point (ADP) = where the SHR line crosses the saturation curve






Chart by: AKTON PSYCHROMETRICS, www.aktonassoc.com

ALTITUDE: SEA LEVEL
 BAROMETRIC PRESSURE: 29.921 in. HG
 ATMOSPHERIC PRESSURE: 14.696 psia



Apparatus Dew Point (ADP) = where the SHR line crosses the saturation curve



$$(T_{\text{CoilEnteringAir}} \times K_{\text{Bypass}}) + (ADP \times (1 - K_{\text{Bypass}})) = T_{\text{CoilLeavingAir}}$$

Where:

$T_{\text{CoilEnteringAir}}$ = CoilEnteringAir Temperature

K_{Bypass} = BypassFactor(see below)

ADP = ApparatusDewPoint

$T_{\text{CoilLeavingAir}}$ = CoilLeavingAir Temperature

TypicalCoilBypassFactors

4 row coil = .20

5 row coil = .15

6 row coil = .10

8 row coil = .05

How to Design Heating Cooling Comfort Systems

Joseph B. Olivieri, P.E.

ALTITUDE: SEA LEVEL
 BAROMETRIC PRESSURE: 29.921 in. HG
 ATMOSPHERIC PRESSURE: 14.696 psia







Chart by: AKTON PSYCHROMETRICS, www.aktonassoc.com

ALTITUDE: SEA LEVEL
 BAROMETRIC PRESSURE: 29.921 in. HG
 ATMOSPHERIC PRESSURE: 14.696 psia



Bigger **dehumidification loads** translate to smaller SHR's, steeper SHR lines, and lower cooling coil discharge temperatures

Chart by: AKTON PSYCHROMETRICS, www.aktonassoc.com

Desiccant Dehumidification


An alternative to the conventional approach

Desiccant Dehumidification

An alternative to the conventional approach


- A technique for achieving very low humidity levels that would otherwise be difficult to achieve
- Chemical process in which the water vapor either interact with the surface of a desiccant (ad^sorption) or permeates the desiccant (ab^sorption)
- Water gives up latent energy in the process so the temperature tends to rise in the process stream
- Most HVAC equipment regenerates the desiccant by blowing hot (250°F or higher) air across the desiccant

A Desiccant System Applied to Supplement a Conventional AHU



A Desiccant System Applied to Supplement a Conventional AHU

AHU C air is nominally 54.3/52.5 tdb/twb at the cooling coil discharge when the coil is condensing




A Desiccant System Applied to Supplement a Conventional AHU

In this case energy was saved relative to a conventional approach because:

- Archival storage requirements set the air change rate and the humidity level
- Conventional dehumidification would have required a 39°F supply air temperature
- There were very few sensible gains
- The air change requirements at a 39°F supply air temperature would have required significant reheat round the clock

Dehumidification requires energy no matter how you do it

A Desiccant System Dedicated to a Very Cold, Dry Archival Storage Requirement



Pressure 29.92 inHg
Altitude 0 ft

