

# Fans, Ducts and Air Handling Systems: Design, Performance and Commissioning Issues

## Filters



Instructor:

David Sellers

Senior Engineer

Facility Dynamics Engineering

November 7, 2017



*Conventional Thinking = HVAC is Filtration*



## Filtration and HVAC Go Hand in Hand

Air conditioning is the control of the humidity of the air by either increasing or decreasing its moisture content. Added to the control of the humidity are the control of temperature either by heating or cooling the air, the purification of the air by washing or filtering the air, and the control of air motion and ventilation.

Dr. Willis Carrier



## Filtration and HVAC Go Hand in Hand

Air conditioning is the control of the humidity of the air by either increasing or decreasing its moisture content. Added to the control of the humidity are the control of temperature either by heating or cooling the air, *the purification of the air by washing or filtering the air*, and the control of air motion and ventilation.

Dr. Willis Carrier

# LEED® Requirements Push Towards Higher Filtration Levels


## IE Q Credit 5: Indoor Chemical and Pollutant Source Control

- *Particle filters or air cleaning devices shall be provided to clean the outdoor air at any location prior to its introduction to occupied spaces.*
- *These filters or devices shall be rated a minimum efficiency reporting value (MERV) of 13 or higher in accordance with ASHRAE Standard 52.2.*

# Face Loading Filters



# Depth Loading Filters




# Filtration Mechanisms

- **Straining**
- **Impingement**
- **Interception**
- **Diffusion**
- **Electrostatic Effects**



*Conventional Thinking = They're All About the Same*



### Camfil Farr HI-FLO

- MERV11 (60-65% ASHRAE Dust-spot Efficiency)
- 24" high, 12" wide, 22" deep
- 4 flexible pockets
- 29 sq.ft. of high lofted air laid micro fiber glass media
- $\Delta P_{\text{Clean}}$  at 500 fpm = 0.28 in.w.c.
- $\Delta P_{\text{MaxDirty}} = 1.00$  in.w.c.
- Dust holding capacity – Not published
- \$16.68

## Filtrair FMV

- MERV14 (95% ASHRAE Dust-spot Efficiency)
- 24" high, 12" wide, 11.5" deep
- 4 rigid pockets
- 77.5 sq.ft. of wet laid scrim laminated to a proprietary gradient density melt blown matrix of synthetic fibers
- $\Delta P_{\text{Clean}}$  at 500 fpm = 0.34 in.w.c.
- $\Delta P_{\text{MaxDirty}} = 1.50$  in.w.c.
- Dust holding capacity = 125 grams
- \$85



### Camfil Farr RIGA-FLO

- MERV11 (60-65% ASHRAE Dust-spot Efficiency)
- 24" high, 12" wide, 11.5" deep
- 8 semi-rigid pockets
- 26.5 sq.ft. of high-lofted, depth-loading, microfine glass media
- $\Delta P_{\text{Clean}}$  at 500 fpm = 0.31 in.w.c.
- $\Delta P_{\text{MaxDirty}} = 1.50$  in.w.c.
- Dust holding capacity = not published
- \$49.97



## FILTRAIR PTL (F6)

- MERV11 (60-65% ASHRAE Dust-spot Efficiency)
- 24" high, 24" wide, 24" deep
- 8 rigid pockets
- High performance depth loading fibers laid using a progressive density multi-layering technique
- $\Delta P_{\text{Clean}}$  at 500 fpm = 0.17 in.w.c.
- $\Delta P_{\text{MaxDirty}} = 1.60$  in.w.c.
- Dust holding capacity = 1,150 grams
- \$124



*Conventional Thinking = They're All About the Same*



### Summary

| Model    | First Cost | MERV | $\Delta P$ , in.w.c.<br>at 500 fpm | Media Area<br>sq.ft. |
|----------|------------|------|------------------------------------|----------------------|
| HI-FLO   | \$16.68    | 11   | 0.28                               | 29.0                 |
| FMV      | \$85.00    | 14   | 0.34                               | 77.5                 |
| RIGA-FLO | \$49.97    | 11   | 0.31                               | 26.5                 |
| PTL (F6) | \$124      | 11   | 0.17                               | 64.0 (estimated)     |

## Summary

| Model    | First Cost | MERV | $\Delta P$ , in.w.c.<br>at 500 fpm | Media Area<br>sq.ft. |
|----------|------------|------|------------------------------------|----------------------|
| HI-FLO   | \$16.68    | 11   | 0.28                               | 29.0                 |
| FMV      | \$85.00    | 14   | 0.34                               | 77.5                 |
| RIGA-FLO | \$49.97    | 11   | 0.31                               | 26.5                 |
| PTL (F6) | \$124      | 11   | 0.17                               | 64.0 (estimated)     |

# Filter Life Cycle Costs

## First cost component


- Decreases over time
- Non-linear
  - Day 1 – Cost per day = Cost of filter set
  - Day X – Cost per day = (Cost of filter set)/X Days

## Energy cost component

- Increases over time
- Non-linear

## Total cost component

- Decreases then increases over time
- Change filters at inflection point for best life cycle cost



# The Life Cycle Cost Game

## Benefits of more expensive media


- More surface area
- Engineered loading characteristics
- Lower pressure drops (less fan energy)
- More dust holding capability

## Leveraging the benefits

- Lower fan energy
- Longer life
- Eliminate prefilters
  - Eliminates related fan energy
  - Eliminates related labor
  - Eliminates related disposal
  - Allows final filters to run to a higher  $\Delta P_{\text{Dirty}}$

## Filter Cost per Average Day and Accumulated Savings

UCB LeConte Hall Current Practice (65% ASHRAE Efficiency Bag filters with Prefilters) vs. 65% Efficiency Extended Surface Area Filters with No Prefilters



## Savings Summary - First Year Basis

|                   | Electricity              |              | Filters          | Total          | Waste      |
|-------------------|--------------------------|--------------|------------------|----------------|------------|
|                   | kWh                      | \$           | \$               | \$             | cu. yd.    |
| Existing Approach | 8,366                    | \$837        | \$631            | \$1,468        | 4.9        |
| Proposed Approach | 1,966                    | \$197        | \$1,860          | \$2,057        | 4.4        |
| Savings           | <b>6,400</b>             | <b>\$640</b> | <b>(\$1,229)</b> | <b>(\$589)</b> | <b>0.5</b> |
| Simple Payback    | 1.92 years (energy only) |              |                  |                |            |

## Savings Summary - 48 Month

Taking a life cycle perspective is important

|                   |                           |                |                |                |            |
|-------------------|---------------------------|----------------|----------------|----------------|------------|
| Existing Approach | 45,151                    | \$1,875        | \$1,232        | \$5,909        | 9.9        |
| Proposed Approach | 13,646                    | \$1,365        | \$1,860        | \$3,225        | 4.4        |
| Savings           | <b>32,816</b>             | <b>\$3,282</b> | <b>(\$598)</b> | <b>\$2,684</b> | <b>5.4</b> |
| Simple Payback    | 8.74 months (energy only) |                |                |                |            |

An important "ripple effect"

## Savings Summary - First Year Basis

|                   | Electricity              |              | Filters          | Total          | Waste      |
|-------------------|--------------------------|--------------|------------------|----------------|------------|
|                   | kWh                      | \$           | \$               | \$             | cu. yd.    |
| Existing Approach | 8,366                    | \$837        | \$631            | \$1,468        | 4.9        |
| Proposed Approach | 1,966                    | \$197        | \$1,860          | \$2,057        | 4.4        |
| <b>Savings</b>    | <b>6,400</b>             | <b>\$640</b> | <b>(\$1,229)</b> | <b>(\$589)</b> | <b>0.5</b> |
| Simple Payback    | 1.92 years (energy only) |              |                  |                |            |

## Savings Summary - 48 Month Cycle Basis

|                   |                           |                |                |                |            |
|-------------------|---------------------------|----------------|----------------|----------------|------------|
| Existing Approach | 46,461                    | \$4,646        | \$1,262        | \$5,909        | 9.9        |
| Proposed Approach | 13,646                    | \$1,365        | \$1,860        | \$3,225        | 4.4        |
| <b>Savings</b>    | <b>32,816</b>             | <b>\$3,282</b> | <b>(\$598)</b> | <b>\$2,684</b> | <b>5.4</b> |
| Simple Payback    | 8.74 months (energy only) |                |                |                |            |

Cost and benefit may not occur in the same purchasing group

- U.C. Berkeley BMS System
  - UC Berkeley Campus
    - UCB Birge Hall
    - UCB Boalt & Simon H
    - UCB Blum Hall
    - UCB DOE Library
    - UCB Durant Hall
    - UCB Leconte Hall
    - Roof
      - AHU-2
      - AHU-2 VFD Mod
      - Air Cooled Chill
      - Air Cooled Chill
      - EF-1
      - EF-2
      - EF-3
      - EF-4
      - EF-5
      - EF-6
      - Attic Temp East
      - Attic Temp West
      - OA Conditions
      - Fourth Floor
      - Third Floor
      - Second Floor
      - First Floor
      - Basement
        - UCB Latimer Hall
        - Museum Collections

Graphics Properties Schedules Alarms Trends Logic Reports

OAT 62.0 °F  
OAH 54 °F  
freeze protection Normal

### Leconte Hall AHU-2

releaf damper

Return Fan VFD  
start / stop On  
vfd speed 99 %  
Amps 16.6  
vfd fault Off 73.2 °F

spt 24989 cfm  
act 24726 cfm

spt 32000 cfm  
act 31989 cfm

spt 65.8 °F  
act 67.5 °F

zone temp 73.3 °F  
nominal clg setpt 74.0 °F  
setpoint adj by -0.1 °F  
effective cool setpt 73.9 °F  
Occupied until 8:00 PM

#### Filter Cost Analysis


Filter Interval Reset **Run**  
Reset Interval Whenever Filters are Changed.

|                          |         |    |
|--------------------------|---------|----|
| cost of filters          | 2300.00 | \$ |
| cost of labor            | 100.00  | \$ |
| cost of disposal         | 20.00   | \$ |
| total 1 time filter cost | 2420.00 | \$ |

|                  |        |      |
|------------------|--------|------|
| fan efficiency   | 0.75   | <1.0 |
| avg fan bhp      | 0.9    |      |
| motor efficiency | 0.80   | <1   |
| vfd efficiency   | 0.80   |      |
| avg motor kW     | 1.1    |      |
| motor kW-hrs     | 3776.7 |      |

|                       |       |    |
|-----------------------|-------|----|
| avg daily elec cost   | 2.30  | \$ |
| avg daily filter cost | 16.87 | \$ |
| avg daily total cost  | 19.18 | \$ |

“State of the art” technology allows real time monitoring for the “inflection point” in the filter life cycle cost curve (a.k.a. the point in time when you should change the filters)






## Camfil Farr Type 8

- 16 gauge galvanized steel
- Foam gaskets (optional)
- Spring clip retainers (not included)
- Riveted or bolted up assembly (not included)
- Structural steel supports required between every-other vertical row (not included and frequently omitted)
- \$66.97 per “hole” (materials only)

## Total Filtration Manufacturing Optiframe/H

- Extruded, epoxy powder coated framing material
- Tongue and groove joints between modules
- Quadruple closed cell foam gaskets between modules
- Knife edge filter seals
- 1.5" I beam structural support between rows
- Over-center and swing bolt retainers
- \$125 per "hole" (installed)



# Assessing Reality

Tests for installed efficiency and pressure drop

Captures the impact of field realities

- Real world dust
- Frame impacts
- System impacts

Provides for correlation with lab test



ASHRAE Guideline 26-2008

## ASHRAE GUIDELINE

### Guideline for Field Testing of General Ventilation Devices and Systems for Removal Efficiency In-Situ by Particle Size and Resistance to Flow

Approved by the ASHRAE Standards Committee on June 21, 2008, and by the ASHRAE Board of Directors on June 25, 2008.

ASHRAE Guidelines are updated on a five-year cycle; the date following the Guideline is the year of approval. The latest edition of an ASHRAE Guideline may be purchased from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: [orders@ashrae.org](mailto:orders@ashrae.org). Fax: 404-321-5478. Telephone: 404-636-8400 (worldwide) or toll free 1-800-527-4723 (for orders in US and Canada).

© Copyright 2008 ASHRAE, Inc.

ISSN 1049-894X

**American Society of Heating, Refrigerating  
and Air-Conditioning Engineers, Inc.**  
1791 Tullie Circle NE, Atlanta, GA 30329  
[www.ashrae.org](http://www.ashrae.org)

# Practice Due Diligence

- ASHRAE Journal article based on research in Denmark found a correlation between perceived air quality and filter life for flexible bag filters
- Scheduled operation seemed to make things worse
- Active carbon seemed to mitigate the problem
- For our field trails to date this has not been an issue

The following article was published in ASHRAE Journal, March 2009. ©Copyright 2009 American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc. It is presented for educational purposes only. This article may not be copied and/or distributed electronically or in paper form without permission of ASHRAE.




Figure 1a (left): New F7 (~MERV13) fiberglass bag filter. Figure 1b (right): The same filter after five months of continuous operation.

## Used Filters And Indoor Air Quality

By Gabriel Bekö, Ph.D.

The presence of used filters in a ventilation system can have an adverse impact on perceived air quality, Sick Building Syndrome symptoms, and performance of office work. This article briefly summarizes earlier works leading to this conclusion, as well as reviews our more recent studies performed to gain better understanding of this problem. Possible mechanisms responsible for the emission of noxious compounds from ventilation filters are described. Finally, the economic impact of polluting ventilation filters and possible engineering solutions are discussed.

Mechanical ventilation systems are commonly used to ensure that ventilation standards and guidelines are met. However, studies have documented that building occupants, especially in older and mechanically ventilated buildings,

consider the indoor air quality unacceptable and suffer from Sick Building Syndrome (SBS) symptoms, sometimes referred to as Building-Related Symptoms (BRS).<sup>1,2,3</sup> Consequently, poor air quality can negatively affect occupants'

productivity.<sup>4,5</sup> The prevalence of asthma and allergic diseases has increased during the past decades, most likely due to changes in environmental exposure.<sup>6</sup> Many of the particles either generated indoors or entering the buildings from outdoors can trigger allergic reactions, asthma, and upper and lower respiratory symptoms.<sup>7</sup> Moreover, epidemiological studies report close association between outdoor airborne particles and mortality and morbidity.<sup>8</sup>

Particulate pollutants (smoke, dust fibers, bioaerosols such as viruses, bacteria, and microorganisms) and gaseous pollutants may enter the buildings

### About the Author

Gabriel Bekö, Ph.D., is a post-doctoral research fellow at the International Centre for Indoor Environment and Energy, Department of Civil Engineering, Technical University of Denmark in Lyngby, Denmark.

# Resources on Filtration

- Follow the field trial at [www.Av8rdas.Wordpress.com](http://www.Av8rdas.Wordpress.com) (starts in a September 2009 post)
- NCBC 2015 Presentation [\*Leveraging Filter Technology and Life Cycle Cost Based Filter Operation\*](#) (linked from my blog)
- The Art and Science of Air Filtration in Health Care
  - [HPAC - October 1998](#)
- Filtration: An Investment in IAQ
  - [HPAC - August 1997](#)
- Specifying Filters
  - [HPAC - November 2003](#)
  - [All by H.E. Barney Burroughs](#)
- National Air Filtration Association (NAFA)
  - <http://www.nafahq.org/>
  - [\*Using Extended Surface Air Filters in Heating Ventilation and Air Conditioning Systems: Reducing Utility and Maintenance Costs while Benefiting the Environment\*, by Michael J. Chimack et.al., ACEEE 2000 Proceedings](#)