

# Fans, Ducts and Air Handling Systems: Design, Performance and Commissioning Issues

## Fans



**Instructor:**


David Sellers

Senior Engineer

Facility Dynamics Engineering

November 7, 2017






Fan Fundamentals;  
(Very Similar to Pump Fundamentals)



# Centrifugal Fan Operation


*Spin the wheel ...*



*... and air is thrown  
from the center to the  
perimeter*

# Centrifugal Fan Operation

*Adding a scroll ...*



*... collects and  
distributes the air  
and recovers  
some of the  
velocity pressure*



# Common HVAC Fan Types

## Centrifugal

- Pressure created by:
  - Centrifugal force
  - Velocity added at the impeller
- Single Width/Single Inlet (SWSI)

# Common HVAC Fan Types

## Centrifugal

- Pressure created by:
  - Centrifugal force
  - Velocity added at the impeller
- Single Width/Single Inlet (SWSI)
- Double Width/Double Inlet (DWDI)





# Common HVAC Fan Types



## Centrifugal

- Pressure created by:
  - Centrifugal force
  - Velocity added at the impeller
- Single Width/Single Inlet (SWSI)
- Double Width/Double Inlet (DWDI)
- Plenum or Plug



# Common HVAC Fan Types



## Centrifugal

- Pressure created by:
  - Centrifugal force
  - Velocity added at the impeller
- Single Width/Single Inlet (SWSI)
- Double Width/Double Inlet (DWDI)
- Plenum or Plug
- Axial




# Common HVAC Fan Types

## Centrifugal

- Pressure created by:
  - Centrifugal force
  - Velocity added at the impeller
- Single Width/Single Inlet (SWSI)
- Double Width/Double Inlet (DWDI)
- Plenum or Plug
- Axial




# Fan Terminology

























## Airfoil Fan Wheel Characteristics:




## Backward Inclined Fan Wheel Characteristics:






## Forward Curved Wheel Characteristics:



## Forward Curved Wheel Characteristics:


Increasing Static, Efficiency and Power ↑






## Vane Axial Fan Characteristics:

See the ASHRAE Systems and Equipment Handbook Table 1 and the ASHRAE Pocket Guide pages 12 and 13 and the Buffalo Fan Engineering Manual for more information




Images courtesy of NASA; [http://www.nasa.gov/centers/langley/images/content/221601main\\_image-0222-2008\\_full.jpg](http://www.nasa.gov/centers/langley/images/content/221601main_image-0222-2008_full.jpg)





# Fan Efficiency




# A Field Issue Affecting Fan Efficiency

## **RADIAL GAP, OVERLAP & WHEEL ALIGNMENT**


Efficient fan performance can be maintained by having the correct radial gap, overlap and wheel alignment. These items should be checked after the fan has been in operation for 24 hours and before start-up when the unit has been disassembled. Radial gap and overlap information applies to models: BISW, AFSW, BIDW, AFDW, PLN, and PLG.

**Inlet Cone to Backplate Distance**  
(inches)

Unit Size	A dim.	± Tolerance
7 - 10	3 5/8	± 1/8
12	4	± 1/8
13	4 7/16	± 1/8
15	5	± 1/8
16	5 7/16	± 1/8
18	6 3/8	± 1/8
20	7	± 3/16
22	7 13/16	± 3/16
24	8 5/8	± 1/4
27	9 7/16	± 1/4
30	10 9/16	± 3/8
33	11 7/16	± 3/8
36	12 3/4	± 3/8
40	14 3/16	± 3/8
44	15 9/16	± 3/8
49	17 1/8	± 1/2
54	18 13/16	± 1/2
60	20 15/16	± 1/2
66	22 7/8	± 1/2
73	25 1/2	± 1/2



BISW, AFSW, PLN, PLG




BIDW, AFDW

### **RADIAL GAP**

Radial gap is adjusted by loosening the inlet cone/ring bolts and centering the cone/ring on the wheel. If additional adjustment is required to maintain a constant radial gap, loosening the bearing bolts and centering wheel is acceptable as a secondary option.

### **OVERLAP**

Overlap is adjusted by loosening the wheel hub from the shaft and moving the wheel to the desired position along the shaft. The Inlet Cone to Backplate Distance chart lists the distance between the wheel and the inlet cone spacing for non-double width fans. Overlap on double width fans is set by having equal spacing on each side of the wheel.



Images courtesy of Greenheck (left) and ASHRAE 2008 Handbook of Systems and Equipment, Chapter 20 (right)



Image courtesy Bill Michell – DOE – NY Marriott Marquee

# Inlet Cones, Inlet Vanes, and VFD Retrofits





Image courtesy Bill Michell – DOE – NY Marriott Marquee

# Inlet Vanes are Supported by Inlet Cones



08/10/2006

Image courtesy Bill Michell – DOE – NY Marriott Marquee



Image courtesy Bill Michell – DOE – NY Marriott Marquee

# Adding VFDs?

Remove the Vanes, Leave the Cone!



# DW Airfoil

Selected Fans

Cataloged

Fan Details

Sound Details

Octave Bands

Type	Size	Cl.	% dia	% wid	% peak	Drive	RPM	Max RPM	Std. BHP	Op. BHP	OV	S.E.	M.E.	In.LwA	Out.LwA	\$\$
BAE-DW	182	I	100	100	93.50	BD	1371	2248	2.07	2.07	1449	75.89	80.85	82	83	1.00
BAE-DW	165	I	100	100	72.49	BD	1793	2761	2.47	2.47	1773	63.54	69.76	87	88	0.93
BAE-DW	150	I	100	100	49.49	BD	2298	3232	2.85	2.85	2146	55.15	63.06	90	91	0.85
BAE-DW	135	I	100	100	45.87	BD	2755	3374	3.11	3.11	2646	50.49	61.51	91	93	0.79

Reports

Curves

AMCA Stmt



## DW Backward Inclined Wheel

Selected Fans																
Cataloged																
Fan Details	Type	Size	Cl.	% dia	% wid	% peak	Drive	RPM	Max RPM	Std. BHP	Op. BHP	OV	S.E.	M.E.	In.LwA	Out.LwA
Sound Details	BAE-DW	182	I	100	100	93.50	BD	1371	2248	2.07	2.07	1449	75.89	80.85	82	83
Octave Bands	BC-DW	200	I	100	100	92.86	BD	1160	1961	2.30	2.30	1208	68.27	71.38	88	N/A
	BC-DW	182	I	100	100	83.83	BD	1338	2149	2.36	2.36	1449	66.69	71.05	89	N/A
	BAE-DW	165	I	100	100	72.49	BD	1793	2761	2.47	2.47	1773	63.54	69.76	87	88
	BC-DW	165	I	100	100	72.61	BD	1595	2358	2.63	2.63	1773	59.66	65.50	89	N/A
	BAE-DW	150	I	100	100	49.49	BD	2298	3232	2.85	2.85	2146	55.15	63.06	90	91
	BC-DW	150	I	100	100	60.75	BD	1918	2594	2.90	2.90	2146	54.26	62.05	91	N/A
	BAE-DW	135	I	100	100	45.87	BD	2755	3374	3.11	3.11	2646	50.49	61.51	91	93



33-AFDW-41


Fan Performance Chart: Operating Conditions

# Fan Performance Presentation

Volume (CFM): 23,000  
SP (in wg): 5.1  
Power (hp): 25.36  
1,178

Air Density (lb/ft<sup>3</sup>): 0.075  
Drive Loss (%): 3  
Elevation (ft): 0  
Air Stream Temp. (F): 70

Inlet Sound Data											Outlet Sound Data										
62.5	125	250	500	1000	2000	4000	8000	LwA	dBA	Sones	62.5	125	250	500	1000	2000	4000	8000	LwA	dBA	Sones
100	97	97	90	88	85	81	78	94	83	42	102	98	95	89	87	82	78	76	92	81	39







## 33-AFDW-41

### Fan Performance Chart: RPM Family


Volume (CFM):	23,000	Air Density (lb/ft <sup>3</sup> ):	0.075
SP (in wg):	5.1	Drive Loss (%):	3
Power (hp):	25.36	Elevation (ft):	0
FRPM:	1,178	Air Stream Temp. (F):	70

#### Inlet Sound Data

62.5	125	250	500	1000	2000	4000	8000	LwA	dBA	Sones
100	97	97	90	88	85	81	78	94	83	42

#### Outlet Sound Data



62.5	125	250	500	1000	2000	4000	8000	LwA	dBA	Sones
102	98	95	89	87	82	78	76	92	81	39



# Fan Performance Presentation

There is a difference between the applied fan curve and the fan curve

Some manufacturers document this







System Flow Rates are Generally Set by  
the Loads Served

A wide-angle photograph of a large industrial facility, likely a water treatment plant. The room has a high ceiling with a complex network of yellow cables or hoses. The floor is made of light-colored square tiles. Several large, rectangular, dark-colored tanks or basins are arranged in rows. A red and yellow scissor lift is positioned in the center of the room. In the background, there are more tanks and some equipment. The overall lighting is bright and even.

System Flow Rates are Generally Set by  
the Loads Served






System Flow Rates are Generally Set by  
the Loads Served

## Pacific Energy Center Main Classroom - Design Load

Baseline; Full Class, Scheduled, Medium Construction, Light Walls, SE Exposure; Shades Open; 2% Cooling Design Condition (High 74°F, Low 57°F), Space - 70°F

# The Loads Can Be Quite Variable






# Static Requirements are Set by Geometry

Fabrication details versus as designed details can make a difference


- Design – 25° mitered offset
  - $C_0 - 0.11$
  - Loss – 0.05 in.w.c.
- Fabrication – 45° mitered offset
  - $C_0 - 0.31$
  - Loss – 0.14 in.w.c.




# Static Requirements are Set by Geometry

Fabrication details versus as designed details can make a difference

- Design – single thickness turning vanes
  - $C_0 - 0.11$
  - Loss – 0.05 in.w.c.
- Fabrication – double thickness turning vanes
  - $C_0 - 0.25$
  - Loss – 0.10 in.w.c.









# The AHU8 Supply Duct Some Perspective

Plotted to scale from the fan discharge (A) to the terminal unit inlet at the most remote terminal unit (C)

40% of the static pressure is used up between the discharge (A) and the mechanical shaft point of entry (B).





## Given:

The fan curve in the next slide

A measured fan speed of 1,411 rpm

A measured flow rate of 30,000 cfm

## Determine:

The fan static pressure

The fan class

The fan brake horsepower

The system curve

The speed required to produce 28,000 cfm and the operating conditions at that speed

What would happen if you throttled to 28,000 cfm instead of reducing fan speed?

Could you speed the fan up and obtain 35,000 cfm?



# 33-AFDW-41

## Fan Performance Chart: RPM Family


Volume (CFM):	23,000	Air Density (lb/ft <sup>3</sup> ):	0.075
SP (in wg):	5.1	Drive Loss (%):	3
Power (hp):	25.36	Elevation (ft):	0
FRPM:	1,178	Air Stream Temp. (F):	70

### Inlet Sound Data

62.5	125	250	500	1000	2000	4000	8000	LwA	dBA	Sones
100	97	97	90	88	85	81	78	94	83	42

### Outlet Sound Data

62.5	125	250	500	1000	2000	4000	8000	LwA	dBA	Sones
102	98	95	89	87	82	78	76	92	81	39







# 33-AFDW-41

## Fan Performance Chart: RPM Family


Volume (CFM):	23,000	Air Density (lb/ft <sup>3</sup> ):	0.075
SP (in wg):	5.1	Drive Loss (%):	3
Power (hp):	25.36	Elevation (ft):	0
FRPM:	1,178	Air Stream Temp. (F):	70

### Inlet Sound Data

62.5	125	250	500	1000	2000	4000	8000	LwA	dBA	Sones
100	97	97	90	88	85	81	78	94	83	42

### Outlet Sound Data

62.5	125	250	500	1000	2000	4000	8000	LwA	dBA	Sones
102	98	95	89	87	82	78	76	92	81	39





## 33-AFDW-41

### Fan Performance Chart: RPM Family


Volume (CFM):	23,000	Air Density (lb/ft <sup>3</sup> ):	0.075
SP (in wg):	5.1	Drive Loss (%):	3
Power (hp):	25.36	Elevation (ft):	0
FRPM:	1,178	Air Stream Temp. (F):	70

#### Inlet Sound Data

62.5	125	250	500	1000	2000	4000	8000	LwA	dBA	Sones
100	97	97	90	88	85	81	78	94	83	42

#### Outlet Sound Data

62.5	125	250	500	1000	2000	4000	8000	LwA	dBA	Sones
102	98	95	89	87	82	78	76	92	81	39







# 33-AFDW-41

## Fan Performance Chart: RPM Family


Volume (CFM):	23,000	Air Density (lb/ft <sup>3</sup> ):	0.075
SP (in wg):	5.1	Drive Loss (%):	3
Power (hp):	25.36	Elevation (ft):	0
FRPM:	1,178	Air Stream Temp. (F):	70

### Inlet Sound Data

62.5	125	250	500	1000	2000	4000	8000	LwA	dBA	Sones
100	97	97	90	88	85	81	78	94	83	42

### Outlet Sound Data

62.5	125	250	500	1000	2000	4000	8000	LwA	dBA	Sones
102	98	95	89	87	82	78	76	92	81	39





# 33-AFDW-41

## Fan Performance Chart: RPM Family


Volume (CFM):	23,000	Air Density (lb/ft <sup>3</sup> ):	0.075
SP (in wg):	5.1	Drive Loss (%):	3
Power (hp):	25.36	Elevation (ft):	0
FRPM:	1,178	Air Stream Temp. (F):	70

### Inlet Sound Data

62.5	125	250	500	1000	2000	4000	8000	LwA	dBA	Sones
100	97	97	90	88	85	81	78	94	83	42

### Outlet Sound Data

62.5	125	250	500	1000	2000	4000	8000	LwA	dBA	Sones
102	98	95	89	87	82	78	76	92	81	39



## Discussion Point

- *Do VAV systems operating on a single fan curve?*
- *Where is the origin of the fan curve for a VAV system.*





## 33-AFDW-41

### Fan Performance Chart: RPM Family


Volume (CFM):	23,000	Air Density (lb/ft <sup>3</sup> ):	0.075
SP (in wg):	5.1	Drive Loss (%):	3
Power (hp):	25.36	Elevation (ft):	0
FRPM:	1,178	Air Stream Temp. (F):	70

#### Inlet Sound Data

62.5	125	250	500	1000	2000	4000	8000	LwA	dBA	Sones
100	97	97	90	88	85	81	78	94	83	42

#### Outlet Sound Data

62.5	125	250	500	1000	2000	4000	8000	LwA	dBA	Sones
102	98	95	89	87	82	78	76	92	81	39





## 33-AFDW-41

### Fan Performance Chart: RPM Family

Volume (CFM):	23,000	Air Density (lb/ft <sup>3</sup> ):	0.075
SP (in wg):	5.1	Drive Loss (%):	3
Power (hp):	25.36	Elevation (ft):	0
FRPM:	1,178	Air Stream Temp. (F):	70

#### Inlet Sound Data

62.5	125	250	500	1000	2000	4000	8000	LwA	dBA	Sones
100	97	97	90	88	85	81	78	94	83	42

#### Outlet Sound Data


62.5	125	250	500	1000	2000	4000	8000	LwA	dBA	Sones
102	98	98	91	89	86	82	79	95	84	39

Increasing the fan speed:

- Exceeds the Class II maximum speed
- Requires 68 bhp; a 17% increase in flow required a 51% increase in power

The new bhp requirement can be assessed using the fan affinity law relating bhp and fan speed:

$$HP_{New} = HP_{Old} \times (RPM_{New}/RPM_{Old})^3$$




# Fan Operating Limits

Fan wheels have structural limits

*“.. must be physically capable of operating safely at every point of rating on or below the minimum performance limit ...”*

- Class I – Class IV (minimum to maximum rating)
- Result in a maximum speed rating for each class





# This Is What Can Happen If You Over-speed A Fan




Image courtesy of  
Jim Bochat of Pro  
Services


These blades should be straight

*The fan had been  
running about 1,000  
rpm over the maximum  
speed limit for its fan  
class.*

# This Is What Can Happen If You Over-speed A Fan



# This Project Was Lucky



The wheel did not disintegrate

The collapse was so uniform the wheel remained in balance

The problem was discovered before stress cracks cause the wheel to fail



# Given the Following Information

- Flow - 25,000 cfm
- Inlet static pressure – negative 1.9 in.w.c.
- Discharge static pressure - 4.1 in.w.c.
- Fan speed – 1,411 rpm
- Volts – 463
- Amps – 42

*Where do you think the fan is operating and why?*




## 33-AFDW-41

### Fan Performance Chart: RPM Family

Volume (CFM): 23,000 Air Density (lb/ft<sup>3</sup>): 0.075  
 SP (in wg): 5.1 Drive Loss (%): 3  
 Power (hp): 25.36 Elevation (ft): 0  
 FRPM: 1,178 Air Stream Temp. (F): 70

Inlet Sound Data											Outlet Sound Data										
62.5	125	250	500	1000	2000	4000	8000	LwA	dBA	Sones	62.5	125	250	500	1000	2000	4000	8000	LwA	dBA	Sones
100	97	97	90	88	85	81	78	94	83	42	102	98	95	89	87	82	78	76	92	81	39



CAPS 3.1.2.3



# 33-AFDW-41

## Fan Performance Chart: RPM Family


Volume (CFM):	23,000	Air Density (lb/ft <sup>3</sup> ):	0.075
SP (in wg):	5.1	Drive Loss (%):	3
Power (hp):	25.36	Elevation (ft):	0
FRPM:	1,178	Air Stream Temp. (F):	70

### Inlet Sound Data

62.5	125	250	500	1000	2000	4000	8000	LwA	dBA	Sones
100	97	97	90	88	85	81	78	94	83	42

### Outlet Sound Data

62.5	125	250	500	1000	2000	4000	8000	LwA	dBA	Sones
102	98	95	89	87	82	78	76	92	81	39





## 33-AFDW-41

### Fan Performance Chart: RPM Family


Volume (CFM):	23,000	Air Density (lb/ft <sup>3</sup> ):	0.075
SP (in wg):	5.1	Drive Loss (%):	3
Power (hp):	25.36	Elevation (ft):	0
FRPM:	1,178	Air Stream Temp. (F):	70

#### Inlet Sound Data

62.5	125	250	500	1000	2000	4000	8000	LwA	dBA	Sones
100	97	97	90	88	85	81	78	94	83	42

#### Outlet Sound Data

62.5	125	250	500	1000	2000	4000	8000	LwA	dBA	Sones
102	98	95	89	87	82	78	76	92	81	39







## 33-AFDW-41

### Fan Performance Chart: RPM Family


Volume (CFM):	23,000	Air Density (lb/ft <sup>3</sup> ):	0.075
SP (in wg):	5.1	Drive Loss (%):	3
Power (hp):	25.36	Elevation (ft):	0
FRPM:	1,178	Air Stream Temp. (F):	70

#### Inlet Sound Data


62.5	125	250	500	1000	2000	4000	8000	LwA	dBA	Sones
100	97	97	90	88	85	81	78	94	83	42

#### Outlet Sound Data

62.5	125	250	500	1000	2000	4000	8000	LwA	dBA	Sones
102	98	95	89	87	82	78	76	92	81	39



# Fan Static Pressure




$$P_{\text{total}} = P_{\text{total out}} - P_{\text{total in}}$$

$$P_{\text{static}} = P_{\text{total}} - P_{\text{velocity in}}$$


- Derived from the AMCA test method
  - Gauge static at 100% effective duct length corrected to discharge
  - Fan draws air from surroundings through a well shaped inlet

$$P_{\text{static}} = P_{\text{static out}} - P_{\text{total in}}$$





# Varying Fan Volume




## Single Zone Technique

- Modulate based on zone temperature

## Multiple Zones

- Zones modulate based on temperature
- Fixed pressure may be maintained at some point in the system

# Varying Fan Volume




## Single Zone Technique


- Modulate based on zone temperature

## Multiple Zones


- Zones modulate based on temperature
- Fixed pressure may be maintained at some point in the system
- Fan follows the total zone flow requirement
- Work on a family of system curves







## Varying Fan Volume



### Inlet Guide Vanes

- Direct the flow into the fan wheel imparting “swirl”
- Changes the shape of the surge line
- Droops the fan curve
- Tend to follow the system curve
- May be integral to the fan’s peak efficiency point

# Inlet Guide Vanes; Directing Airflow into the Fan Wheel





# Inlet Guide Vanes; Directing Airflow into the Fan Wheel





# Inlet Guide Vanes; Directing Airflow into the Fan Wheel





# Inlet Guide Vanes; Directing Airflow into the Fan Wheel





Inlet Guide Vanes; Should You Remove Them if you Retrofit a VSD?





# Inlet Guide Vanes; Should You Remove Them if you Retrofit a VSD?

“It Depends”

Jay Santos

See *Inlet Guide Vanes (IGVs) and Variable Speed Drives(VSDs)* at <http://av8rdas.wordpress.com/> for more information




Adding VFDs?  
Remove the Vanes (Maybe),  
Leave the Inlet Cone (For Sure)

08/10/2006



# Varying Fan Volume





## Varying Speed

Traditional balancing approach  
Family of similar shaped operating curves

Tends to preserve the efficiency at the original operating point

- Tend to follow the system curve



**TWO STAGE CONTROLLABLE PITCH FAN****ITEM NUMBERS**

- 1) CASING ASSEMBLY
- 2) FAN SUPPORT
- 3) SUPPORT BRACE
- 4) SUPPORT MTG. HARDWARE
- 5) ELECTRIC MOTOR
- 6) MOTOR MOUNTING HARDWARE
- 7) ROTOR ASSEMBLY (FIRST STAGE)
- 8) ROTOR ASSEMBLY (SECOND STAGE)
- 9) INLET BELL
- 10) INLET BELL MTG. HARDWARE
- 11) ALUMINUM NOSE
- 12) NOSE MTG. HARDWARE
- 13) INLET SCREEN GUARD
- 14) SCREEN GUARD CLIP
- 15) CONDUIT BOX KIT PARTS
- 16) MAIN CONDUIT PIPE
- 17) MOTOR GREASE LEADS
- 18) ADJ. MECHANISM (FIRST STAGE)
- 19) ADJ. MECHANISM GREASE LEAD (FIRST STAGE)
- 20) ADJ. MECHANISM (SECOND STAGE)
- 21) ADJ. MECHANISM GREASE LEAD (SECOND STAGE)
- 22) ROTOR NUT AND LOCKWASHER (FIRST STAGE)
- 23) ROTOR NUT AND LOCKWASHER (SECOND STAGE)
- 24) LEVER BAR (FIRST STAGE)
- 25) LINKAGE (ACTUATOR/LEVER BAR)
- 26) ACTUATOR
- 27) LEVER BAR (SECOND STAGE)
- 28) MOTOR FRAME SUPPORT HARDWARE
- 29) REAR VANE ASSEMBLY
- 30) BOOT AND PLATE ASSEMBLY (TOP)
- 31) BOOT AND PLATE ASSEMBLY (BOTTOM)

Image courtesy AVA HVAC Products

[http://avahvacproducts.com/Joy\\_Fan\\_Service\\_Parts.html](http://avahvacproducts.com/Joy_Fan_Service_Parts.html)



JO14C

**CONTROLLABLE PITCH ROTOR ASSY**  
**17 $\frac{1}{2}$ " , 21" AND 26 $\frac{1}{2}$ " HUB**  
**ORDERING REPAIR PARTS**

- \* GIVE FAN MODEL
- \* GIVE FAN SERIAL NUMBER
- \* GIVE FAN ITEM NUMBER

**ITEM NUMBERS**

- 1) C.P. BLADE
- 2) TEFLON WASHER
- 3) BUSHING
- 4) 26-1/2" HUB
- 5) HUB INSERT
- 6) SPACER
- 7) THRUST WASHER
- 8) BUTTON HEAD CAP SCREW
- 9) FLAT WASHER
- 10) LOCK NUT
- 11) CLAMP
- 12) WASHER
- 13) NUT
- 14) SUPPORT WASHER
- 15) ROLLER
- 16) SOCKET HEAD SHOULDER SCREW
- 17) INSERT LOCK RING
- 18) HEX SOCKET HEADLESS SET SCREW

NEW PHILADELPHIA FAN COMPANY




Image courtesy AVA HVAC Products  
[http://avahvacproducts.com/Joy\\_Fan\\_Service\\_Parts.html](http://avahvacproducts.com/Joy_Fan_Service_Parts.html)












FANS


# Power Consumption Comparison

Source:  
Howden Buffalo  
*Fan Engineering*  
9<sup>th</sup> Edition




# Power Consumption Comparison

Greenheck's Dampers for Centrifugal Fans Bulletin also Contains Curves in % of Flow/Static/HP Metrics





# Plenum/Plug Fans Solve Space Problems



# Plenum/Plug Fans Don't Have the Scroll





# SWSI Fans Do

(SWSI = Single Width Single Inlet)






So Do DWDI Fans  
(DWDI = Double Width Double Inlet)



# Integration of the Fan with the Duct System Also Impacts Efficiency

Fitting placement  
and/or lack of a  
discharge duct  
has the same  
effect as adding  
static pressure



*System effect assessed at 2,500 fpm and an outlet  
area to blast area ratio of 70%*

# Past Experience with Fan Selections

All other things being equal a SWDI or DWDI fan will be 5-10% more efficient than a plenum fan for the same operating conditions


The improved efficiency gained by a SWDI or DWDI fan can be squandered in losses at the inlet and discharge if system effect is not considered




# DD Phase Air Handling Equipment

Air handling units incorporate multiple plenum fans

Ducts leave the unit in multiple directions



PLAN VIEW





ELEVATION VIEW

# DD Phase Air Handling Equipment

Air handling units incorporate multiple plenum fans

Ducts leave the unit in multiple directions

Mechanical spaces are constrained **vertically** but not so much **horizontally**



# DD Phase Air Handling Equipment

Air handling units incorporate multiple plenum fans

Ducts leave the unit in multiple directions

Mechanical spaces are constrained vertically but not so much horizontally

Brake horse power requirements imply fan efficiencies in the range of 68-71%

TYPE	EQUIPMENT LOCATION	AREA SERVED	SUP					
			CFM	TOTAL S.P. IN W.C.	EXT S.P. IN W.C.	Motor RPM	FAN QTY	BHP PER FAN
AHU-AX-01	PENTHOUSE	POD/OFFICE	11,000	6.03	4.0	1,800	2	7.66
AHU-AX-02	PENTHOUSE	POD/OFFICE	22,000	6.01	4.0	1,800	3	9.81
AHU-AX-03	PENTHOUSE	ENTRANCES	20,000	6.31	4.0	1,800	3	9.49
AHU-AX-04	PENTHOUSE	ENTRANCES	20,000	6.31	4.0	1,800	3	9.49
AHU-AX-05	PENTHOUSE	ENTRANCES	12,500	5.15	3.5	1,800	2	7.45
AHU-AX-06	PENTHOUSE	ENTRANCES	10,000	5.17	3.5	1,800	2	6.00
AHU-AX-09	PENTHOUSE	MINI ENTRANCE	4,000	3.52	2.0	1,800	1	3.25
AHU-AX-10	PENTHOUSE	MINI ENTRANCE	7,000	5.87	4.0	1,800	2	5.00
AHU-AX-11	PENTHOUSE	BATHROOMS	5,500	3.49	2.0	1,800	1	4.30
AHU-AX-12	PENTHOUSE	BATHROOMS	4,500	3.59	2.0	1,800	1	3.72

$$\eta_{Fan} = \left( \frac{Flow \times Static}{6,356 \times bhp} \right)$$

Where :

bhp = Brake horse power into the fan drive shaft

Flow = Flow rate in cubic feet per minute

Static = Fan static in inches water column

6,356 = A units conversion constant

$\eta_{Fan}$  = Fan efficiency



# DD Phase Air Handling Equipment

Air handling units incorporate multiple plenum fans

Ducts leave the unit in multiple directions

Mechanical spaces are constrained **vertically** but not so much **horizontally**

Brake horse power requirements imply fan efficiencies in the range of 68-71%

Twin City Blower SWSI fan selections indicate a 8-11% potential efficiency improvement

Type	Size	CL	% dia	% wid	% peak	Drive	RPM	Max RPM	Std. BH	Op. BHP	OV	S.E.	E.	LWA	\$S
BAE-SW	200	I	100	100	89.12	BD	2145	2627	6.7	6.74	2391	77.36	1.93	89	1.00
BAE-SW	182	I	100	100	78.10	BD	2511	2879	6.9	6.96	2865	74.88	1.23	90	0.91
BAE-SW	165	I	100	100	63.06	BD	3345	3487	8.1	8.11	3503	64.26	2.41	97	0.87

Op. BHP	OV	S.E.	M.E.
6.74	2391	77.36	81.93
6.96	2865	74.88	81.23
8.11	3503	64.26	72.41

Type	Size	CL	% dia	% wid	% peak	Drive	RPM	Max RPM	Std. BH	Op. BHP	OV	S.E.	E.	LWA	\$S
BAE-SW	300	I	100	100	93.55	BD	1383	1731	13.0	13.04	2128	79.69	3.43	89	1.00
BAE-SW	270	I	100	100	83.45	BD	1627	1923	13.0	13.09	2625	79.39	5.06	92	0.85
BAE-SW	245	I	100	100	72.53	BD	1956	2149	14.4	14.44	3188	71.95	9.54	93	0.75
BAE-SW	222	I	100	100	58.90	BD	2390	2982	16.0	16.01	3860	64.89	4.92	96	0.89

Op. BHP	OV	S.E.	M.E.
13.04	2128	79.69	83.43
13.09	2625	79.39	85.06
14.44	3188	71.95	79.54
16.01	3860	64.89	74.92

# DD Phase Air Handling Equipment

Air handling units incorporate multiple plenum fans

Ducts leave the unit in multiple directions

Mechanical spaces are constrained vertically but not so much horizontally

Brake horse power requirements imply fan efficiencies in the range of 68-71%

Twin City Blower SWSI fan selections indicate a 8-11% potential efficiency improvement

The potential benefits


- 8-11% lower fan energy
- 8-11% lower operating cost
- Potential first cost improvements
  - Smaller motors
  - Smaller variable speed drives
  - Smaller electrical distribution equipment


The question


*Can SWSI fans be applied in a way that allows them to fit with out compromising their discharge conditions?*


















Supply Ducts

## Outdoor Air Ducts



Mixing Box  
(Economizer/Free  
Cooling Section)






Filters

FANS

Plenum with Bypass  
Damper



Preheat Coils


FANS





A 3D perspective diagram of a mechanical room. In the center, there is a large, light gray rectangular coil. To its left, a series of smaller, similar coils are arranged in a row. A red line is drawn along the top edge of these smaller coils, indicating a path. The floor is a dark gray, and the walls are light gray. A concrete curb runs along the front of the coils. The text "Access Between Coils" is positioned to the left of the main coil.


Access Between  
Coils



Cooling Coils

FANS

101




A 3D architectural rendering of a mechanical room. The room features a large, light gray rectangular unit, likely a fan or filter, with a red rectangular area on its top surface. This red area is labeled 'Plenum for Bypass Connection'. The unit is situated on a dark gray floor. In the background, there are other mechanical components, including a dark gray rectangular structure and a light gray structure with a sloped top. A light gray horizontal band is visible at the top of the image.


Plenum for Bypass  
Connection



Complete Mixed Air  
Bypass System



Complete Mixed Air  
Bypass System








A 3D architectural rendering of a fan compartment. The structure is composed of several rectangular blocks. A central block is highlighted in red, while the others are light gray. The blocks are arranged in a row, with the red block in the middle. The entire structure sits on a dark gray base. A light gray horizontal band is visible in the background. The text 'Fan Compartment' is overlaid on the left side of the image.

Fan Compartment



Fan Discharge  
Plenum




A 3D perspective diagram showing a supply plenum system. On the left, a grey rectangular duct labeled "Supply Plenum" leads into a larger, light grey rectangular box. This box is part of a series of similar units, with a red line indicating a connection or flow path. To the right of this main unit is a smaller, dark grey rectangular box. The entire assembly is situated on a light grey floor, with a white wall and ceiling in the background.

Supply Plenum




## Option 1 – Two SWSI Bottom Angle Discharge Fans



Unit elevation remains the same as the current design


## Option 1 – Two SWSI Bottom Angle Discharge Fans



Unit elevation remains the same as the current design

Coil discharge plenum extended to ensure no water carry over and good fan entry conditions

## Option 1 – Two SWSI Bottom Angle Discharge Fans



Unit elevation remains the same as the current design


Coil discharge plenum extended to ensure no water carry over and good fan entry conditions

Overall length is shorter than the original design

- Fits original foot print
- Potential first cost reduction due to smaller casing




## Option 1 – Two SWSI Bottom Angle Discharge Fans



Supply duct reconfigured on one side relative to the original design to ensure good discharge conditions


- Modest if any budget impact at the current level of cost projection
- May require some coordination with a VAV near the elbow

## Option 2 – Two SWSI Bottom Horizontal Discharge Fans



Unit elevation dropped to sit on top of the structural support rails

## Option 2 – Two SWSI Bottom Horizontal Discharge Fans




Unit elevation dropped to sit on top of the structural support rails

- Provides for improved fan discharge conditions, further improving efficiency




## Option 2 – Two SWSI Bottom Horizontal Discharge Fans



Unit elevation dropped to sit on top of the structural support rails


- Provides for improved fan discharge conditions, further improving efficiency
- Bypass section moves to the top of the unit
- Lower center of gravity = reduces seismic load

## Option 2 – Two SWSI Bottom Horizontal Discharge Fans




Unit elevation dropped to sit on top of the structural support rails

- Provides for improved fan discharge conditions, further improving efficiency
- Bypass section moves to the top of the unit
- Lower center of gravity = reduces seismic load
- Modest impact on OA duct




Arr. 1 SI

For belt drive or direct connection. Impeller overhung. Two bearings on base.




Arr. 2 SI

For belt drive or direct connection. Impeller overhung. Bearings in bracket supported by fan housing.




Arr. 3 SI or DI

For belt drive or direct connection. One bearing on each side supported by fan housing or on independent pedestals.




Arr. 4 SI

For direct drive. Impeller overhung on motor shaft. No bearings on fan. Motor mounted on base or supported by fan housing.




Arr. 7 SI or DI

For belt drive or direct connection. Arrangement 3 plus base for motor.




Arr. 8 SI

For belt drive or direct connection. Arrangement 1 plus extended base for motor.



Arr. 9 SI

For belt drive. Impeller overhung, two bearings, with motor outside base.




Arr. 10 SI

For belt drive. Impeller overhung, two bearings, with motor inside base.

Drive and Motor Locations Would Need to be Coordinated with Available Space






SWSI Fan Motors Would Likely Be Out of the Air Stream, Eliminating a Parasitic Load Some of the time Since Motor Heat Ends Up in the Return/Relief Air Stream

**Figure 9.7 Standard Motor Positions**

Adapted from the data of AMCA: "Motor Positions for Belt or Chain Drive Centrifugal Fans," AMCA Standard 2407-98, 1998.

# Assessing Fan Energy Potential Savings

- Assume an average flow profile based on past data and ASHRAE handbook metrics
- Original fan efficiency based on the current air handling unit schedule
- New fan efficiency based on 2<sup>nd</sup> best fan selection for a SWSI fan operating at the same conditions
- Assume system static requirement follows the “square law”
- Capture motor efficiency vs. load from US Motor performance curves
- Assume well adjusted and maintain belts (98% efficient)
- Assume VFD efficiency losses are a flat number that will not vary significantly from one case to the other (94.3% based on DOE/Safetronics data for current technology drives)





# Fan Energy Savings Projection Results


## AHU 2 System Type, 8 Similar Building Modules

AHU System Type Fan Energy Savings


	Weekday -	143	kWh						
	Weekend -	19	kWh						
	Total for a week -	162	kWh						
		Low End	High End						
	Total for a year -	7,587	8,430	kWh					
	Assumed electric rate -	\$0.1000	\$0.1500	per kWh					
	Annual savings potential -	\$759	\$1,265	per system					
	AHU 2 Systems per wedge -	7	7						
	Savings per wedge -	\$5,311	\$8,852						
	Number of wedges -	8	8						
	Total savings for AHU2 system type -	\$42,488	\$70,814						

## But Wait, There's More!

*Fan energy shows up as a temperature rise across the fan due to the work the fan is doing on the air; a phenomenon identified by Willis Carrier and termed “fan heat”*



# But Wait, There's More



*The energy associated with handling the fan heat ripples back through the central plant and is compounded by the various equipment inefficiencies*



# Fan Heat Savings Projection Results

## AHU 2 System Type, 8 Similar Building Modules

### AHU 2 Fan Heat Savings

Fan heat saved for the year -	7,155	kWh (Based on fan energy savings with out the VFD losses since the VFD is not in the supply air stream, just the return air stream and the losses will go out with the relief air a lot of the time)		
	24,419,027	Btu		
Derate the savings potential by the number of hours when the systems would not be operating on an economizer cycle				
Hours per year -	8,760			
Hours per year when on economizer cycle -	6,473	2009 - 2012 average from climate analysis spreadsheet		<a href="#">Natural Ventilation v2.xlsx</a>
AHU 2 design LAT -	51.5	°F (from fan schedule)		
Assumed drybulb based economizer change-over temperature -	70	°F (Engineering judgement based on Bay Area experience)		
Hours per year above 51.5 °F -	2,808	Hours when the system would have been driven to 100% outdoor air, from bin data, 9 am to 5 pm bin only		
Hours per year above 70 °F -	822	Hours when the system would have been returned to MOA, from bin data, 9 am to 5 pm bin only		
Hours per year below 51.5 °F -	113	Hours when the system be on less than 100% OA using the economizer process, from bin data, 9 am to 5 pm bin only		
Hours per year on 100% outdoor air -	1,986	Hours when motor heat would go out the relief system		
Hours per year when air is recirculated -	935	(fan and motor heat are a chilled water or economizer load)		
Total hours in 9 am to 5 pm bin -	2,921			
% of hours with recirculation and chilled water cooling -	822	(hours when fan heat shows up as a coil load)		
	28%			
Derated fan heat -	6,871,770	Btu		
-	573	Ton-hours		
Plant over-all kW per ton -	0.85	1.00		
Annual kWh savings from reduced fan heat -	487	573	per system	
Annual \$ savings from reduced fan heat -	\$49	\$86	per system	
AHU 2 Systems per wedge -	7	7		
Savings per wedge -	\$341	\$601		
Number of wedges -	8	8		
Total savings for AHU2 system type -	\$2,726	\$4,810		

## Another Energy Benefit



For a plenum fan, the motor and belts are in the air stream

- Motor and belt losses become a cooling load
  - Chilled water load when the cooling coil is active



For a SWSI fan, the motor and belts are out of the air stream

- No load at all if the mechanical room is unconditioned
- Load on the return side if it is a return plenum; discharged with relief air during economizer cycle

# Motor Loss Savings Projection Results

## AHU 2 System Type, 8 Similar Building Modules

### Central Plant Savings from AHU 2 Motors No Longer in the Air Stream

	Motor efficiency losses - Weekday	628,269	Btu						
	Motor efficiency losses - Weekend	81,417	Btu						
	Total for a week -	709,686	Btu						
	Total for a year -	36,903,659	Btu						
	% of hours when air is recirculated (see fan heat calc) -	28%	Use this as a derating factor for the savings associated with fan heat the motors no longer being in the air stream						
	Derated motor efficiency savings -	10,385,076	Btu						
		865	Ton-hours						
	Plant over-all kW per ton -	0.85	1.00						
	Annual kWh savings from reduced fan heat -	736	865	per system					
	Annual \$ savings from reduced fan heat -	\$74	\$130	per system					
	AHU 2 Systems per wedge -	7	7						
	Savings per wedge -	\$515	\$909						
	Number of wedges -	8	8						
	Total savings for AHU2 system type -	\$4,119	\$7,270						



# Savings Summary

Item	kWh		Dollars	
	Low End	High End	Low End	High End
Fan Energy Savings	424,882	472,091	\$42,488	\$70,814
Fan Heat Savings	27,258	32,068	\$2,726	\$4,810
Motor Heat Savings	41,194	48,464	\$4,119	\$7,270
TOTALS	493,334	552,623	\$49,333	\$82,893
Low end savings assessed at \$0.10 per kWh; high end savings assessed at \$0.15 per kWh				

# Fan Walls

## Not a Panacea


- Smaller fan wheels usually less efficiency than bigger ones
- Smaller motors usually less efficient than bigger ones
- Backdraft dampers = system effect
- Backdraft dampers = optional
- Multiple motors on one VFD
  - Possible application issue
  - Possible motor circuit protection issue
  - Possible reverse spinning motor start issue



# Fan Walls

## A Tool in the Efficiency Tool Box

- Existing fan selection at 60% efficiency
- Poor discharge conditions
  - Manual backdraft damper
  - Air blender
  - Short diffuser/evase'
- Fans run round the clock
- Mission critical application; redundancy important
- System turn-down potential during unoccupied hours





# Fan performance optimization

Specify in terms of fundamentals

- Flow
- Fan total or static pressure
- Maximum bhp
- Minimum fan efficiency
- Minimum motor efficiency
- Minimum motor power factor
- Maximum motor speed

Allow the manufacturers to exploit their technology

# Get What you Asked For

If you don't need it, don't specify it

If you do need it, enforce the specification requirement

Require shop drawings

- Standard catalog data – A good starting point
- Fan performance curves
- Motor performance curves
- Seismic qualification certification statement
- Documentation of special features and requirements
- Require O&M data upon approval of shop drawings for commissioning support

Review shop drawings

# Fan Efficiency Is Only Part Of The Equation

The fan's characteristics need to be matched to the system's requirements

The air handling unit components need to be optimized to the application


Distribution efficiency is critical

The air handling system needs to be tuned to the actual operating requirements


- Flexible, robust design
- Commissioning
- Training



Economizers bring in **outdoor air** above and beyond the **ventilation** requirement, **mix it** with **return air** as required to control set point and thereby provide free cooling



A Quick Word about Economizers,  
Return Fans, and Relief Fans




# Return Fans

Overcome the static pressure loss  
between the zone and the air  
handling system

Operate any time the supply fan runs

- Return air for recirculation
- Frequently, deliver air to the relief louver for discharge to the exterior when operating on an economizer cycle





# Relief Fans

Overcome the static pressure loss  
between the air handling unit location  
and the relief louver

- Only operate during an economizer cycle
- VFD operation often coordinated with building pressure

