

# Fans, Ducts and Air Handling Systems: Design, Performance and Commissioning Issues

## Louvers and Dampers



Instructor:

David Sellers

Senior Engineer

Facility Dynamics Engineering

November 7, 2017

# Louvers; The Point of Entry and Exit for the Air in Our Air Handling Systems

# Louvers; Main Functions

## **Architectural appearance**

*Above all else, it is of critical importance that the louvers appeal to the senses of the casual passer by; that they somehow beckon and call out to them, causing them to pause and contemplate, even relish the possibility of entering the building and securing a tour of the air handling systems and major mechanical spaces*

Unknown

A close-up photograph of a metal mesh louver on a building facade. The louver is made of a silver-colored metal with a diamond-shaped mesh pattern. It is mounted on a light-colored concrete or stone wall. The louver is partially open, showing the dark interior of the building. The lighting is bright, creating strong highlights and shadows.

# Louvers; Main Functions


**Architectural appearance**

**Only let air in (or out)**

- Keep out the bugs and birds  
(and bats)
- Keep out the rain
- Secure the envelope penetration

**Have minimal pressure drop**

# Dampers; Critical Control and Life Safety Devices



## Control Functions

### Ventilation

- Minimum outdoor air flow
- Supply/return flow balance

### Temperature

- Economizer cycle
- Face and bypass control
- Zone temperature control

### Pressure

- Building pressure control
- Pressure relief


# Typical Pressure Relief Door Installation



## Air Hammer Event; Duct Pressure vs. Time

Based on Ruskin Test Data from their Catalogue

Note that Full Scale on the Time Axis is 1 Second



— Upstream Pressure  
— Down Stream Pressure

Why We Need Pressure Relief Doors

# Critical Control and Life Safety Devices

## Control Functions

### Ventilation

- Minimum outdoor air flow
- Supply/return flow balance

### Temperature

- Economizer cycle
- Face and bypass control
- Zone temperature control

### Pressure

- Building pressure control
- Pressure relief

### Balancing



11/14/2002

# Critical Control and Life Safety Devices

## Control Functions

### Ventilation

- Minimum outdoor air flow
- Supply/return flow balance

### Temperature

- Economizer cycle
- Face and bypass control
- Zone temperature control

### Pressure

- Building pressure control
- Pressure relief

### Balancing

11/14/2002

# Critical Control and Life Safety Devices

## Control Functions

### Ventilation

- Minimum outdoor air flow
- Supply/return flow balance

### Temperature

- Economizer cycle
- Face and bypass control
- Zone temperature control

### Pressure


- Building pressure control
- Pressure relief

### Balancing



11/14/2002


# Damper Parts



# A Conventional, Flat Plate Blade Cross-Section



# Greenheck's Airfoil Blade Cross-Section




Jamb Seal

Blade seals


Seal Details

# Parallel vs. Opposed Blade Dampers

Parallel Blade Damper



Opposed Blade Damper





# Dampers Use Pressure Drop to Control Flow


Opposed and parallel blade characteristics curves are different

The damper's pressure drop needs to be significant relative to the system

The more significant the pressure drop, the more linear the flow vs. stroke response



# Linkage Kinematics Can Be Critical



See [Economizers – The Physics of Linkage Systems](#) on my blog for more information

# Critical Control and Life Safety Devices



## Life Safety Functions

### Ventilation

### Pressure Relief

- Explosion vents
- Pressure differential control

### Fire Separation



# Fusible Links are Typically U.L. Labeled ...



# Fusible Links are Typically U.L. Labeled... But Not Always





The damper is in a sleeve

The sleeve is mounted in an oversized opening in the wall and supported by framing angles that allow relative motion due to thermal expansion and structural motion in an event to occur

There Are A Lot of Critical Details Associated with a Fire Damper Installation



A "break away" joint is designed to allow the duct to be knocked away on either side of the wall without pulling the damper out of the wall

There Are A Lot of Critical Details Associated with a Fire Damper Installation

# Critical Control and Life Safety Devices

## Life Safety Functions


Ventilation

Pressure Relief

- Explosion vents
- Pressure differential control

Fire Separation

Smoke Management



Think About Repairing the Center Actuator in the Previous Slide Through the Access Door in This Slide

11/14/2002

# Fire/Smoke/Control Damper Access is Critical

*Preferably, it should not involve tearing down a wall*


# Commissioning and Preventive Maintenance are Critical

System	Number of HVAC System Fans	Number of Other Components	Reliability of New System Before Cx	Mean Life of Commissioned System (months)
1	3	0	0.97	116
2	0	3	0.83	46
3	3	9	0.56	14
4	5	18	0.31	8
5	5	54	0.03	3

1. Data derived from the ASHRAE's Design of Smoke Management Systems
2. HVAC fan reliability assumed to be .99 and other components assumed to be .94
3. HVAC fan fan failure rates were assumed to be  $10^{-6}$  per hour and other components assumed to be  $10^{-5}$  per hour

# Minimizing Pressure Drop to Capture Savings

Upgrade smoke dampers to airfoil blade design  
Savings potential = 50%+ reduction in pressure drop for every hour of operation



# Fans, Ductwork, & Air Handling Components:

Supplemental Information

**More on Linkage Systems**



Instructor:


David Sellers

Senior Engineer

Facility Dynamics Engineering

November 12, 2013

# An Experiment



Clinometer on the Outdoor Air Damper Blade (initially horizontal)

Stroke indicator

Clevis and crank arm

Damper shaft

Clinometer on the Return Air Damper Blade (initially vertical)

Control signal

Return damper linkage

# Start



4 psig



5 psig




6 psig



7 psig




7-1/2 psig (50% stroke)




8 psig



9 psig



10 psig



11 psig




12 psig (Should be full stroke, but it wasn't)




# Experimental Results

Shaft Extension and Blade Rotation for a Pivot Mount Actuator Driving An Outdoor Air and Return Air Damper




# Fortunately, Centerline Drive Actuators Solve the Linearity Problems



# Fortunately, Centerline Drive Actuators Solve the Linearity Problems; Or Not



# Dampers; Critical Control and Life Safety Devices



## Control Functions

### Ventilation

- Minimum outdoor air flow
- Supply/return flow balance

### Temperature

- Economizer cycle
- Face and bypass control
- Zone temperature control

### Pressure

- Building pressure control
- Pressure relief

## Life Safety Functions

### Ventilation

### Pressure Relief

- Explosion vents
- Pressure differential control

# Fans, Ductwork, & Air Handling Components:

Supplemental Information

**More on Damper Cost Savings**



Instructor:

David Sellers

Senior Engineer

Facility Dynamics Engineering

November 12, 2013

## Savings via a blade design change

Horse power =  $\frac{\text{Flow in cfm} \times (\text{Fan static pressure in in.w.c.})}{(\text{Conversion constant} \times \text{Fan efficiency} \times \text{Motor efficiency})}$

Flow rate = 46,687 cfm

Static pressure eliminated = 0.23 in.w.c. (Ruskin data for an FD60 at 3,000 fpm)

Assumed fan efficiency = 80%

Assumed motor efficiency = 85%

Fan horse power = 2.43 hp.

Kw = 1.81

Operating hours per year = 2,600

Annual kWh savings potential = 4,714 kWh per year

Assumed electrical cost = \$0.0750 \$/kWh


Annual savings potential for AHU9 = \$354 per year

# The Simple Payback at Design

Damper area = 15.82 sq.ft.  
Conventional blade cost per square foot = \$88  
Airfoil blade cost per square foot = \$104  
Cost difference for this damper = \$257  
Simple payback = 0.73 years

**The payback decays rapidly if the change is not made until after the damper is purchased or installed!**

# Thinking Outside the Box to Capture Savings



# Operating Cost Savings

Horse power =  $\frac{\text{Flow in cfm} \times \text{Fan static pressure in in.w.c.}}{\text{Conversion constant} \times \text{Fan efficiency} \times \text{Motor efficiency}}$

Flow rate = 46,687 cfm

Static pressure eliminated = 0.18 in.w.c. (Ruskin data for an FD60 at 3,000 fpm)

Assumed fan efficiency = 80%

Assumed motor efficiency = 85%

Fan horse power = 1.89 hp.

Kw = 1.41

Operating hours per year = 2,600

Annual kWh savings potential = 3,666 kWh per year

Assumed electrical cost = \$0.0750 \$/kWh

Annual savings potential for AHU9 = \$275 per year

For 16 air handling units = \$4,400 per year

# First Cost Savings

Supply damper area = 15.82 sq.ft.  
Damper first cost = \$104 \$/sq.ft.

	<u>One Unit</u>	<u>All Units</u>
Supply damper savings	\$1,642	\$26,266
Return damper savings	<u>\$3,283</u>	<u>\$52,532</u>
Total savings	\$4,925	<u>\$78,798</u>

- This does not include the installation costs and wiring, so the actual savings could easily be twice this much!

# Early Discovery = Better

## Detail improved fitting at design

- May lower first cost
  - Less sheet metal
- Capture life time savings with a wiser and/or lower first cost expenditure
  - Less static =
    - Smaller fan
    - Smaller drive
    - Smaller wire
    - Smaller service

# Early Discovery = Better

## Discover a problem during installation

- May take money to correct
  - Reconfigure
  - Design issue vs. contractor issue
- Capture operational savings
- Loose first cost savings

# Early Discovery = Better

## Discover a problem after installation

- Correction may be financially unviable unless driven by a performance requirement
- Operational penalty for the life of the system
- First cost savings opportunity lost