

# Pumps (and Piping)

Design, Performance and Commissioning Issues

Pump Optimization Options



**Instructor:**

David Sellers

Senior Engineer

Facility Dynamics Engineering


April 4, 2017

# The San Diego Marriott Marquis and Marina

South Tower  
chiller plant in  
lower level  
mechanical  
space




## San Diego Marina Marriott Chilled Water Plant Hours of Operation at Different Tonnages Based on ECS Data





# Peerless 8BT12, 65 gpm at 1200.0 ft.w.c., 26.98 bhp

9.19" impeller, 30 hp, 1750 rpm



Single pump operating point produces significantly more flow and uses significantly more pump energy than required by the single chiller design flow requirement

- 1,920 gpm vs. 1,200 gpm
- 28.75 bhp vs. 8-12 bhp potentially

The information on this pump curve was reproduced from the manufacturers certified performance curves for the purposes of analysis and illustration. To verify certified performance for this pump, refer to the manufacturers certified performance curve

# Option 1 – Throttling

## Implementation Strategy

- Convert the two position output controlling the isolation valve to an analog output
- If the chiller is off, close the valve
- If the chiller is the **only** chiller running, open the valve to a setting that throttles to design flow
- If both chillers are running, fully open the valve

# Option 1 – Throttling

## Energy Savings Assessment Methodology

- Read bhp wide open and throttled from the pump curve
- Divided by motor efficiency
- Converted to kW
- Multiplied by hours per year that the pump runs
- Multiplied by the electric rate

# Option 1 – Throttling

## Implementation Cost Assessment Methodology

- Made a list of what needed to be done
  - Convert digital output to analog output
  - Test to determine valve position with one chiller running
- Contacted the control vendor to ask for a price to accomplish the required hardware and firmware modifications
- Planned on doing hardware change-out and testing in-house

# Option 1 – Throttling

## Cost/Benefit Metrics

- Wide open bhp = 28.75
- Throttled bhp = 26.98
- Bhp savings = 1.77
- Motor efficiency = 92.0 %
- kW savings = 1.44
- Annual hours = 6,746
- Annual kWh savings = 9,682
- Annual dollar savings = \$1,162
- Implementation cost = \$1,000 or less
- Simple payback = .86 years or less

# Option 1 – Throttling

## Advantages

- Simple
- Quick
- Attractive simple payback
- Can be done in-house with some support from the control system vendor

## Disadvantages

- Low energy savings potential relative to some of the other options

# Option 2 – Trim Impeller on Back-up Pump

## Implementation Strategy

- Trim the impeller in the standby pump
  - Smallest impeller still too big
  - Use smallest impeller and throttle
- Run the pump with the trimmed impeller when only one chiller is in operation
- Run the un-modified pumps when two chillers are in operation
- Pump disassembly, impeller trimming and pump reassembly can be done by a preferred contractor and may be possible in-house

# Option 2 – Trim Impeller on Back-up Pump

## Energy Savings Assessment Methodology

- Read bhp wide open from the pump curve
- Calculated bhp at the new operating point from pump curve data

$$\text{kW} = \frac{(\text{Flow} \times \text{Head})}{(3,960 \times \eta_{\text{Pump}} \times \eta_{\text{Motor}})} \times .746 \frac{\text{hp}}{\text{kW}}$$

- Multiplied by hours per year that the pump runs
- Multiplied by the electric rate

# Option 2 – Trim Impeller on Back-up Pump

## Implementation Cost Assessment Methodology

- Made a list of what needed to be done
- Contacted the pump vendor to determine the cost of an overhaul and impeller trim
- Reviewed the option for performing the overhaul in-house with the operating staff

## Option 2 – Trim Impeller on Back-up Pump

### Cost/Benefit Metrics

- Wide open bhp = 28.75
- Trimmed bhp = 17.20
- Bhp savings = 11.55
- Motor efficiency = 92.5%
- kW savings = 9.44
- Annual hours = 6,746
- Annual kWh savings = 63,694
- Annual dollar savings = \$7,643
- Implementation cost = \$5,000 or less
- Simple payback = .65 years or less

## Option 2 – Trim Impeller on Back-up Pump

### Advantages

- Significantly more energy savings than Option 1
- Similar savings to Option 3 with lower first cost and less complexity
- Very persistent
- Much of the work could be done in-house further reducing the cost and improving the payback

### Disadvantages

- Redundancy lost; if one of the unmodified pumps fails with both chillers running, you will not be able to run both chillers
- Costly to “undo”

# Option 3 – Reduce Speed

## Implementation Strategy

- Affinity laws identify target speed

$$Speed_{New} = Speed_{Old} \times \left[ \frac{Flow_{New}}{Flow_{Old}} \right]^2$$

- Redundancy and required speed eliminate speed change via motor change option
- Variable speed drive (VSD) slows the pump down when only one chiller is running
- Both fixed speed pumps run when two chillers run
- VSD runs at full speed to back up fixed speed pumps




# Option 3 – Reduce Speed

## Energy Savings Assessment Methodology

- Read bhp wide open from the pump curve
- Calculated bhp at the new operating point from pump curve data

$$\text{kW} = \frac{(\text{Flow} \times \text{Head})}{(3,960 \times \eta_{\text{Pump}} \times \eta_{\text{Motor}} \times \eta_{\text{Drive}})} \times .746 \frac{\text{hp}}{\text{kW}}$$

- Divided by motor efficiency
- Converted to kW
- Multiplied by hours per year that the pump runs
- Multiplied by the electric rate



# Option 3 – Reduce Speed

## Implementation Cost Assessment Methodology

- Made a list of what needed to be done
  - Furnish and install a VFD
  - Interlock with existing control system
- Perform control work in-house
- Develop a RFP and price VFDs for installation by an electrician



# Option 3 – Reduce Speed

## Cost/Benefit Metrics

- Wide open bhp = 28.75
- Reduced speed bhp = 9.19
- Bhp savings = 19.56
- Motor efficiency = 91.0%
- VFD efficiency = 92.0%
- kW savings = 15.12
- Annual hours = 6,746
- Annual kWh savings = 102,012
- Annual dollar savings = \$12,241
- Implementation cost = \$12,850
- Simple payback = 1.05 years




# Option 3 – Reduce Speed

## Advantages

- 2<sup>nd</sup> largest energy savings
- Attractive simple payback
- Preserves redundancy

## Disadvantages


- Complex
- 2<sup>nd</sup> most expensive
- Less persistent



# Option 4 – Replace the Pump

## Implementation Strategy

- Select and install a pump rated for peak efficiency at the required conditions of 1,200 gpm at 23 ft.w.c.




# Option 4 – Replace the Pump

## Energy Savings Assessment Methodology

- Read bhp wide open from the existing pump curve
- Calculated bhp at the new operating point from the new pump curve data

$$kW = \frac{(Flow \times Head)}{(3,960 \times \eta_{Pump} \times \eta_{Motor})} \times .746 \frac{hp}{kW}$$

- Multiplied by hours per year that the pump runs
- Multiplied by the electric rate



# Option 4 – Replace the Pump

## Implementation Cost Assessment Methodology


- Made a list of what needed to be done
  - Pump and trim
  - Pipe
  - Valves
  - Fittings
  - Welds/labor
  - Wire and conduit
  - Electrical gear
- Use R.S. Means or other resources to assess the cost

Cost Projection for Adding a Redundant Pump									
No.	Description	Quant.	Units	Material		Outside Contractor Labor			
				Unit Cost, \$	Total Cost, \$	Rate, \$ per hour	Unit Hours	Total Hours	Total Cost, \$
	Pump	1	ea	\$10,600.00	\$10,600	\$43.75	48.0000	48.0	\$2,100
	8" suction Diffuser	1	ea	\$1,775.00	\$1,775	\$43.75	9.6000	9.6	\$420
	8" butterfly valve	2	ea	\$320.00	\$640	\$43.75	5.3330	10.7	\$467
	Butterfly valve operator	2	ea		With valve		With valve	0.0	\$0
	8" check valve	1	ea	\$950.00	\$950	\$43.75	5.3330	5.3	\$233
	8" flex connector	2	ea	\$310.00	\$620	\$43.75	2.0000	4.0	\$175
	8" pipe flanges	12	ea	\$92.50	\$1,110	\$43.75	3.4290	41.1	\$1,800
	Flange gaskets and bolt sets	12	ea	\$16.20	\$194	\$43.75	1.6000	19.2	\$840
	8" pipe	20	ft	\$48.94	\$979	\$43.75	0.8280	16.6	\$725
	10" x 8" reducing tee	2	ea	\$558.00	\$1,116	\$43.75	12.0000	24.0	\$1,050
	8" 45 degree elbow	2	ea	\$115.00	\$230	\$43.75	6.4000	12.8	\$560
	Gauge valves (1/4" ball valves)	3	ea	\$10.30	\$31	\$43.75	0.3330	1.0	\$44
	Vent and drain (3/4" ball valves)	2	ea	\$16.95	\$34	\$43.75	0.4000	0.8	\$35
	Pressure gauge	1	ea	\$167.00	\$167	\$43.75	0.2500	0.3	\$11
	Pipe insulation	0	ft	\$4.78	\$0	\$38.76	0.1780	0.0	\$0
	Pump/suction diffuser insulation	0	sq.ft	\$4.24	\$0	\$38.76	0.1680	0.0	\$0
	Fitting insulation - flanges	0	ea	\$19.12	\$0	\$38.76	0.7120	0.0	\$0
	Fitting insulation - special fittings	0	ea	\$19.12	\$0	\$38.76	0.7120	0.0	\$0
	Fitting insulation - 8" elbow	0	ea	\$14.34	\$0	\$38.76	0.5340	0.0	\$0
	Fitting insulation - 10" tee	0	ea	\$15.45	\$0	\$38.76	0.6000	0.0	\$0
	1" conduit	50	ft	\$3.66	\$183	\$45.53	0.1230	6.2	\$280
	#8 gauge wire	200	ft	\$0.41	\$81	\$45.53	0.0100	2.0	\$91
	Pull box	2	ea	\$26.00	\$52	\$45.53	1.4450	2.9	\$132
	Variable speed drive	0	ea	\$13,930.00	\$0	\$45.53	51.2820	0.0	\$0
	Panel board switch	1	ea	\$1,100.00	\$1,100	\$45.53	2.0000	2.0	\$91
	VFD factory start-up	1	ea	\$0.00	\$0	\$91.06	4.0000	4.0	\$364
	Pad	1	ea	\$150.00	\$150	\$37.81	1.6000	1.6	\$61
	Grouting	1	ea	\$75.00	\$75	\$37.81	1.6000	1.6	\$61
	Alignment	1	ea	\$25.00	\$25	\$91.06	2.0000	2.0	\$182
	Start stop point	1	ea	\$330.00	\$330		With material	0.0	\$0
	Proof of operation point	1	ea	\$850.00	\$850		With material	0.0	\$0
	Speed command point	1	ea	\$330.00	\$330		With material	0.0	\$0
	Network interface for diagnostics	1	ea	\$550.00	\$550		With material	0.0	\$0
	Verification checks and start-up	1	lot	\$0.00	\$0	\$125.00	2.0000	2.0	\$250
					\$0			0.0	\$0
	<b>TOTALS</b>				<b>\$22,172</b>			<b>218</b>	<b>\$9,970</b>
	<b>TOTAL - All Cost Components</b>				<b>\$32,142</b>				
	<b>TAX</b>		5.00%		<b>\$1,109</b>				
	<b>NET COST</b>				<b>\$33,251</b>				
	<b>Design</b>	0.00%			<b>\$0</b>				
	<b>Construction</b>	3.00%			<b>\$998</b>				
	<b>CONTRACTOR'S MARK-UPS</b>								
	<b>Overhead</b>	10.00%			<b>\$3,425</b>				
	<b>Profit</b>	5.00%			<b>\$1,884</b>				
	<b>Net Mark-up with contingencies</b>	123.07%							
	<b>GRAND TOTAL</b>				<b>\$39,557</b>				

# Option 4 – Replace the Pump

## Cost/Benefit Metrics

- Wide open bhp = 28.75
- New pump bhp = 8.37
- Bhp savings = 20.38
- Motor efficiency = 92.1%
- kW savings = 18.46
- Annual hours = 6,746
- Annual kWh savings = 124,502
- Annual dollar savings = \$14,940
- Implementation cost = \$39,577
- Simple payback = 2.65 years




# Option 4 – Replace the Pump

## Advantages

- Largest energy savings
- Very persistent

## Disadvantages

- Complex implementation
- Most expensive
- Exceeds Owner's simple payback window



# Bottom Lines

Item	Throttling	Impeller Trim	Speed Reduction	New Pump
Savings, kW	1.44	9.44	15.12	18.46
Annual Savings, kWh	9,682	63,694	102,012	124,502
Annual Savings	\$1,162	\$7,643	\$12,241	\$14,940
Implementation Cost	\$1,000 or less	\$5,000 or less	\$12,850	\$39,557 minimum
Simple Payback, Years	.86 or less	.65 or less	1.05	2.65 or more

## Simple measures are good first steps

- Accumulate initial savings while other options are assessed
- Don't blow the baseline in utility programs by implementing too quickly

# Bottom Lines

Item	Throttling	Impeller Trim	Speed Reduction	New Pump
Savings, kW	1.44	9.44	15.12	18.46
Annual Savings, kWh	9,682	63,694	102,012	124,502
Annual Savings	\$1,162	\$7,643	\$12,241	\$14,940
Implementation Cost	\$1,000 or less	\$5,000 or less	\$12,850	\$39,557 minimum
Simple Payback, Years	.86 or less	.65 or less	1.05	2.65 or more

## Best Simple Payback May Not be Best Energy Savings

- Implementation cost impacts simple payback

# Bottom Lines

Item	Throttling	Impeller Trim	Speed Reduction	New Pump
Savings, kW	1.44	9.44	15.12	18.46
Annual Savings, kWh	9,682	63,694	102,012	124,502
Annual Savings	\$1,162	\$7,643	\$12,241	\$14,940
Implementation Cost	\$1,000 or less	\$5,000 or less	\$12,850	\$39,557 minimum
Simple Payback, Years	.86 or less	.65 or less	1.05	2.65 or more

## There May be Critical Issues Beyond Energy Savings and Simple Payback

- Reliability and redundancy can have dollar values associated with them that are as significant or more significant than energy savings

# Bottom Lines

Item	Throttling	Impeller Trim	Speed Reduction	New Pump
Savings, kW	1.44	9.44	15.12	18.46
Annual Savings, kWh	9,682	63,694	102,012	124,502
Annual Savings	\$1,162	\$7,643	\$12,241	\$14,940
Implementation Cost	\$1,000 or less	\$5,000 or less	\$12,850	\$39,557 minimum
Simple Payback, Years	.86 or less	.65 or less	1.05	2.65 or more

## Best Efficiency Often Equates to Best Selection

- Getting it right the first time is often the best choice
- Getting it right the first time can have first cost benefits

# Bottom Lines

Item	Throttling	Impeller Trim	Speed Reduction	New Pump
Savings, kW	1.44	9.44	15.12	18.46
Annual Savings, kWh	9,682	63,694	102,012	124,502
Annual Savings	\$1,162	\$7,643	\$12,241	\$14,940
Implementation Cost	\$1,000 or less	\$5,000 or less	\$12,850	\$39,557 minimum
Simple Payback, Years	.86 or less	.65 or less	1.05	2.65 or more

## Achievable Savings may be Constrained by the Owner's financial metrics

- Life cycle cost analysis may swing the financial perspective
- The Owner's economic game drives the economic bottom line

# Bottom Lines

Item	Throttling	Impeller Trim	Speed Reduction	New Pump
Annual Energy Cost	1.00	1.00	1.00	1.00
Simple Payback, years	.66 or less	.65 or less	1.05	2.65 or more

*It Depends*  
Jay Santos

*What's the right choice?*

# Bottom Lines

Item	Throttling	Impeller Trim	Speed Reduction	New Pump
Savings, kW	1.44	9.44	15.12	18.46
Annual Savings, kWh	9,682	63,694	102,012	124,502
Annual Savings	\$1,162	\$7,643	\$12,241	\$14,940
Implementation Cost	\$1,000 or less	\$5,000 or less	\$12,850	\$39,557 minimum
Simple Payback, Years	.86 or less	.65 or less	1.05	2.65 or more

For the San Diego Marriott Marquis and Marina condenser water system, a variable speed drive represented the best option for maximizing savings while ensuring guest satisfaction via redundancy in the central plant

# Bottom Lines

In the bigger picture, understanding pumps and piping systems opens the door to a number of benefits

- Optimized selections from the start
  - Better efficiency from the start
  - Lower first costs
  - Fewer ripple effects
- Improved performance and reliability
  - Delivers Non-Energy Benefits (NEBs) that are critical to the Owner's bottom line
- Its *Fun*

**Thank you for participating!**  
**PG&E Pacific Energy Center**

**More FREE educational opportunities at**  
**[www.pge.com/energyclasses](http://www.pge.com/energyclasses)**

