

- REFER TO DRAWING M.01 FOR ADDITIONAL SHEET NOTES.
- UNLESS OTHERWISE NOTED, ALL HWS AND HWR CONNECTIONS TO REHEAT HEATING COILS SHALL BE 2".
- PIPING (ABOVE 4 INCHES IN DIAMETER) AND DUCTS (ABOVE 20 INCHES IN DIAMETER ROUND OR EQUIVALENT RECTANGULAR CONFIGURATION) LOCATED IN THE SUB-FAB MECHANICAL ROOM #280 AND THE CHILLER ROOM #281 SHALL NOT BE SUPPORTED FROM LEVEL 3M SLAB. PROVIDE SUPPORTS FOR DUCTWORK AND PIPING FROM A SECONDARY FRAMING ELEMENTS LOCATED BELOW 3M SLAB.
- HVAC CONTRACTOR SHALL PROVIDE EQUIPMENT, DUCT, AND PIPING SEISMIC BRACING AND ANCHORAGE PER SPECIFICATION SECTION 1524S.

KEYED NOTES

- CHEMICAL SHOT FEEDER.
- 1" COLD WATER SUPPLY AND RETURN DOWN TO WALL MOUNTED CORROSION COUPON ASSEMBLY.
- CONNECT TO MICROFAB DUCTWORK. REFER TO DRAWING OM3.3.
- CONNECT TO MICROFAB PIPING. REFER TO DRAWING QP2.2.
- CHILLER ROOM CONSTRUCTION SHALL BE AIR-TIGHT.
- NO PIPES, DUCTS, CONDUITS, TRAYS, ETC., FOREIGN TO THE CHILLER ROOM SHALL PASS "THROUGH" THE CHILLER ROOM.
- MANUFACTURER INSTALLED CROSSOVER CONDENSER WATER PIPING.
- HEATING AND COOLING COIL PULL-OUT SPACE.
- SUPPLY FAN VSD. REFER TO DRAWING M6.10.
- EMERGENCY REFRIGERATION CONTROL SWITCH (BREAKING GLASS TYPE). FOR ADDITIONAL INFORMATION REFER TO SPECIFICATION SECTION 17000-37.1B.
- EMERGENCY PURGE VENTILATION CONTROL SWITCH (BREAKING GLASS TYPE). FOR ADDITIONAL INFORMATION REFER TO SPECIFICATION SECTION 17000-31.07.
- CHILLER PLANT REFRIGERATION LEAK MONITOR FURNISHED BY CHILLER MANUFACTURER FOR INSTALLATION BY DIVISION 17. PROVIDE A MINIMUM OF FOUR LEAK MONITOR SENSORS REQUIRED FOR THE REFRIGERATION MACHINERY ROOM. THE SYSTEM, INCLUDING THE SENSORS SHALL BE INSTALLED PER THE MANUFACTURER'S INSTALLATION INSTRUCTIONS. PROVIDE SUBMITTALS TO CAMPUS FIRE MARSHAL FOR REVIEW AND APPROVAL PRIOR TO THE INSTALLATION. THE SUBMITTALS SHALL INCLUDE BUT NOT BE LIMITED TO THE PICK-UP (SENSOR) LOCATIONS AND ELEVATIONS.
- CONNECT TO MICROFAB PIPING. REFER TO DRAWING QM2.2.
- CONDENSATE FLOW METER.

