

Harmonic Analysis

Drive Harmonic Calculator		Harmonic-US-3.0		ID #
Zsource,Isc,Idmd Calculator		Isc/Idmd = 17.4	Idmd/Idrv = 4.58	Isc/Idrv = 79.82435
Detailed Inputs are in green		Primary Impedance: R =	Primary MVA SC = 400	Pri Isc = 17,496
Critical Inputs are in red		+jX =	ohms, Z =	ohm X/R =
Application (Spc, Gen, Ded) = Gen		Primary Wire AWG Size:	Wire Length(ft) =	# in Paral=
T1 KVA dxfmr= 2,500		Vdxfmrpri = 13,200	Idistxfmr rated@Vpcc = 3007.121	Amps
Dist Xfmr % Z = 5.75		Vdxfmrsec = 480	Idmd t1pri = 98.4	VII @ pcc = 480
% Demand: T1 KVA = 90		KVA dmd = 2,250	Idmd t1sec= 2706.409	Idmd@pcc 2,706.4
PCC Location = t1		Ave %Mtr Loading: 80	LineFreq = 60	Idrv@pcc 590.9234
Transformer		Network Inputs:		AveSysEff*PF: 0.82
#	ID TAG	Fed From	KVA	% Z
T1	XFMR-T1-UTIL	Utility	2,500	5.75
T2				
T3				
T4				
T5				
T6				
T7				
T8				
T9				
Drive #	ID TAG	Fed From	Conv Type	Hp Drive
1	CH-6, 7, 8,9	t1	1	540
2	P-5, 6	t1	1	40
3	P-7, 8	t1	1	15
4	P-11, 12, 13	t1	1	5
5	VF-1, 2, 3, 4, 6, 7	t1	1	6
6	VF-5, 8, 9, 10, 11, 12	t1	1	5
7	VF-13	t1	1	1
8	EF-7	t1	1	3
9	CT-1, 2	t1	1	20
10	P-1,2,3,4	t1	1	40
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				
<p>All % Impedances are with respect to the total drives connected thru the PCC.</p> <p>I-demand includes both drive currents and sinusoidal currents. The ratio I-demand / I-drives is assumed the same at all points in network unless sine loads are added at a point.</p> <p>6 pulse drives have built-in internal line reactor or equivalent bus choke. For : 3/2.5% for VT, 2.3/1.9% for CT; for : 5/4% @ 60/50Hz.</p> <p>For Converter Input above: Input 1 = 6 pulse, 2 = 12 pulse, 3 = 18 pulse, 4 = 5th harmonic trap and 5% filter, 5 = Mirus Coupled filter, 6 = ACS800-11, 17, 31, 37</p> <p>7 = New TCI Trap Filter, 8 = Active Filter, 9 = Sine Load, 10 = MTE Low Pass Filter, 11 = 18 Pulse w/AutoTransformer</p>				

Harmonic Analysis

HARMONIC ANALYSIS REPORT						Harmonic	Frequency	%TDD Limit	%Ithd	Ih amps	% Vthd	% TDD
Project ID #: [REDACTED]		DATE: [REDACTED]		Description: Harmonic Calculation		1	60		100.0	554.71	0.000	0.000
Requested By: [REDACTED]		Contact: [REDACTED]		FAX: [REDACTED]		2	120	1.00	0.02	0.09	0.000	0.003
Phone: [REDACTED]		By: [REDACTED]		Phone: [REDACTED]		3	180	1.00	4.00	22.17	0.108	0.819
Email: [REDACTED]		Fax: [REDACTED]		System Data:		4	240	1.00	0.02	0.10	0.001	0.004
PCC =		t1		Line Freq = 60 Hz		5	300	4.00	34.51	191.42	1.561	7.073
MVA		MVA		VII @ PCC = 480 Volts		6	360	1.00	0.01	0.05	0.000	0.002
Other Z primary: R =		ohm		Total Drive HP @ PCC = 675 HP		7	420	4.00	8.71	48.32	0.552	1.785
X =		ohm		Total Used HP @ PCC = 540.002 HP		8	480	1.00	0.01	0.04	0.001	0.001
Z =		ohm		I Short Ckt @ PCC = 47,170 Amps		9	540	1.00	0.71	3.96	0.058	0.146
AWG Wire Size =				I demand @ PCC = 2,706.4 Amps		10	600	1.00	0.00	0.03	0.000	0.001
Wire Length =		feet		I drives in @ PCC = 590.9 Amps		11	660	2.00	6.44	35.73	0.641	1.320
# in Parallel =				Isc / Idmd = 17.4		12	720	0.50	0.00	0.02	0.000	0.001
% Wire Voltage Drop		%		Idmd/Idrv = 4.6		13	780	2.00	3.33	18.50	0.392	0.684
Dist Xfmr KVA: 2500 KVA				Isc/Idrv = 79.8		14	840	0.50	0.01	0.05	0.001	0.002
Dist Xfmr % Z: 5.75 %				%Zs before PCC = 1.3 %		15	900	0.50	0.36	2.01	0.049	0.074
DXfmr Irate @ PCC: 3007.12 Amps				% Zf after PCC = 6.0 %		16	960	0.50	0.01	0.04	0.001	0.002
Demand % KVA Xfmr: 90 %				% Z loop @ PCC = 7.3 %		17	1020	1.50	2.35	13.05	0.362	0.482
Demand KVA: 2250 KVA				If drvs@ PCC = 554.7 Amps		18	1080	0.38	0.00	0.02	0.001	0.001
Ave % Motor Loading: 80 %				Ih @ PCC = 203.7 Amps		19	1140	1.50	1.63	9.04	0.280	0.334
Meets IEEE-519: % TDD at T1 PRI				Irms @ PCC = 590.9 Amps		20	1200	0.38	0.01	0.04	0.001	0.002
% Ithdf: 36.720		IEEE-519 Limits:		K factor = 5.001		21	1260	0.38	0.28	1.53	0.053	0.057
% TDD: 7.526		%TDD limit		Disp PF = 0.965		22	1320	0.38	0.01	0.03	0.001	0.001
% Vthdf: 1.956		@ PCC		Act PF = 0.906		23	1380	0.60	1.24	6.89	0.258	0.255
		@ t1 Pri		Vrms @ PCC = 471		24	1440	0.15	0.00	0.02	0.001	0.001
		% Vthdlim		Vbus @ D1 = 617.6		25	1500	0.60	0.79	4.39	0.179	0.162
						26	1560	0.15	0.01	0.05	0.002	0.002
						27	1620	0.15	0.22	1.21	0.053	0.045
						28	1680	0.15	0.01	0.03	0.002	0.001
						29	1740	0.60	0.84	4.67	0.221	0.173
						30	1800	0.15	0.00	0.02	0.001	0.001
						31	1860	0.60	0.49	2.71	0.137	0.100
						32	1920	0.15	0.01	0.05	0.003	0.002
						33	1980	0.15	0.17	0.92	0.050	0.034
						34	2040	0.15	0.12	0.66	0.037	0.025
						35	2100	0.30	0.57	3.15	0.180	0.116
						36	2160	0.08	0.12	0.66	0.039	0.025
						37	2220	0.30	0.34	1.91	0.115	0.071
						38	2280	0.08	0.12	0.66	0.041	0.025
						39	2340	0.08	0.14	0.76	0.049	0.028
						40	2400	0.08	0.12	0.66	0.043	0.025
						41	2460	0.30	0.39	2.15	0.144	0.079
						42	2520	0.08	0.12	0.66	0.046	0.025
						43	2580	0.30	0.22	1.23	0.086	0.045
						44	2640	0.08	0.12	0.66	0.048	0.025
						45	2700	0.08	0.12	0.66	0.049	0.025
						46	2760	0.08	0.12	0.66	0.050	0.025
						47	2820	0.30	0.31	1.70	0.130	0.063
						48	2880	0.08	0.12	0.66	0.052	0.025
						49	2940	0.30	0.16	0.89	0.071	0.033
						50	3000	0.08	0.12	0.66	0.054	0.025

