



How Water and Steam Systems; Basic Principles, Ongoing Commissioning, Operation, and Optimization

Water Source Heat Pump Loop Example




Presented By:
David Sellers

Senior Engineer, Facility Dynamics Engineering

A Hospitality Industry Campus Style Location

- Palm Springs, CA
- North is towards the top of the image
- Focusing on the guest room buildings












A Typical Guest Room Heat Pump Loop




Water Source Heat Pump Loop

2022-11-16, DS










Do You Think There Is Much Heat to Pump?




Are There Other Benefits to the Water Source Heat Pump Loop?



The Loop Pumps




The Tower Pump



The Heat Exchanger and Boiler



Thinking About Monitoring



Water Source Heat Pump Loop

2022-11-16, DS

Monitoring Plan Targets

- Firm up (or not) opportunities identified during scoping
- Provide data
 - Support more detailed investigations
 - Diagnostics and trouble shooting
 - Calculations
 - Looking for common opportunities
 - Are schedules actually working?
 - Are VAV systems VAVing?
 - Are optimization strategies working?
- Support expansion of the findings list
- Support cost benefit assessments
- Support verification

Logger, Serial Number (BMS indicates control system trend)	System	Point (use full point name for BMS Point)	Sensor	Sampling Time	Sensor Location	Logger Location	Link to Screenshot of deployed location of sensor and logger	Link to Screenshot of Launch	Notes
02163770	Cooling Tower	Cell 1 Hot Room Temperature	TM205-1B	3 minute	Hot Room of cell 1	On magnet under the stairs	Sensor 1	Screenshot	1. Put logger in a zip bag and then over something to protect it.
	Cooling Tower	Cell 2 Hot Room Temperature	TM205-1B	3 minute	Hot Room of cell 2		Sensor 2	Logger location	
	Cooling Tower	Cell 1 Cold Room Temperature	TM205-1B	3 minute	Hot Room of cell 1		Sensor 3	Typical Basic Temperature Sensor	
	Cooling Tower	Cell 2 Cold Room Temperature	TM205-1B	3 minute	Hot Room of cell 2		Sensor 4		
02163769	South Tower ACC	Cooling tower - Air temp	CTV-B (50 amp)	3 minute	CT 1 floor at MCC	AT ACC	Sensor 1	Screenshot of logger at floor at launch	1. See general notes 2
	South Tower ACC	Cooling tower 2 for temp	CTV-B (50 amp)	3 minute	CT 2 floor at ACC		Sensor 2	Screenshot of logger	
	South Tower ACC	CW Pump 1 temp	CTV-B (50 amp)	3 minute	CW Pump 1 floor at ACC		Sensor 3		
	South Tower ACC	CW Pump 2 temp	CTV-B (50 amp)	3 minute	CW Pump 2 floor at ACC		Sensor 4		
	South Tower CHW	Chiller 1 Amps	CTV-B (500 amp)	3 minute	Chiller 1 main switch		Sensor 1	Screenshot of logger 02163769	1. Could will monitor ACC over CTV for you to use.
	South Tower CHW	Chiller 2 Amps	CTV-B (500 amp)	3 minute	Chiller 2 main switch		Sensor 2		
	South Tower CHW	Chiller 1 Flow	TM205-1B	3 minute	Transmitter well	At chiller	Sensor 1	Logger location	1. See general notes 1 and 3
	South Tower CHW	Chiller 2 Flow	TM205-1B	3 minute	Transmitter well		Sensor 2	Screenshot	
	South Tower CHW	Chiller 1 Flow	TM205-1B	3 minute	Transmitter well		Sensor 3	Sensor data	
	South Tower CHW	Chiller 2 Flow	TM205-1B	3 minute	Transmitter well		Sensor 4		
02163767	South Tower CHW	Chiller 2 LWT - Chilled Water	TM205-1B	3 minute	Transmitter well	At chiller	Sensor 1	Logger location	1. See general notes 1 and 2
	South Tower CHW	Chiller 2 LWT - Chilled Water	TM205-1B	3 minute	Transmitter well		Sensor 2	Screenshot	
	South Tower CHW	Chiller 2 LWT - Chilled Water	TM205-1B	3 minute	Transmitter well		Sensor 3		
	South Tower CHW	Chiller 2 LWT - Chilled Water	TM205-1B	3 minute	Transmitter well		Sensor 4		
02163771	South Tower CHW	CHW Pump 1 Amps	CTV-B (200 amp)	3 minute	CT 1 floor at MCC	At ACC	Sensor 1	Screenshot of logger at floor at launch	1. See general notes 2
	South Tower CHW	CHW Pump 2 Amps	CTV-B (200 amp)	3 minute	CT 2 floor at ACC		Sensor 2	Screenshot of logger	2. I have assumed a 200 amp CTV is big enough for the chiller's motor pumps.
	South Tower CHW	Pump 1 Amps	CTV-A (200 amp)	2 seconds	DW Pump 1 floor at MCC		Sensor 3		
	South Tower CHW	Pump 2 Amps	CTV-A (200 amp)	2 seconds	DW Pump 2 floor at MCC		Sensor 4		
02163812	ST Bq. Bm. Cond. flow	ST Bq. Bm. Temperature	Internal	3 minute	On Top of BQ Pump Room	At BQ Pump	Sensor 1	Logger 02163771 deployment screenshot	1. Borehole one of Carter's loggers with an internal lighting sensor.
	ST Bq. Bm. Cond. flow	ST Bq. Bm. E & F	Internal	3 minute	On Top of BQ Pump Room		Sensor 2	Logger 02163771 deployment screenshot	
	ST Bq. Bm. Cond. flow	ST Bq. Bm. Lighting Level	Internal	3 minute	On Top of BQ Pump Room		Sensor 3		
	ST Bq. Bm. Cond. flow	ST Bq. Bm. Cond. flow	Internal	3 minute	On Top of BQ Pump Room		Sensor 4		
02163768	NT Lobby 20 Use	Supply fan error	CTV-B (50 amp)	3 minute	NT2 occupancy line	Transmitted by supply fan VFD	Sensor 1	Screenshot of 02163768 launch	1. See general notes 1 and 4
	NT Lobby 20 Use	Post cooling air Temperature	TM205-1B	3 minute	Downstream of fan		Sensor 2	Screenshot of sensor	
	NT Lobby 20 Use	Cool Deck Temperature	TM205-1B	3 minute	Downstream of fan		Sensor 3	Cool deck sensor	
	NT Lobby 20 Use	Hot Deck Temperature	TM205-1B	3 minute	Downstream of fan		Sensor 4	Hot deck sensor	
02164049	NT Lobby 20 Use	Supply fan error	CTV-B (50 amp)	3 minute	NT2 occupancy line	Transmitted by supply fan VFD	Sensor 1	Screenshot of logger at launch	1. Try to get the sensor into the space away from the door so the air change around the door does not influence the logger's data.
	NT Lobby 20 Use	Post cooling air Temperature	TM205-1B	3 minute	Downstream of fan		Sensor 2	Screenshot of sensor	
	NT Lobby 20 Use	Cool Deck Temperature	TM205-1B	3 minute	Downstream of fan		Sensor 3		
	NT Lobby 20 Use	Hot Deck Temperature	TM205-1B	3 minute	Downstream of fan		Sensor 4		


Logger Serial Number (EMS indicates control system trend)	System	Point (use full point name for EMS Points)	Sensor	Sampling Time	Sensor Location	Logger Location	Link to Screenshots of deployed location of sensors and Logger	Notes
							Link to Screenshot of Launch	
10263770	Cooling Tower	Cell 1 Hot Basin Temperature	TMC50-HD	1 minute	Hot basin of cell 1	On magnet under the steel	Sensor 1 Overview	1. Put logger in a zip lock bag and then under something to protect it.
	Cooling Tower	Cell 2 Hot Basin Temperature	TMC50-HD	1 minute	Hot basin of cell 2		Sensor 2 Logger Location	
	Cooling Tower	Cell 1 Cold Basin Temperature	TMC50-HD	1 minute	Hot basin of cell 1		Sensor 3 Typical Basin Temperature Sensor	
	Cooling Tower	Cell 2 Cold Basin Temperature	TMC50-HD	1 minute	Hot basin of cell 1		Sensor 4	
10263769							Logger Screen shot of logger status at launch	
	South Tower MCC	Cooling tower 1 fan amps	CTV-B (50 amp)	1 minute	CT 1 feed at MCC	At MCC	Sensor 1 Central Plant MCC	1. See general note 2.
	South Tower MCC	Cooling tower 2 fan amps	CTV-B (50 amp)	1 minute	CT 2 feed at MCC		Sensor 2	
	South Tower MCC	CW Pump 1 amps	CTV-B (50 amp)	1 minute	CW Pump 1 feed at MCC		Sensor 3	
	South Tower MCC	CW Pump 2 amps	CTV-B (50 amp)	1 minute	CW Pump 2 feed at MCC		Sensor 4	
							Logger Screen shot of logger 10263769	
	South Tower CHW	Chiller 1 Amps	CTV-D (600 amp)	1 minute	Chiller 1 main switch		Sensor 1	1. David will ship down 600 amp CTs for you to use.
	South Tower CHW	Chiller 2 Amps	CTV-D (600 amp)	1 minute	Chiller 2 main switch		Sensor 2	
							Sensor 3	
							Sensor 4	
10263774							Logger	
	South Tower CHW	Chiller 1 EWT - Chilled Water	TMC20-HD	1 minute	Thermometer well	At chiller	Sensor 1 Logger Location	1. See general notes 1 and 3.
	South Tower CHW	Chiller 1 LWT - Chilled Water	TMC20-HD	1 minute	Thermometer well		Sensor 2 Sensors	
	South Tower CHW	Chiller 1 EWT - Condenser Water	TMC20-HD	1 minute	Thermometer well		Sensor 3 Sensor detail	
	South Tower CHW	Chiller 1 LWT - Condenser Water	TMC20-HD	1 minute	Thermometer well		Sensor 4	
10263767							Logger Logger 10263774 Launch	
	South Tower CHW	Chiller 2 EWT - Chilled Water	TMC20-HD	1 minute	Thermometer well	At chiller	Sensor 1 Logger Location	1. See general notes 1 and 3.
	South Tower CHW	Chiller 2 LWT - Chilled Water	TMC20-HD	1 minute	Thermometer well		Sensor 2 Sensors	
	South Tower CHW	Chiller 2 EWT - Condenser Water	TMC20-HD	1 minute	Thermometer well		Sensor 3	
	South Tower CHW	Chiller 2 LWT - Condenser Water	TMC20-HD	1 minute	Thermometer well		Sensor 4	
10263771							Logger Screen shots with bad sensor and fix	
	South Tower CHW	CHW Pump 1 Amps	CTV-D (200 amp)	1 minute	CT 1 feed at MCC	At MCC	Sensor 1 Central Plant MCC	1. See general note 2. 2. I have assumed a 20 amp CT will be big enough for the domestic water pumps.
	South Tower CHW	CHW Pump 2 Amps	CTV-D (200 amp)	1 minute	CT 2 feed at MCC		Sensor 2	
	South Tower DomWtr	Pump 1 Amps	CTV-A (20 amp)	2 seconds	DW Pump 1 feed in MCC		Sensor 3	
	South Water DomWtr	Pump 2 Amps	CTV-A (20 amp)	2 seconds	DW Pump 2 feed in MCC		Sensor 4	
10359812 (Carlos's logger)							Logger Logger 10263771 deployment screenshot	
	ST Eq. Rm. Conditions	ST Eq. Rm. Temperature	Internal	1 minute	On Top of DW Pump Panel	At DW Pumps	Sensor 1 Logger tied to conduit at Booster Pump	1. Borrow one of Carlos's loggers with an internal lighting sensor.
	ST Eq. Rm. Conditions	ST. Eq. Rm RH	Internal	1 minute	On Top of DW Pump Panel		Sensor 2	
	ST Eq. Rm. Conditions	ST Eq. Rm. Lighting Level	Internal	1 minute	On Top of DW Pump Panel		Sensor 3	
							Sensor 4	
10263768							Logger Screen shot of 10359812 launch	
	NT Lobby DD Unit	Supply fan amps	CTV-D (50 amp)	1 minute	VFD incoming line	Tie-wrapped to supply fan VFD	Sensor 1 Fan amps sensor	1. See general notes 1 and 4.
	NT Lobby DD Unit	Fan Leaving Air Temperature	TMC20-HD	1 minute	Downstream of fan		Sensor 2 Fan discharge sensor	
	NT Lobby DD Unit	Cold Deck Temperature	TMC20-HD	1 minute	Downstream of coil		Sensor 3 Cold deck sensor	
	NT Lobby DD Unit	Hot Deck Temperature	TMC20-HD	1 minute	Downstream of coil		Sensor 4 Hot deck sensor	
10264069							Logger Screen shot of logger ant launch	
	NT Lobby DD Unit	Return temperature	Internal	1 minute	In return duct	Tie-wrapped to duct support in the return duct	Sensor 1 Data logger - Initial deployment	1. Try to get the sensor into the system away from the door so that air leakage around the door does not influence the logger too much.
	NT Lobby DD Unit	Return RH	Internal	1 minute	In return duct		Sensor 2	
							Sensor 3	
							Sensor 4	
							Logger Screen shot of logger ant launch	
							Screen shot of logger re-deployment	

Monitoring Plan Resources

- Monitoring Plan Template (blank and a filled-out example)
- Monitoring Plan Blog Posts
- Data Logging Resources
- A Video
- All linked from this location
- <https://tinyurl.com/MonitoringPlans>



What Points Would You Monitor and What Tests Might You Run?



Water Source Heat Pump Loop


2022-11-16, DS

Adding Some Constraints

Your logger inventory


- 2 – four channel loggers
- 8 – temperature sensors
- 4 – CTs


What data points would you select to give you the most insight?



Water Source Heat Pump Loop

2022-11-16, DS






Let's Look at Some Data

<https://tinyurl.com/DataLoggingDecades>






What You Might Learn



Water Cooled Heat Pump Loop

March 27, 6 to 9 pm




— Supply Temperature °F

— Tower Return Temperature °F

— Tower Supply Temperature °F

— Tower Fan and Pump Current amps

What You Might Learn From the Pump




Design Condition

- 11 inch impeller
- Design Flow – 320 gpm
- Design Head – 100 ft.w.c.

Fredrick/Weinman Engineered Products 2 -1/2 KH, 2-1/2 x 3 x 12

Serial Number 110188-1-96, 1 inch pattern 4586 impeller, 20 hp, 1750 rpm, Curve number 2 -1/2KH-182




The information on this pump curve was reproduced from the manufacturers certified performance curves for the purposes of analysis and illustration. To verify certified performance for this pump, refer to the manufacturers certified performance curve

Does the Pump Head Seem Reasonable?

Fredrick/Weinman Engineered Products 2-1/2 KH, 2-1/2 x 3 x 12


Serial Number 110188-1-96, 1 inch pattern 4586 impeller, 20 hp, 1750 rpm, Curve number 2-1/2KH-182



The information on this pump curve was reproduced from the manufacturer's certified performance curves for the purposes of analysis and illustration. To verify certified performance for this pump, refer to the manufacturer's certified performance curve.



What You Might Learn From the Pump




Pump Test Results

- 11 inch impeller
- Wide open head – 84 – 86 ft.w.c.
- Flow (from pump curve) – 375 - 380 gpm
- Design Flow – 320 gpm


Fredrick/Weinman Engineered Products 2-1/2 KH, 2-1/2 x 3 x 12

Serial Number 110188-1-96, 1 inch pattern 4586 impeller, 20 hp, 1750 rpm, Curve number 2-1/2KH-182




Fredrick/Weinman Engineered Products 2-1/2 KH, 2-1/2 x 3 x 12

Serial Number 110188-1-96, 1 inch pattern 4586 impeller, 20 hp, 1750 rpm, Curve number 2-1/2KH-182





Fredrick/Weinman Engineered Products 2-1/2 KH, 2-1/2 x 3 x 12

Serial Number 110188-1-96, 1 inch pattern 4586 impeller, 20 hp, 1750 rpm, Curve number 2-1/2KH-182




Considering Heat Pump Interactions


Heat pump performance can be impacted by the flows and temperatures in the system



Heat pump performance at different flow rates, 85°F entering water temperature



Heat pump performand at different entering water temperatures, 3 gpm flow rate



Bottom Lines

Findings Summary Table			\$0.10 per kWh		\$0.78 per therm					
Item	Finding	Annual Electricity Savings		Annual Gas Savings		Total Annual Savings	Implementation Costs	Simple Payback	Recommended (Yes/No)	Note Reference
		kWh	\$	Therms	\$	\$	\$	Years		
Guest Housing Heat Pump Loops										
1	GHL4 - Potential to vary loop flow rate	41,540	\$4,154	0	\$0	\$4,154	\$22,704	5.5	Yes	Note 2
2	GHL2 - Cycle cooling tower pump as 1st stage	0	\$0	0	\$0	\$0	\$0	0.0	N/A	Note 1
3	GHL8 - Bypassing Flow around Heat Exchang	0	\$0	0	\$0	\$0	\$0	0.0	No	
4	GHL5 - Trim Cooling Tower Pump	40,396	\$4,040	0	\$0	\$4,040	\$9,000	2.2	Yes	
5	GHL1, GHL3 - Optimize closed loop	277,192	\$27,719	48,094	\$37,513	\$65,232	\$140,199	2.1	Yes	
Total for Guest Housing Heat Pump Loops		359,127	\$35,913	48,094	\$37,513	\$73,426	\$171,903	2.3		
Notes	1. This finding has already been implemented by the operating staff									
	2 The simple payback for this finding could be as low as 4 years. The energy savings is a conservative estimate.									
	3 Further investigation is needed to estimate benefits and cost for this measure.									
	4 Energy savings possible is a conservative estimate. The actual savings could be double from the amount listed									

Bottom Lines

Note that none of the savings opportunities are directly related to the heat pumps!

Findings Summary Table			\$0.10 per kWh		\$0.78 per therm					
Item	Finding	Annual Electricity Savings		Annual Gas Savings		Total Annual Savings	Implementation Costs	Simple Payback	Recommended (Yes/No)	Note Reference
		kWh	\$	Therms	\$	\$	\$	Years		
Guest Housing Heat Pump Loops										
1	GHL4 - Potential to vary loop flow rate	41,540	\$4,154	0	\$0	\$4,154	\$22,704	5.5	Yes	Note 2
2	GHL2 - Cycle cooling tower pump as 1st stage	0	\$0	0	\$0	\$0	\$0	0.0	N/A	Note 1
3	GHL8 - Bypassing Flow around Heat Exchanger	0	\$0	0	\$0	\$0	\$0	0.0	No	
4	GHL5 - Trim Cooling Tower Pump	40,396	\$4,040	0	\$0	\$4,040	\$9,000	2.2	Yes	
5	GHL1, GHL3 - Optimize closed loop	277,192	\$27,719	48,094	\$37,513	\$65,232	\$140,199	2.1	Yes	
Total for Guest Housing Heat Pump Loops		359,127	\$35,913	48,094	\$37,513	\$73,426	\$171,903	2.3		
Notes	1. This finding has already been implemented by the operating staff									
	2. The simple payback for this finding could be as low as 4 years. The energy savings is a conservative estimate.									
	3. Further investigation is needed to estimate benefits and cost for this measure.									
	4. Energy savings possible is a conservative estimate. The actual savings could be double from the amount listed									



Questions?



Together, Building
a Better California



Break Time

We will be back at ??:?? ?m Pacific Time



Together, Building
a Better California