

# Facility Dynamics

## *ENGINEERING*

## Controlling Analog Processes

Proportional Control and Proportional plus Integral plus Derivative Control

**Presented By:**

David Sellers; Facility Dynamics Engineering

Senior Engineer

NAVFAC, San Diego

# Control System Building Blocks

*Automatically adjust a piece of machinery to give us what we want by comparing what is going on to what we want to go on and making appropriate adjustments to the process we want to control*

# Control System Building Blocks

*Automatically adjust a piece of machinery to give us what we want by comparing **what is going on** to what we want to go on and making appropriate adjustments to the process we want to control*

Inputs

Measure the process variable

# Control System Building Blocks

*Automatically **adjust a piece of machinery** to give us what we want by comparing **what is going on** to what we want to go on and making appropriate adjustments to the process we want to control*

**Inputs**

**Outputs**

**Measure the process variable**

**Adjust the controlled variable**

# Control System Building Blocks

*Automatically **adjust a piece of machinery** to give us what we want by comparing **what is going on** to what we want to go on and **making appropriate adjustments** to the process we want to control*

Inputs

Outputs

Control Process

Measure the process variable

Adjust the controlled variable

Logic and algorithms that tries to bring the controlled variable into agreement with the set point

# Control System Building Blocks

Automatically *adjust a piece of machinery* to give us what we want by comparing *what is going on* to *what we want* to go on and *making appropriate adjustments* to the process we want to control

Inputs

Outputs

Control Process

Set Point


Measure the process variable

Adjust the controlled variable


Logic and algorithms that tries to bring the controlled variable into agreement with the set point

Our requirements for the process that is under control, which can be fixed or variable

ALTITUDE: 810 FEET  
 BAROMETRIC PRESSURE: 29.056 in. HG  
 ATMOSPHERIC PRESSURE: 14.271 psia



Are they appropriate for the climate?



TAB 12-1 - PROPORTIONAL AND PID CONTROL PROCESSES

ALTITUDE: 7 FEET  
 BAROMETRIC PRESSURE: 29.915 in. HG  
 ATMOSPHERIC PRESSURE: 14.693 psia

# Set Points

Are they appropriate for the climate?

Weather Data Location:  
 SAN\_FRANCISCO\_INTL\_AP, CALIFORNIA, USA






Chart by: AKTON PSYCHROMETRICS, [www.aktonassoc.com](http://www.aktonassoc.com)

D:\FIDE Tools\Ppsych Charts\San Francisco, CA Design Conditions Economizer Change-over 72 45.aad



ALTITUDE: SEA LEVEL  
 BAROMETRIC PRESSURE: 29.921 in. HG  
 ATMOSPHERIC PRESSURE: 14.696 psia



Are they appropriate for the load?





Chart by: AKTON PSYCHOMETRICS, [www.aktonassoc.com](http://www.aktonassoc.com)  
 D:\FDE Tools\Ppsych Charts\ASHRAE Space vs. Surgery 2.aad

TAB 12-1 - PROPORTIONAL AND PID CONTROL PROCESSES

# Set Points

Do the resets provide the intended value?



## Best Life Cycle Cost Towers

$t_{wb} = 72.9^{\circ}\text{F}$  (San Deigo Design Condition)

Target CW Temp	Lowered CW Temp	Tower fan kW penalty	Tonnage at which colder water could be produced (Note 1)	Break Even Point; kW per ton improvement at different load conditions, tons				
				100	200	300	400	500
85	77.41	10.24	311	0.10	0.05	0.03		
$t_{wb} = 60.0^{\circ}\text{F}$								
85	67.74	10.92	389	0.11	0.05	0.04	0.03	

## Best First Cost Towers

$t_{wb} = 72.9^{\circ}\text{F}$  (San Deigo Design Condition)


Target CW Temp	Lowered CW Temp	Tower fan kW penalty	Tonnage at which colder water could be produced (Note 1)	Break Even Point; kW per ton improvement at different load conditions, tons				
				100	200	300	400	500
85	78.30	25.52	311	0.26	0.13	0.09		

Note 1: Tonnage is based on a nominal 15,000 Btu/hr of heat rejection for every ton (12,000) Btu/hr of cooling.

# Two Different Worlds

**Where We Came From**


*Analog*  
*Continuously*  
*Variable*




**Where We Are**

**Digital**

Discrete units



# A 1950/60's Vintage Analog Controller






# A 1950/60's Vintage Analog Controller



# A 1950/60's Vintage Analog Controller






# A 1950/60's Vintage Analog Controller



# A 1950/60's Vintage Analog Controller





# A 1970's Vintage Control and Automation System






# A 1970's Vintage Control and Automation System



TAB 12-1 - PROPORTIONAL AND PID CONTROL PROCESSES






## Current Technology Control and Automation System – The Controller

# Not Being Able to See or Get Your Hands on What's Going On


*... a down side to DDC*



Black Box


# Even Though You Can't See Them ...

*... the inner workings and controlling software of a DDC controller are critical to success*




# Even Though You Can't See Them ...

*... the inner workings and controlling software of a DDC controller are critical to success*




# Even Though You Can't See Them ...

*... the inner workings and controlling software of a DDC controller are critical to success*




# Even Though You Can't See Them ...

*... the inner workings and controlling software of a DDC controller are critical to success*





# Step Outside the Black Box and its Still and Analog World



# Generally, there's Good News and Bad News

## Good News


- No moving parts in the controller
- More information
- Fast response
- Precision
- Modifications made by typing things in instead of wiring or piping things
- Infinitely flexible
- Cost effective
- Out of this world capabilities

## Bad News

- The controller is a black box
- The information may not be correct
- Capable of doing dumb things very quickly
- Capable of doing dumb things very precisely
- Not everyone took the high school typing elective
- Can implement misapplication of fundamentals
- Flexibility sacrificed by poorly defined designs in competitive bid environments
- Still have to deal with the real world



# By Definition, a Lot of HVAC Processes are *Continuously Variable*

## *Analog*




- Variable Air Volume
- Variable Flow Pumping
- Variable Speed Drives
- Variable Pitch Inlet Vanes
- Variable Pitch Fans
- Variable Flow Refrigeration


# By Nature, Most HVAC Components Have Analog, Non-linear Characteristics





# By Nature, Most HVAC Components Have Analog, Non-linear Characteristics



## Temperature Measurement Output Variation with Temperature





# By Nature, Most HVAC Components Have Analog, Non-linear Characteristics



TAB 3-3 - PUMPS AND FANS

6

# By Nature, Most HVAC Components Have Analog, Non-linear Characteristics









## A Simple Digital Control Process





## A Simple Digital Controller








## A Fun Digital Control Process




# Multiple Relays Allow You to Perform Logic



# Multiple Relays Allow You to Perform Logic



W-01 - Jeopardy Game Wiring - Overview



Drawn by: DAS Checked by: DAS  
December 26, 2005, Rev 1 12-29-05




# Simple Things are Sometimes Complex

Fan Truth Table					
Switch Position	60° Left	30° Left	Centered	30° Right	60° Right
Fan 1	Off	On	On	On	On
Fan 2	Off	Off	On	On	On
Fan 3	Off	Off	Off	On	On
Fan 4	Off	Off	Off	Off	On

# Simple Things are Sometimes Complex

Fan Truth Table					
Switch Position	60° Left	30° Left	Centered	30° Right	60° Right
Fan 1	Off	On	On	On	On
Fan 2	Off	Off	On	On	On
Fan 3	Off	Off	Off	On	On
Fan 4	Off	Off	Off	Off	On
Selector Switch Truth Table					
Desired Function					
	All Fans Off	Fan 1 Runs	Fans 1 and 2 Run	Fans 1, 2, and 3 Run	Fans 1, 2, 3, and 4 Run
Switch Position	60° Left	30° Left	Centered	30° Right	60° Right
Contact 1	Closed	Open	Open	Open	Open
Contact 2	Open	Closed	Open	Open	Open
Contact 3	Open	Open	Open	Closed	Open
Contact 4	Open	Open	Open	Open	Closed



# Multiple Relays Allow You to Perform Logic

*For more about how to make your own Jeopardy game, see [Learning about Relay Logic; Build Your Very Own Jeopardy Game](#) and [Making a Jeopardy Game Board in PowerPoint to Supplement Your Light and Buzzer System \(and Learning a Bit About PowerPoint Templates\)](#)*



# A Simple Analog Control System

Set Point and Throttling Range Adjustments

Sensor


Final Control Element

Feedback Mechanism




# A Simple Control Requirement


The make up valve is the device to be controlled; a.k.a. the Controlled Variable or Final Control Element




# A Simple Control Requirement




# A Simple Proportional Control System




# A Simple Proportional Control System



# A Simple Proportional Control System




# A Simple Proportional Control System






# A Simple Proportional Control System

By its nature, a proportional control system will always have a difference or “error” between the set point and the control point except at one specific condition




# A Simple Proportional Control System




# A Simple Proportional Control System

... but at some point, feedback from the process would interact with the control loop in a way that would make it unstable



# The Impact of Narrowing Throttling Range

Proportional band =400% and set point changed to 80%  
(black line)






# The Impact of Narrowing Throttling Range

Proportional band = 400% (black line)

Proportional band = 300% and set point changed to 80% (red line)




# The Impact of Narrowing Throttling Range

Proportional band = 400% (black line)

Proportional band = 300% (red line)

Proportional band = 200% and set point changed to 80% (blue line)




# The Impact of Narrowing Throttling Range

Proportional band = 400% (black line)

Proportional band = 300% (red line)

Proportional band = 200% (blue line)

Proportional band = 150% and set point changed to 80% (gray line)



# The Impact of Narrowing Throttling Range


Proportional band = 400% (black line)

Proportional band = 300% (red line)

Proportional band = 200% (blue line)

Proportional band = 150% (gray line)

Proportional band = 100% and set point changed to 80% (second black line)






# Bottom Lines On Proportional Control

1. All proportional control processes will show a difference between set point and control point (a.k.a. error) under all operating conditions other than one very specific condition
2. The error can be reduced by narrowing down the throttling range
3. There is a limit to how much you can narrow the throttling range with out hunting
4. The limit is a function of the physics of the control system; things like lags, play in the linkage system, the nature of the process, etc.

# Then a Miracle Occurs




# Proportional plus Integral plus Derivative Control (PID)

PID is the Miracle that can:

- Eliminate error
- Reduce the magnitude of a spike when a system is upset
- Reduce the settling time after an upset


# Eliminating Proportional Error; A Simple Proportional Control System Becomes Less Simple

By its nature, a proportional control system will always have a difference or “error” between the set point and the control point except at one specific condition







# Eliminating Proportional Error; A Simple Proportional Control System Becomes Less Simple




# Eliminating Proportional Error; A Simple Proportional Control System Becomes Less Simple



# Eliminating Proportional Error; A Simple Proportional Control System Becomes Less Simple




# Eliminating Proportional Error; A Simple Proportional Control System Becomes Less Simple







# The Impact of Adding Integral Gain




# The Impact of Adding Integral Gain



# The Impact of Adding Integral Gain




# Eliminating Proportional Error; A Simple Proportional Control System Becomes Less Simple






# Eliminating Proportional Error; A Simple Proportional Control System Becomes Less Simple




# Eliminating Proportional Error; A Simple Proportional Control System Becomes Less Simple



# The Impact of Adding Derivative Gain

Proportional + Integral + Derivative response;  
250% proportional band, Integral time = 0.75  
minutes, Derivative time = 0.1 minutes





# PID; *Its Been Around for a While*




Image courtesy Control Engineering Magazine

TAB 12-1 - PROPORTIONAL AND PID CONTROL PROCESSES



# PID Good News and Bad News

## Good News

Eliminate offset

- Save energy
- Improve precision

Minimize process swings at start-up

## Bad News

Not well understood by the HVAC industry

- More difficult to tune and adjust
- More difficult to maintain

Algorithm used varies with the manufacturer

- Tuning solution specifics are not portable
- Auto-tuning is not a panacea

Difficult to apply correctly

Often misapplied

# PID; The Math Perspective

$$\text{Output} = K_p \times \text{Proportional Offset} + K_I \times \sum_{\text{Time}} \text{Proportional Offset} + K_D \times \frac{\partial \text{Proportional Offset}}{\partial \text{Time}}$$

Where :

$K_p$  = Proportional Gain

$K_I$  = Integral Gain


$\sum_{\text{Time}} \text{Proportional Offset}$  = Accumulated proportional offset over time


$K_D$  = Derivative Gain

$\frac{\partial \text{Proportional Offset}}{\partial \text{Time}}$  = Rate of change of proportional offset over time

P only response - - -

## Integral Gain; Minutes per Repeat or Repeats per Minute








P only response - - -

PI response —

## Integral Gain; Minutes per Repeat or Repeats per Minute



# Potential Problems when Adding Integral Action

Loop instability unless a commensurate reduction in proportional gain is made


Tuning and maintenance become more complex, time consuming and difficult

“Wind-up” can occur


- During HVAC system overload conditions.
- During HVAC shut down if not handled appropriately

P only response - - -


## Derivative Gain is in Minutes



# Derivative Gain is in Minutes



# Derivative Gain is in Minutes





# Derivative Action Is Difficult to Apply

Provides no benefit if there is not enough

Too much can cause many more problems than it is worth

Typically not necessary for HVAC applications

Use it with **CAUTION!**