



Design Review for New Construction Commissioning and Beyond

Day 1 of 2



Presented By:

- David Sellers, Facility Dynamics Engineering
- Senior Engineer

Disclaimer

- The information in this document is believed to accurately describe the technologies described herein and are meant to clarify and illustrate typical situations, which must be appropriately adapted to individual circumstances. These materials were prepared to be used in conjunction with a free, educational program and are not intended to provide legal advice or establish legal standards of reasonable behavior. Neither Pacific Gas and Electric Company (PG&E) nor any of its employees and agents:
- Makes any written or oral warranty, expressed or implied, including, but not limited to, those concerning merchantability or fitness for a particular purpose;
- Assumes any legal liability or responsibility for the accuracy or completeness of any information, apparatus, product, process, method, or policy contained herein; or
- Represents that its use would not infringe any privately owned rights, including, but not limited to, patents, trademarks, or copyrights.

Copyright Materials

Some or all of this presentation may be protected by US and International Copyright laws. Reproduction, distribution, display and use of the presentation without written permission of the copyright holder is prohibited

Learning Objectives – Class Series

1. Attendees will be able to list the different phases in the design and construction process and where design review activities are desirable in that process.

Learning Objectives – Class Series

2. Attendees will be able to describe the importance of reviewing the construction documents and which drawings and specification sections to target in order to best address potential commissioning issues.

Learning Objectives – Class Series

3. Attendees will be able to discuss the importance of reviewing equipment submittals and shop drawings emphasizing the items to look for in order to best mitigate potential commissioning issues.

Learning Objectives – Class Series

4. Attendees will be able to explain how construction observation can be applied as a tool to complement the design review process for new construction projects.

Learning Objectives – Class Series

5. Attendees will recognize that the implementation phase of EBCx projects is often a small NCx project and that design review and construction observation are key aspects to the success of that process.

Agenda

1. Introduction
2. The Submittal Review Angle
3. The Construction Observation Angle
4. Pump Assessment Case Study
5. Design Conditions Assessment Case Study

Getting to Know You

Please visit the following link if you have not already while waiting for class to start and complete the form. This will help get us all acquainted with each other and also help the instructors target the content to the audience.

<https://tinyurl.com/PECDdesRevGet2Know>





Introduction

A Bit About Me



A Bit About Me

I intended to be an aircraft
maintenance engineer

*I'm doing something totally
different*



A Bit About Me

- HVAC field technician
- Control system designer
- HVAC designer
- MCC Powers system engineer
- Murphy Company controls and start-up engineer
- Project engineer
- Wafer fab facilities engineer and system owner
- A happily married PECl technical support engineer and trainer
- FDE Senior Engineer



I've Had Great Mentors Along the Way




Bill Coad's Thoughts on Energy Conservation

“... that is to practice our profession with an emphasis upon our responsibility to protect the long-range interests of the society we serve and, specifically, to incorporate the ethics of energy conservation and environmental preservation in everything we do.”


Energy Conservation is an Ethic
ASHRAE Journal, vol. 42, no. 7, p. 16-21

PDF available at
<https://tinyurl.com/EnergyConservationEthic>



My Most Important Lesson

It's all about the load profile





A Commissioning Resources Web Site

HOME BLOG RESOURCES TRAINING CONTACT

© Brother Placid Sellers; Saint Vincent Archabbey, Latrobe, Pennsylvania

What's New?

Search

Buildings are Talking to Us

We Just Need to Learn How to Listen

My Goal

Welcome to A Field Perspective on Engineering's commissioning resource website. For those who don't know me from my blog or some other venue, I am a senior engineer for a company named **Facility Dynamics Engineering** a.k.a FDE, which specializes in commissioning, control system design, and some forensic engineering work.




<http://www.av8rdas.com/>

Design Review Resources

A Field Perspective on Engineering

Engineering lessons from the field



← System Diagrams: Practice Making a System Diagram – The Answer

Simulating Small Pressures; My Inch Water Column Simulator →

Design Review Resources

Posted on October 13, 2013 by David Sellers

2023-04-24 Author's Note – This was originally posted in 1028. Some of the links in were broken because sites were modified or shut down. In this repost, I have gone through and fixed them. Otherwise, the post is unchanged from when I first put it up.

In the past, I have written a few posts that bring up the topic of design review including:

- [Equipment Replacement Cost Calculations; There's More to it than Simple Payback](#)
- [Design Review; Leveraging Opportunities Before Ideas Become Realities](#)
- [Design Review – Same Frame Size, Different Fan Sizes – Part 2](#)
- [Design Review – Taking a Look at Coil Options](#)

It's not unusual for people to ask me if I can suggest design review resources and that happened just the other day at dinner. So, I thought I would just make a blog post that shared what I know in answer to the request.

Incidentally, some of the posts above were from when the blog first started on the CSE web site. When the magazine shut down for a while and I decided to continue the blog on my

Click the Image to Visit Our Commissioning Resources Website



Subscribe to A Field Perspective on Engineering

▪ [RSS - Posts](#)

Archives

Select Month ▼

Categories

Select Category ▼

Site Administration

- [Site Admin](#)
- [Log out](#)
- [Entries feed](#)
- [Comments feed](#)
- [WordPress.com](#)



<https://tinyurl.com/DesignReviewResources>


A Question For You

<https://tinyurl.com/PECDesRevWhen2Do>



Typical New Construction Commissioning Activity

600,000 sq.ft. High Rise Basis



Design Review During NCx

Design Phase

- Bringing an integration perspective to the drawing board
- Bringing field experience to the drawing board
- Sooner may be better
- Allows the provider to learn the project

Construction Phase

- Takes the form of submittal review
- Some submittals may happen in multiple phases
 - Control system hardware
 - Control system installation
 - Control system database, logic and graphics

Typical New Construction Cx Issues

- Poor turn-down capabilities
- Unanticipated interactions
- Pump head is excessive
- Fan static is insufficient
- Rouge zones
- Control sensor calibration
- Control sensor location
- Control system logic
- Control system design
- Schedules missing
- Equipment missing




Typical Existing Building Cx Issues

- Poor turn-down capabilities
- Unanticipated interactions
- Pump head is excessive
- Fan static is insufficient
- Rouge zones
- Control sensor calibration
- Control sensor location
- Control system logic
- Control system design
- Schedules missing
- Equipment missing



Typical Existing Building Construction Commissioning Activity

750,000 sq.ft. Hospital Basis



Processes that Complement Design Review

Submittal Review

- You are about to transition from concepts on paper to physical, wired, bolted, welded in place reality
- Just because you asked for it does not mean someone read the spec and drawings and thus, you will get it

See previous comments regarding cable termination details, shields, etc.

AC-1 Control Schematic
Location: Evidence Storage Roof Top
DSHQ202-#W030305HX

AC-1 Wiring Diagram
Location: Evidence Storage Roof Top (in the Unit)

Tag	Manufacturer	Part Number	Product Description	Quantity	Panel Or Field
ALC-1	Automated Logic	ZN511	Zone Controller, 8DO, 8IA, 1AO	1	P
TS-1	Automated Logic	ZSDPLV4ALC	ZSD Plus Space Temp Sensor with 4in. Rtd, SP Adj, Onst	1	P
TS-2	BAUTHER	BA170-204F-4812	Coat. 17' max/min in BAUTHER 17' NEMA 4X	1	P
CR-1	Phoenix Contact	RFP-4-RPTLV2-240V1Q1-2803541	SPOT Relay & Base, 24VAC Coil, 15A Switching Current	1	P
CR-2	Phoenix Contact	RFP-4-RPTLV2-240V1Q1-2803541	SPOT Relay & Base, 24VAC Coil, 15A Switching Current	1	P
SC-1	Siemens	5YD00	Contact Switch, 500V, 10A, 1P, 1C, 1N, 1D, 1E, 1F, 1G, 1H, 1J, 1K, 1L, 1M, 1N, 1O, 1P, 1Q, 1R, 1S, 1T, 1U, 1V, 1W, 1X, 1Y, 1Z	1	P

It would be good to include a control panel layout detail like you do for the other systems.

dsellers

This comment generally applies to all of the wiring diagrams.


Please include the equipment manufacturer's wiring diagram as a separate drawing so that this drawing set provides the Owner with a "full deck" regarding how your wiring interfaces with their wiring.

On a related note, is there some sort of fire alarm shut down associated with this system or any other interlocks for that matter. I imagine the field verification process referenced in "Note 1" will pick this stuff up.

Processes that Complement Design Review

Construction Observation

- Just because you asked for it and marked up the submittal to reflect that does not mean that the information got to the field




Construction Documents

Processes that Complement Design Review

Construction Observation

- Just because you asked for it and marked up the submittal to reflect that does not mean that the information got to the field




Submittal

Processes that Complement Design Review

Construction Observation

- Just because you asked for it and marked up the submittal to reflect that does not mean that the information got to the field



Reality

Processes that Complement Design Review

Construction Observation

- Just because you asked for it and marked up the submittal to reflect that does not mean that the information got to the field
- Pausing for corrections mid-reality is better than making corrections later



Reality

Design Review Skills

Technical

- Understand systems and equipment
 - Design experience
 - Field experience
 - Mentoring
- O&M interest and perspective
- Recognize the load importance of the load profile and being able to follow it

Non-technical

- Detail oriented
- Integration perspective
- People skills
- Curious
- Willing to learn
- Persistent

Design Review Targets



EnergyDesignResources.Com

Cx Assistant™

**Design Review Tool Module
Master Reference Guide**

Developed by
Portland Energy Conservation, Inc.

Under contract to
Pacific Gas and Electric Company

March 2007

Design Review Targets



EnergyDesignResources.Com

Cx Assistant™

**Design Review Tool Module
Master Reference Guide**

Developed by
Portland Energy Conservation, Inc.

Under contract to
Pacific Gas and Electric Company

March 2007

Design Review Master Reference Guide

Energy Design Resources Cx Assistant

Table of Contents

1. Sequence of Operation and Control Drawing Issues	7
2. Sensor Issues	20
3. Control Software and Hardware Issues	26
4. Maintainability Issues	35
5. Constructability Issues	41
6. Clarity and Detail of Contract Documents Issues	44
7. Specification of Requirements, Roles and Responsibilities Issues	51
8. Test Port and Gauge Issues	55
9. Energy Efficiency Issues	57
10. Air and Water Balancing Issues	71
11. Underfloor Air Distribution Issues	76
12. Moisture Issues – Envelope and HVAC Related	89
13. Staging and Low-Flow Operation Issues	95
14. Outdoor Air Control Issues	99
15. Duct Design Issues	104
16. Pump, Piping and Plant Design Issues	109
17. Building and Space Pressurization Issues	115
18. Daylight Dimming Issues	121

Let's Try It

Given

Fan Power Relationship

$$bhp_{Fan} = \left(\frac{Flow_{cfm} \times Static_{in.w.c.}}{6,356 \times \eta_{Fan}} \right)$$

Where:

bhp_{Fan} = Input to the system to produce the flow and static pressure.

$Flow$ = Flow rate in cubic feet per minute.


$Static$ = The fan static pressure in inches water column.

$6,356$ = A units conversion constant that is good for air at approximately 0 - 2,000 feet_{msl} and between -40°F and 120°F.

η_{Fan} = Fan static efficiency.


Given

V-Groove Blade
Fire/Smoke Damper
Detail on the drawings
for a project



Given

V-Groove Blade Fire/Smoke Damper Product Data



Given

V-Groove Blade



Given

Fabricated Airfoil Blade




Given

Extruded Airfoil Blade



Given

Pressure Drop Curves



A Question For You


<https://tinyurl.com/PECDesRevFSD>



Damper Pressure Drop vs. Flow

Greenheck Dampers
24" x 24" damper size

Damper is the full size of the duct with straight duct entering and leaving






11/14/2002





11/14/2002
















Let's Try Another

Given


The installed reality



Given

A Few “Rules of Thumb”

1. Designers will go up a line size if the friction rate exceeds 4 ft.w.c. per 100 ft. of pipe
2. The equivalent feet of pipe will be 1.5 to 2 times the linear feet of pipe



Given

The pump portion of the equipment schedule

Pump Schedule

Pump Number	Unit or System Served	Make	Model	Flow, gpm	Head, ft.w.c.	Impeller Diameter, in.	Rpm	Bhp	Minimum Pump Efficiency	Hp	Motor	Phase	Comments
											Volts		
CHWP-01	Chiller 01 Evaporator Pump	Bell and Gossett	1510 6G	1,100	40	10-7/8	1,150	13.6	82.1%	15.0	480.0	3.0	
CHWP-02	Chiller 02 Evaporator Pump	Bell and Gossett	1510 6G	1,100	40	10-7/8	1,150	13.6	82.1%	15.0	480.0	3.0	
CHWP-03	Chilled Water Distribution Pump	Bell and Gossett	1510 5A	1,100	90	6	3,550	34.7	72.0%	40.0	480.0	3.0	Note 1,3
CHWP-04	Chilled Water Distribution Pump	Bell and Gossett	1510 5A	1,100	90	6	3,550	34.7	72.0%	40.0	480.0	3.0	Note 1, 3
CWP-01	Chiller 01 Condenser Pump	Bell and Gossett	1510 6E	1,650	84	10-1/4	1,770	40.7	85.9%	50.0	480.0	3.0	Note 2
CWP-02	Chiller 02 Condenser Pump	Bell and Gossett	1510 6E	1,650	84	10-1/4	1,770	40.7	85.9%	50.0	480.0	3.0	Note 2

Notes

1. VFD Rated Motor
2. Pump selection allows for the head required for the future addition of a 550 ton absorbtion chiller
3. Revision 1, VE Analysis

1

Given

The cooling coil portion of the equipment schedule

Cooling Coil Schedule																	
Coil Number	Unit or System Served	Flow, cfm	Maximum Fins per Inch	Rows	Minimum Face Area, sq.ft.	Airside Performance						Waterside Performance					Comments
						Entering Air		Leaving Air		Face Velocity, fpm	Pressure Drop, in.w.c.	Entering Water Temperature, °F	Leaving Water Temperature, °F	Flow Rate, gpm	Pressure Drop, ft.w.c.	Tons	
						Dry bulb, °F	Wet bulb, °F	Dry bulb, °F	Wet bulb, °F								
CC-1	AHU1 - Hotel Lobby and Administration	26,000	8	6	52.0	81.0	63.8	51.0	50.5	433	0.63	42.0	56.0	141.0	8.6	82.2	Note 3
CC-2	Main Ball Room	20,000	9	6	40.0	86.6	66.1	51.4	50.9	500	0.82	42.0	54.0	148.7	11.0	74.4	Note 3
CC-3	Junior Ball Room	15,000	8	6	30.0	80.2	63.5	51.7	51.1	500	0.74	42.0	54.0	88.7	9.2	44.3	Note 3
CC-4	Meeting Rooms	15,000	9	6	30.0	90.3	67.6	52.2	51.6	500	0.83	42.0	54.0	120.1	9.1	60.1	3-way valve, Notes 1, 4
CC-5	Corridor Make-up Air	23,775	8	6	47.6	90.3	67.6	53.7	52.9	495	0.74	42.0	54.0	177.0	4.9	88.5	Note 4
CC-6	Corridor Make-up Air	23,775	8	6	47.6	90.3	67.6	53.7	52.9	495	0.74	42.0	54.0	177.0	4.9	88.5	Note 4
CC-7	Laundry	10,000	8	6	20.0	81.3	65.0	53.9	53.3	500	0.75	42.0	54.0	57.9	3.1	29.0	Note 3
CC-8	Breakfast/Lunch Café	6,500	8	6	13.0	82.7	64.5	50.9	50.4	406	0.56	42.0	54.0	43.9	7.8	21.9	3-way valve, Notes 1,3
CC-9	Restaurant and Lounge	11,500	8	6	23.0	82.7	64.5	51.8	51.2	479	0.70	42.0	54.0	73.7	9.3	36.9	Note 3
CC-10	Main Kitchen	19,000	8	6	38.0	88.5	67.6	51.5	51.0	396	0.56	42.0	54.0	157.2	9.2	78.6	Note3
VF-1	Electrical Room	8,200	8	3	16.4	83.7	67.6	60.7	57.9	410	0.35	42.0	54.0	42.5	9.8	21.2	Note 3
CC-GR01	Typcial North Exposure Guest Room (294 thus)	300	14	3	1.4	72.0	60.0	49.4	49.0	214	0.15	42.0	48.6	2.7	3.5	0.7	Note 2
CC-GR02	Typcial East Exposure Guest Room (22 thus)	400	14	3	1.4	72.0	60.0	51.2	50.5	285	0.22	42.0	49.4	2.8	3.7	0.9	Note 2
CC-GR03	Typcial South Exposure Guest Room (292 thus)	600	14	3	2.2	72.0	60.0	50.4	49.8	275	0.21	42.0	50.1	4.1	9.7	1.4	Note 2
CC-GR04	Typcial West Exposure Guest Room (22 thus)	400	14	3	1.4	72.0	60.0	51.2	50.5	285	0.22	42.0	49.4	2.8	3.7	0.9	Note 2
CC-CR05	Typcial Luxury Guest Room (4 thus)	1,000	14	3	3.2	72.0	60.0	51.2	50.4	313	0.26	42.0	50.3	6.3	8.9	2.2	0

- Note 1Bypass balanced to 5 gpm with the valve positioned to full bypass
- Note 2One fan coil at the top of each riser to have a three way valve with the bypass balanced to the fan coil design flow rate when the valve in full bypass
- Note 3Integrated economizer equipped
- Note 4100% outdoor air

Assignment


- Assess the diversity designed into the chilled water plant
- Estimate the pump head required for an evaporator pump

A resource:

<https://tinyurl.com/FieldEstimate>



Cooling Coil Schedule																	
Coil Number	Unit or System Served	Flow, cfm	Maximum Fins per inch	Rows	Minimum Face Area, sq ft	Airside Performance						Waterside Performance				Comments	
						Entering Air		Leaving Air		Face Velocity, fpm	Pressure Drop, in.w.c.	Entering Water Temperature, °F	Leaving Water Temperature, °F	Flow Rate, gpm	Pressure Drop, ft.w.c.		Tons
						Dry bulb, °F	Wet bulb, °F	Dry bulb, °F	Wet bulb, °F								
CC-1	AHU - Hotel Lobby and Administration	25,000	8	6	52.0	81.0	62.8	81.0	60.5	322	0.53	42.0	56.0	21.0	8.5	Note 2	
CC-2	Room Ball Room	10,000	8	6	40.0	86.6	66.1	81.2	59.5	700	0.80	48.0	54.0	14.7	11.0	Note 3	
CC-3	Junior Ball Room	10,000	8	6	30.0	85.3	63.0	81.7	61.1	500	0.74	42.0	54.0	8.7	8.5	Note 3	
CC-4	Meeting Rooms	10,000	8	6	30.0	85.3	62.8	82.2	61.6	500	0.80	42.0	54.0	10.5	9.1	Pump value, 46 tons 1, 2	
CC-5	Corridor Make-up Air	11,775	8	6	47.8	85.1	62.8	82.2	61.2	395	0.73	42.0	54.0	17.0	4.9	Note 4	
CC-6	Corridor Make-up Air	11,775	8	6	47.8	85.7	62.8	82.7	61.2	405	0.74	42.0	54.0	17.0	4.9	Note 4	
CC-7	Kitchen	10,000	8	6	25.0	81.2	68.0	82.8	61.3	400	0.78	42.0	54.0	9.2	9.1	Note 2	
CC-8	Breakfast/Lunch Cafe	6,500	8	6	13.0	82.7	64.5	82.5	60.8	400	0.50	48.0	54.0	4.3	7.8	Pump value, 10 tons 1, 2	
CC-9	Restaurant and Lounge	11,000	8	6	23.0	82.7	64.5	81.8	61.2	420	0.70	42.0	54.0	7.3	9.2	Note 2	
CC-10	Bar Kitchen	10,000	8	6	18.0	88.0	67.8	81.5	61.0	384	0.56	42.0	54.0	10.2	9.2	Note 2	
CC-11	Electrical Room	8,200	8	6	16.8	83.7	62.8	82.7	61.0	410	0.36	42.0	54.0	4.0	9.8	Note 2	
CC-12	Typical North 8 duplex (Over 800 sq ft)	300	14	3	1.4	72.0	60.0	42.4	49.0	214	0.15	42.0	48.0	2.7	8.5	Note 2	
CC-13	Typical East Exposure Board Room (220 sq ft)	400	14	3	1.4	72.0	60.0	50.4	50.5	280	0.14	42.0	48.0	3.6	8.7	Note 2	
CC-14	Typical South Exposure Board Room (220 sq ft)	400	14	3	2.2	72.0	60.0	50.4	49.8	279	0.13	42.0	48.0	4.1	9.7	1.4 Note 2	
CC-15	Typical West Exposure Board Room (220 sq ft)	400	14	3	1.4	72.0	60.0	50.4	50.5	280	0.14	42.0	48.0	3.6	8.7	Note 2	
CC-16	Typical Lobby Board Room (400 sq ft)	1,000	14	3	3.5	72.0	60.0	50.2	50.4	310	0.16	42.0	50.3	6.3	8.4	2.3 0	
Note 1	Bypass balanced to 5 gpm with the valve positioned to full bypass																
Note 2	One fan coil at the top of each riser to have a three way valve with the bypass balanced to the fan coil design flow rate when the valve is full bypass																
Note 3	Integrated economizer equipped																
Note 4	100% outdoor air																




Pump Number	Unit or System Served	Make	Model	Flow, gpm	Head, ft. w.c.	Impeller Diameter, in.	Rpm	Bhp	Minimum Pump Efficiency	Hp	Motor Volts	Phase	Comments
CHWP-01	Chiller 01 Evaporator Pump	Bell and Gossett	1510 66	1,300	40	10-7/8	1,150	13.6	82.1%	15.0	480.0	3.0	
CHWP-02	Chiller 02 Evaporator Pump	Bell and Gossett	1510 66	1,300	40	10-7/8	1,150	13.6	82.1%	15.0	480.0	3.0	
CHWP-03	Chilled Water Distribution Pump	Bell and Gossett	1510 5A	1,300	90	10-7/8	1,150	34.7	73.0%	40.0	480.0	3.0	Note 1, 3
CHWP-04	Chilled Water Distribution Pump	Bell and Gossett	1510 5A	1,300	90	10-7/8	1,150	34.7	73.0%	40.0	480.0	3.0	Note 1, 3
CWP-01	Chiller 01 Condenser Pump	Bell and Gossett	1510 6E	1,650	84	10-1/4	1,770	40.7	85.9%	50.0	480.0	3.0	Note 2
CWP-02	Chiller 02 Condenser Pump	Bell and Gossett	1510 6E	1,650	84	10-1/4	1,770	40.7	85.9%	50.0	480.0	3.0	Note 2


Notes:
 1. VFD Rated Motor.
 2. Pump selection allows for the head required for the future addition of a 850 ton absorption chiller.
 Revision 1, VE Analysis


Pump Curve Refresher


Digitized Curve



Vendor's Curve








Let's Try Another


Given

The kW per Ton Concept




Given

Proposed CHW Schematic



Given

Proposed CW Schematic



Given

Proposed chiller performance

CHILLERS - WATER COOLED

MARK LOCATION SERVES		CH-1	CH-2	CH-3
		MECH RM	MECH RM	MECH RM
		CLG WATER	CLG WATER	CLG WATER
CAPACITY	TONS	300.0	1,000.0	1,000.0
	KW/TON	0.554	0.470	0.470
	COP			
COMPRESSOR	TYPE	CNTFGL	CNTFGL	CNTFGL
	QUANTITY: NO	2	3	3
EVAPORATOR	FLOW: GPM	450	1,500	1,500
	EWT: F	59	59	59
	LWT: F	43	43	43
	PD: FT HD	11	18	18
	FOULING FACTOR	0.00010	0.00010	0.00010
CONDENSER	FLOW: GPM	850	2,800	2,800
	EWT: F	86	86	86
	LWT: F	76	76	76
	PD: FT HD	15	16	16
	FOULING FACTOR	0.00025	0.00025	0.00025
REFRIGERANT	TYPE	R-134A	R-134A	R-134A
	CHARGE: LBS	895	2851	2851
ELECTRICAL	VOLT/PHASE	460/3	460/3	460/3
	TOTAL KW	163.3	470.4	470.4
	MCA	261	518 [3]	518 [3]
	MOP	350	724 [3]	724 [3]
	SCCR: AMPS	100,000	100,000	100,000
	WEIGHT: LBS	10,000	35,000	35,000
BASIS OF DESIGN	MANUFACTURER	SMARDT	SMARDT	SMARDT
	MODEL	WA095.2H	WV400.3U	WV400.3U
	NOTES	[1, 2, 4, 6]	[1, 2, 4, 6]	[1, 2, 4, 6]

PROVIDE ALL CHILLERS FROM ONE MANUFACTURER.

NOTES:

1. SINGLE POINT CONNECTION, REFER TO ELECTRICAL DRAWINGS.
2. MAGNETIC BEARING, OIL-LESS COMPRESSORS.
3. RATINGS PER COMPRESSOR.
4. PROVIDE ONE SPARE COMPRESSOR FOR EACH SIZE USED IN THE NOMINAL 300 TON AND 1000 TON CHILLERS. DELIVER AT END OF WARRANTY PERIOD - ALTERNATE BID ITEM.
5. PROVIDE 5 YEAR WARRANTY - ALTERNATE BID ITEM.
6. PROVIDE MARINE BOXES AT ENDS WITH PIPING CONNECTIONS (300 LB PRESSURE CLASS ON EVAPORATOR) AND HINGED ACCESS AT ALL ENDS.

Given

Proposed pump performance

PUMPS - HYDRONIC							
MARK LOCATION SERVES		P14-1	P14-2	P14-3	P14-4	P14-5	P14-6
		MECH RM	MECH RM	MECH RM	MECH RM	MECH RM	MECH RM
		CHILLED WTR	CHILLED WTR	CHILLED WTR	COND WTR	COND WTR	COND WTR
CAPACITY	FLOW: GPM	500	1,500	1,500	900	3,500	3,500
	TDH: FT	120	160	160	60	60	60
	EFFICIENCY: %	75	79	79	67	74	74
TYPE	DESCRIPTION	VIL	VIL	VIL	VIL	VIL	VIL
	MOTOR RPM	1,800	1,800	1,800	1,800	1,800	1,800
	MAX BHP	27.00	87.00	87.00	21.00	70.00	70.00
	SUCT CONN: IN	6	8	8	8	12	12
	DISCH CONN: IN	6	8	8	8	12	12
	IMP DIA: IN	11.20	13.26	13.26	8.34	10.00	10.00
ELECTRICAL	VOLT/PHASE	460/3	460/3	460/3	460/3	460/3	460/3
	MOTOR HP	40	100	100	25	75	75
	SCCR: AMPS	35,000	65,000	65,000	14,000	35,000	35,000
OPER WEIGHT	WEIGHT: LBS	1,050	2,150	2,150	950	2,600	2,600
BASIS OF DESIGN	MANUFACTURER	PACO	PACO	PACO	PACO	PACO	PACO
	MODEL	VLS 6x6x11.5	VLS 8X8X15	VLS 8X8X15	VLS 6x6x11.5	VLS 12x12x13	VLS 12x12x13
	NOTES	[1, 2, 3, 4]	[1, 2, 3, 4]	[1, 2, 3, 4]	[1, 2, 3, 4]	[1, 2, 3, 4]	[1, 2, 3, 4]

PROVIDE ALL PUMPS FROM ONE MANUFACTURER.

NOTES:

1. REFER TO ELECTRICAL DRAWINGS FOR DISCONNECT SWITCH.
2. PROVIDE WITH VARIABLE FREQUENCY DRIVE AND SUCTION DIFFUSER.
3. MOUNT PUMP ON SPRING ISOLATED CONCRETE INERTIA BASE; OPER WEIGHT DOES NOT INCLUDE INERTIA BASE.
4. PROVIDE ALL PUMPS WITH SUCTION DIFFUSERS; 300 LB PRESSURE CLASS ON CHILLED WATER PUMPS.

Given

Proposed cooling tower performance

COOLING TOWERS			
MARK LOCATION SERVES		CT-1A	CT-1B
		ROOF	ROOF
		CHILLERS	CHILLERS
TYPE	AIRFLOW CONFIG	IND DRAFT	IND DRAFT
	DISCHARGE	VERTICAL	VERTICAL
	CELLS	2	2
CAPACITY [1]	HEAT REJ: TONS	1,185	1,185
	FLOW: GPM	3,450	3,450
	AMBIENT WB: F	66	66
	EW: F	86	86
	LWT: F	76	76
	PD: FT HD	12	12
FAN	TYPE	SILENT PROP	SILENT PROP
	FANS: NO	2	2
	AIRFLOW: CFM	268,800	268,800
	ESP: IN WG	—	—
	TOTAL MOTOR HP	60	60
	PONY MOTOR HP	—	—
	VOLT/PHASE	460/3	460/3
BASIN HEATER	HEATERS	—	—
	CAPACITY: KW	—	—
	VOLT/PHASE	460/3	460/3
ELECTRICAL	SCCR: AMPS	14,000	14,000
OPER WEIGHT	WEIGHT: LBS	43,780	43,780
BASIS OF DESIGN	MANUFACTURER	EVAPCO	EVAPCO
	MODEL	UT-224-418	UT-224-418
	NOTES	[2-7]	[2-7]


PROVIDE ALL COOLING TOWERS FROM ONE MANUFACTURER.

NOTES:

1. CAPACITIES BASED ON WATER.
2. REFER TO ELECTRICAL DRAWINGS FOR MOTOR STARTER AND DISCONNECT SWITCH.
3. PROVIDE WITH VIBRATION CUTOFF SWITCH.
4. PROVIDE WITH VARIABLE SPEED DRIVE AND FAN MOTORS.
5. PROVIDE WITH VORTEX ELIMINATOR AND BOTTOM PIPING CONNECTIONS.
6. PROVIDE STAINLESS STEEL PAN AND SUMP SWEEP PIPING/NOZZLES.
7. PROVIDE WITH REMOVABLE MOTOR LIFTING DAVIT PER 2-CELL TOWER, AND LIFTING DAVIT MOUNTING CHANNEL ON EACH TOWER CELL.

Given


Proposed kW per ton profile



A Question For You

<https://tinyurl.com/PECDesRevkWPerTon>





Annual Hours at Tonnages Based on a Regression from Measured Data

Plant kW/ton from June 2017 CDs

Pump Power Relationship

$$bhp = \left(\frac{Flow \times Head}{3,960 \times Efficiency_{Pump}} \right)$$

Where:

Flow = Flow produced by the pump in gpm

Head = Head produced by the pump in feet water column

3,960 = A units conversion constant that will work for water at the temperatures and pressures typically encountered in HVAC systems.

$Efficiency_{Pump}$ = Pump efficiency, read from the pump curve or estimated from past experience;
.40 - .70 for small (under 500 gpm) pumps, .70 - .85 for large pumps

$$kW = \left(\frac{Flow_{gpm} \times Head_{ft.w.c.}}{3,960 \times \eta_{Pump} \times \eta_{Motor} \times \eta_{VSD}} \right) \times .746$$

System Configuration

- ☒ General
☐ Pressure Booster

System Parameters

Total Flow Gallons / Minute ▼

Head Feet of Water ▼

Number of Pumps in Parallel ▼

Motor Parameters

▼

- ☐ ESP-Optimized™ Motor Selection
☒ Use Non-Overloading Motors
☐ Select Motor Using Duty Point

Minimum HP Req. ▼

System Options

Fluid Property

Current Fluid: Water

Max NPSHr:

Pump Series

All Pumps Shown
Ecocirc_XL Small Circulator Pumps
Booster Small Circulator Pumps
60-ECM Series 60 With ECM Motor
60 & 60-STOCK In-Line 1" to 2-1/2"
1522 Floor-mounted Booster
e-90-ECM e-90 With ECM motors
90 & e-90 In-Line Close Coupled, 1" to 3"
1535 Small Close Coupled
80 In-Line Closed Coupled, 1-1/2" to 8"
80SC In-Line Split Coupled, 1-1/2" to 14"
e-1510 Base-mounted End-suction
1531 & e-1531 & e-1532 Cls-cpld End-suction
VSX-VSC New Dbl-Suction Pump
VSX-VSCS New Dbl-Suction Pump
VSX-VSH New Dbl-Suction Pump

- ☒ Show All
☐ Base-Mounted
☐ In-Line

For multiple pumps in parallel, system flow will be split equally among pumps.

Select Pumps




Bell & Gossett
a xylem brand




Let's Work on This One Together

Given an Owners Requirement




- Winter Indoor Dry Bulb Temperature Target – 68°F – 72°F
- Winter Indoor Relative Humidity Target – 25% - 35%

An Early Design Development Meeting




- The project is projecting to be over budget
- It may be necessary to eliminate commissioning from the project

The Pacific NW Climate



File Not Saved

Is There Something We Can Do to Keep Commissioning in the Project



Some psychrometric resources

- <https://tinyurl.com/FreePsychChart>



- <https://tinyurl.com/OlivieriChapters>




- <https://tinyurl.com/SlfSLoadsPsych>



Let's Try Another Submittal Review

Given Submittal Data


Basis of Design



Submitted



These files in the class materials




Answer the Questions at This Link

<https://tinyurl.com/PECDdesRevBoiler>



Comparing the Boilers



Leaving water temperature restricted to 130°F minimum


Noncondensing heat exchanger restricted to 130°F EWT

Pump and control valve control EWT and make boiler loop variable flow

Condensing heat exchanger

Entering water temperature range – 85 - 160°F

Constant volume pumping circuit



Comparing the Boilers

The primary difference between the Aerco Benchmark BMK2.0 boilers (left illustration) that were the basis of design and the Lochinvar Intellifin IBM2000 boilers (right illustration) that were actually furnished is that the Aerco units employ a single heat exchanger, rated and designed for condensing operation. In contrast, the Lochinvar units employ two heat exchangers, one of which (termed the secondary heat exchanger) is rated and designed for condensing operation and one of which (termed the primary heat exchanger) is not. To protect the primary heat exchanger from damage due to the corrosive by-products associated with condensing operation, the Lochinvar boilers incorporate a circulating pump (A) and a control valve (B), arranged to ensure that the entering water temperature to the primary heat exchanger never drops below 130°F. This is accomplished by recirculating water from the boiler's discharge to the inlet side of the primary heat exchanger as indicated by the blue shaded arrow in the right illustration. For this approach to work, the boiler must be controlled so that the leaving water temperature from the primary heat exchanger is never below 130°F. As a result, a system that employs the Lochinvar units and must directly control for supply water temperatures below 130°F need to incorporate some other mechanism for achieving the supply temperature requirement while protecting the boilers. One common approach for accomplishing this is to provide the system with a three-way valve that allows water from the boiler loop to be mixed with return water from the system to achieve the required supply temperature. Since the Aerco boilers are rated to control directly for any set point from 50-190°F, the basis of design system did not incorporate such a feature. As a result, when the Lochinvar boilers are applied in the basis of design system configuration, there is no direct method for controlling supply temperature to a set point of 130°F. Rather, the master controller charged with cycling the boilers to maintain a desired system supply temperature must try to find a combination of boiler settings that indirectly produces the desired result by forcing the distribution system into an over-flow condition (distribution flow exceeds boiler loop flow) while the individual boiler controllers work to prevent the entering water temperature to their primary heat exchangers from dropping below 130°F. This is a complex hydraulics problem at best and may be impossible to achieve under some operating conditions without considerable operator intervention.

Other Issues Identified During Construction Observation



Other Issues Identified During Construction Observation







Optional Assignment

Given the Pump Schedule

PUMP SCHEDULE									
PLAN MARK	MANUFACTURER & MODEL	LOCATION & SERVICE	GPM	FT. HD.	1 IMPELLER SIZE	MOTOR SPEED RPM	MOTOR		NOTES
							HP	VOLTS / ϕ	
MP-D12	B&G HSC-6X8X17M	'D' LEVEL - HEATING WATER	1380	193	15	1750	100	460/3 ϕ	2 3
MP-D13	B&G HSC-6X8X17M	'D' LEVEL - HEATING WATER	1380	193	15	1750	100	460/3 ϕ	2 3
MP-D14	GRUNDFOSS #CR16-30U	'D' LEVEL - BOILER FEED	83	140		3500	7 1/2	460/3 ϕ	5
MP-D15	GRUNDFOSS #CR16-30U	'D' LEVEL - BOILER FEED	83	140		3500	7 1/2	460/3 ϕ	5
MP-G1	B&G 60-2 AA	6D.FL.-AHU-G1	50	20	4 3/4	1750	3/4	460/3 ϕ	
MP-3B	B&G 60-1 1/2 AA	3rd FL.- AHU-3B	40	18	4 3/4	1750	1/2	460/3 ϕ	
MP-3D	B&G 60-1 1/2 AA	3rd FL.- AHU-3D	40	18	4 3/4	1750	1/2	460/3 ϕ	
MP-3G	B&G 80-2 1/2 X 2 1/2 X 7	3rd FL.- AHU-3G	120	25	6	1750	1 1/2	460/3 ϕ	
MP-3-1	B&G 80-3 X 3 X 8 1/2	3rd FL.- TOWER WATER	220	66	8 1/2	1750	7 1/2	460/3 ϕ	4 6
MP-3-2	B&G 1510-3 BB	3rd FL.- LOOP WATER	220	80	9	1750	10	460/3 ϕ	
MP-G3	B&G 60-2AA	GRD FL MEZE-AHU-G3	50	21	4 3/4	1750	3/4	"	4

2 400 PSIG WORKING PRESSURE.

6 HORIZONTAL MOUNT


3 PROVIDE WITH VARIABLE SPEED PUMPING SYSTEM - SEE SPEC.

4 250 PSIG WORKING PRESSURE.


5 CONTROL CABINET, C/W STARTERS, CIRCUIT BREAKERS, PILOT LIGHT AND HOA SELECTOR SWITCHES.

1 PROVIDE FULL SIZE IMPELLER, TRIMMED/SHAVED IMPELLER IS NOT ACCEPTABLE

Given the Basis of Design Pump Curve




Given the Submittal Pump Curve



Given the Manufacturers Catalog Data


Basis of Design



Submitted




These files in the class materials



Would You Approve the Substitution

- Why or why not?
- What other things might you comment on?



Questions?

Thank you for participating!


Visit our website at www.FacilityDynamics.com

Visit our blog at <https://av8rdas.wordpress.com/>

Visit our commissioning resources website at <https://www.av8rdas.com/>

Contact me at Dsellers@FacilityDynamics.com

- David Sellers; Facility Dynamics Engineering
- Senior Engineer
- March 12, 2017



AEP 2023

