

# VAV Systems

Design, Performance and Commissioning Issues

Minimum Flow Settings



**Instructor:**

David Sellers

Senior Engineer

Facility Dynamics Engineering

March 7, 2018

ALTITUDE: SEA LEVEL  
BAROMETRIC PRESSURE: 29.921 in. HG  
ATMOSPHERIC PRESSURE: 14.696 psia

A Lower Mass Flow Rate  
Means a Given Load will  
Cause a Large Change  
in the State of the Air




Chart by: AKTON PSYCHROMETRICS, [www.aktonassoc.com](http://www.aktonassoc.com)

C:\Users\DSellers\Documents\FDE Tools\SketchUp\Marriott Ballroom AHU\Design Info Anahiem Marriott Basis\Ballroom Load Components - 10 - Less Flow.aad

MINIMUM FLOW SETTINGS

# What is in This Module?

- What sets the minimum flow in a VAV zone
- What limits how low you can go in terms of minimum flow
- What limits how high you can go in terms of maximum supply temperature
- The impact of minimum flow on heating capability
- VAV systems and diffuser performance

# Setting Minimum Flow

Based on the ventilation requirement at the zone level

- Contaminant (IEQ) control
- Rule of thumb – 15 cfm of outdoor air required per person
- Could be set by a code or production required air change rate

# Setting Minimum Flow

The volume required at the zone level is a function of the AHU's MOA setting

- For a 100% OA system
  - 15 cfm of OA at the zone equates to 15 cfm at the AHU intake
- For a system with a 10% MOA setting
  - To get 15 cfm of OA to the zone when the system is on MOA, the zone minimum needs to be set for 150 cfm

ALTITUDE: SEA LEVEL  
BAROMETRIC PRESSURE: 29.921 in. HG  
ATMOSPHERIC PRESSURE: 14.696 psia

Given the Goals of HVAC  
(Safe, Comfortable,  
Productive) Reheat  
May Eventually Be  
Required




Chart by: AKTON PSYCHROMETRICS, [www.aktonassoc.com](http://www.aktonassoc.com)

C:\Users\DSellers\Documents\FDE Tools\SketchUp\Marriott Ballroom AHU\Design Info Anahiem Marriott Basis\Ballroom Load Components - 12 - Minimum Flow.aad

MINIMUM FLOW SETTINGS

ALTITUDE: SEA LEVEL  
BAROMETRIC PRESSURE: 29.921 in. HG  
ATMOSPHERIC PRESSURE: 14.696 psia

Given the Goals of HVAC  
(Safe, Comfortable,  
Productive) Reheat  
May Eventually Be  
Required




Chart by: AKTON PSYCHROMETRICS, [www.aktonassoc.com](http://www.aktonassoc.com)

C:\Users\DSellers\Documents\FDE Tools\SketchUp\Marriott Ballroom AHU\Design Info Anahiem Marriott Basis\Ballroom Load Components - 12 - Minimum Flow.aad

MINIMUM FLOW SETTINGS

ALTITUDE: SEA LEVEL  
BAROMETRIC PRESSURE: 29.921 in. HG  
ATMOSPHERIC PRESSURE: 14.696 psia

# Resetting the Discharge Temperature May Be the Sensible Thing to Do




Chart by: AKTON PSYCHROMETRICS, [www.aktonnassoc.com](http://www.aktonnassoc.com)

C:\Users\DSellers\Documents\FDE Tools\SketchUp\Marriott Ballroom AHU\Design Info Anahiem Marriott Basis\Ballroom Load Components - 13 - Minimum Flow Reset.aad

MINIMUM FLOW SETTINGS



ALTITUDE: SEA LEVEL  
BAROMETRIC PRESSURE: 29.921 in. HG  
ATMOSPHERIC PRESSURE: 14.696 psia

# Resetting the Discharge Temperature May Be the Sensible Thing to Do




Chart by: AKTON PSYCHROMETRICS, [www.aktonnassoc.com](http://www.aktonnassoc.com)

C:\Users\DSellers\Documents\FDE Tools\SketchUp\Marriott Ballroom AHU\Design Info Anahiem Marriott Basis\Ballroom Load Components - 13 - Minimum Flow Reset.aad

MINIMUM FLOW SETTINGS

ALTITUDE: SEA LEVEL  
BAROMETRIC PRESSURE: 29.921 in. HG  
ATMOSPHERIC PRESSURE: 14.696 psia

# Consider this “Vanilla” System in St. Louis, MO At Design Conditions




Chart by: AKTON PSYCHROMETRICS, [www.aktonassoc.com](http://www.aktonassoc.com)

C:\Users\DSellers\Documents\FDE Tools\SketchUp\Marriott Ballroom AHU\Design Info Anahiem Marriott Basis\St. Louis 2014-08-27 - Design Cycle.aad

MINIMUM FLOW SETTINGS

ALTITUDE: SEA LEVEL  
BAROMETRIC PRESSURE: 29.921 in. HG  
ATMOSPHERIC PRESSURE: 14.696 psia

# Consider this “Vanilla” System in St. Louis, MO At Upper Reset Limit

Zone Cooling at  
Minimum Demand




Chart by: AKTON PSYCHROMETRICS, [www.aktonassoc.com](http://www.aktonassoc.com)

C:\Users\DSellers\Documents\FDE Tools\SketchUp\Marriott Ballroom AHU\Design Info Anahiem Marriott Basis\St. Louis 2014-08-27 - Reset Up.aad

MINIMUM FLOW SETTINGS

ALTITUDE: SEA LEVEL  
BAROMETRIC PRESSURE: 29.921 in. HG  
ATMOSPHERIC PRESSURE: 14.696 psia

# What's Taking the Water Out of the Air?





Chart by: AKTON PSYCHROMETRICS, [www.aktonassoc.com](http://www.aktonassoc.com)

C:\Users\DSellers\Documents\FDE Tools\SketchUp\Marriott Ballroom AHU\Design Info Anahiem Marriott Basis\St. Louis 2014-08-27 - Reset Up.aad

MINIMUM FLOW SETTINGS

ALTITUDE: SEA LEVEL  
 BAROMETRIC PRESSURE: 29.921 in. HG  
 ATMOSPHERIC PRESSURE: 14.696 psia

# What's Taking the Water Out of the Air?





ALTITUDE: SEA LEVEL  
BAROMETRIC PRESSURE: 29.921 in. HG  
ATMOSPHERIC PRESSURE: 14.696 psia

# You Won't Hit the ASHRAE Target




Chart by: AKTON PSYCHROMETRICS, [www.aktonassoc.com](http://www.aktonassoc.com)

C:\Users\DSellers\Documents\FDE Tools\SketchUp\Marriott Ballroom AHU\Design Info Anahiem Marriott Basis\St. Louis 2014-08-27 - Ground Water Temperatures High RH.aad

# Heating versus Reheat

## Heating


- Offset a loss of energy from the
- Occurs when ambient temperatures are below the room set point
- Deliver air at a temperature above the space temperature
- Diffusion of warm air can be an issue

## Reheat

- Offset unnecessary cooling provided by the required minimum flow rate
- Occurs year round
- Air frequently delivered below room temperature but above AHU discharge temperature
- Diffusion still can be an issue

# More Flow $\neq$ More Heating


What happens with this terminal unit control strategy if the minimum flow rate delivers more cooling than the space requires under most of the load conditions it might see?






# More Flow $\neq$ More Heating

Flow, cfm	Space Temperature, °F	Entering Air, °F	Leaving Air, °F	Capacity, Btu/hr	Simultaneous Heating and Cooling		Heat Available to Offset Losses	
					Btu/hr	% of Total	Btu/hr	% of Total
650	72	52	74	15,374	14,321	93%	1,053	7%




# More Flow $\neq$ More Heating

Flow, cfm	Space Temperature, °F	Entering Air, °F	Leaving Air, °F	Capacity, Btu/hr	Simultaneous Heating and Cooling		Heat Available to Offset Losses	
					Btu/hr	% of Total	Btu/hr	% of Total
650	72	52	74	15,374	14,321	93%	1,053	7%
352	72	52	85	12,545	7,755	62%	4,790	38%



# More Flow $\neq$ More Heating

Flow, cfm	Space Temperature, °F	Entering Air, °F	Leaving Air, °F	Capacity, Btu/hr	Simultaneous Heating and Cooling		Heat Available to Offset Losses	
					Btu/hr	% of Total	Btu/hr	% of Total
650	72	52	74	15,374	14,321	93%	1,053	7%
352	72	52	85	12,545	7,755	62%	4,790	38%
151	72	52	105	8,757	3,327	38%	5,431	62%



# Diffusers and Flow Variation

- Need to be designed for the full range of supply flow
- Performance with hot air different from performance with cold air
- Lower average velocity at lower flow rates
  - Less throw
  - Less mixing
  - “Dumping”

# Bottom Lines?

- Zone loads have to general components
  - Sensible load
  - Latent load
- Zone loads can vary quite a bit
- The coil leaving air temperature is driven by the dehumidification requirement (so is the plant leaving chilled water temperature)
- The zone flows are set based on the maximum sensible load, the coil leaving condition, and heat gains between the coil and the diffuser
- There are a lot of variable associated with designing and operating a Variable Air Volume system