

# Economizers: Design, Performance, and Commissioning Issues

## Economizer Basics




### Instructor:


- David Sellers
- Senior Engineer
- Facility Dynamics Engineering
- February 6, 2018

# What's In This Module?


- How buildings use outdoor air; Ventilation vs. Free Cooling
- Heating vs. Cooling Processes
- Integrated vs. Non-Integrated Economizers
- Return vs. Relief Fans



## Outdoor Air Above and Beyond the Ventilation Requirement



Outdoor Air Above and Beyond  
the Ventilation Requirement



## A “Free Cooling” Process

# Definition


## Cooling

*A process that removes energy. For a space, this is often accomplished by circulating air through it at a temperature below the required set point. For an airstream, this is often accomplished by passing it over a surface that is below the required supply temperature. If the surface is below the dew point of the air stream, dehumidification (moisture removal) will also occur.*

# Definition

## Heating

*A process that adds energy. For a space, this is often accomplished by circulating air through it at a temperature above the required set point. For an airstream, this is often accomplished by passing it over a surface that is above the required supply temperature.*




## A “Free Cooling” Process

It should shut down if no cooling is needed




# Should Core and Perimeter Zones be on the Same Economizer Equipped Air Handling System?


## January Core Load Profile



## January Perimeter Load Profile




58°F Set Point




Non-Integrated is Different  
from Integrated

58°F Set Point




Non-Integrated

58°F Set Point



Non-Integrated

58°F Set Point



Non-Integrated

ALTITUDE: SEA LEVEL  
 BAROMETRIC PRESSURE: 29.921 in. HG  
 ATMOSPHERIC PRESSURE: 14.696 psia






Chart by: AKTON PSYCHROMETRICS, [www.aktonassoc.com](http://www.aktonassoc.com)




58°F Set Point



Integrated


58°F Set Point



Integrated





58°F Set Point




Integrated

ALTITUDE: SEA LEVEL  
 BAROMETRIC PRESSURE: 29.921 in. HG  
 ATMOSPHERIC PRESSURE: 14.696 psia




# Non-integrated vs. Integrated



ECONOMIZER BASICS

13

- Cooling coil load
- $Q = 4.5 \times \text{cfm} \times \Delta h$
- $Q = 4.5 \times 30,000 \times (25.4 - 22.8)$
- $Q = 351,0000 \text{ Btu/hr}$
- $Q = 29.3 \text{ tons}$




ECONOMIZER BASICS

18

- Cooling coil load
- $Q = 4.5 \times \text{cfm} \times \Delta h$
- $Q = 4.5 \times 30,000 \times (22.8 - 22.6)$
- $Q = 27,0000 \text{ Btu/hr}$
- $Q = 2.3 \text{ tons}$


# Non-integrated vs. Integrated



ECONOMIZER BASICS

13

- Space Conditions
- Space temperature = 72°F
- Space RH = 50%
- Space enthalpy = 26.4 Btu/lb




ECONOMIZER BASICS

18


- Space Load (average cooling coil leaving conditions)
- $Q = 4.5 \times \text{cfm} \times \Delta h$
- $Q = 4.5 \times 30,000 \times (26.4 - 22.7)$
- $Q = 499,500 \text{ Btu/hr}$
- $Q = 41.6 \text{ tons}$

# Non-integrated vs. Integrated



ECONOMIZER BASICS

13



ECONOMIZER BASICS

18

## LOADS

Space

- 41.6 tons


Coil – Non-Integrated  
Economizer

29.3 tons

Coil – Integrated  
Economizer


2.3 tons

# Non-integrated vs. Integrated



ECONOMIZER BASICS

13



ECONOMIZER BASICS


18

- LOADS

- The coil load often is not the same as the space load*
  - Typically less if it is cool and dry outside*
  - Typically more if it is hot and humid outside*



# Non-integrated vs. Integrated




ECONOMIZER SAVINGS ASSESSMENTS - PART 1

15


- **LOADS**

- *The coil load often is not the same as the space load*
  - *Always the case for a 100% outdoor air system (all though at a very specific condition they could be numerically equal)*
  - *Integrated economizers are 100% outdoor air systems until the change-over happens at hot/humid outdoor conditions*


Economizers bring in **outdoor air** above and beyond the **ventilation** requirement, **mix it** with **return air** as required to control set point and thereby provide free cooling



A Quick Word about Economizers,  
Return Fans, and Relief Fans









# Return Fans

- Overcome the static pressure loss between the zone and the air handling system
- Operate any time the supply fan runs
  - Return air for recirculation
  - Frequently, deliver air to the relief louver for discharge to the exterior when operating on an economizer cycle
- Coordinating with VAV supply operation is tricky





# Relief Fans

- Overcome the static pressure loss between the air handling unit location and the relief louver
- Only operate during an economizer cycle
- VFD operation often coordinated with building pressure



# A Side by Side Comparison



## Bottom Lines

- Airside economizers bring in air above and beyond what we need to ventilate a building in order to minimize the cost of cooling
- Economizers are cooling process
  - Heating and economizing should not be happening at the same time
  - Consider separate HVAC systems for loads with dissimilar supply temperature profiles
- “Integrated economizer” refers to integrating the economizer cooling with mechanical cooling
  - Maximizes savings potential
  - Adds complexity
- The magnitude of the cooling coil load is often not the same as the magnitude of the zone cooling load
- Return fans and relief fans are different